

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.10-F10, Canadian Electrical Code, Part 1 (21th Edition), Safety Standard for Electrical Installations.
 - .2 CAN3-C235-F83(R2015), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC).
- .3 National Electrical Manufacturers Association (NEMA).
- .4 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
 - .1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.

1.2 DEFINITIONS

- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.

1.3 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
 - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates and labels for control items in English and French.
- .4 Use one nameplate or label for both languages.

1.4 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.

- .2 Shop drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Provinces and Territories of Canada.
 - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.
 - .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
 - .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
 - .5 Submit 1 number of copies of drawings and technical sheet in PDF format for verification.
 - .6 If changes are required, notify Departmental Representative of these changes before they are made.
- .3 Quality Control: in accordance with Section 01 45 00 - Quality Control.
 - .1 Provide CSA certified equipment and material.
 - .2 Where CSA certified equipment and material is not available, submit such equipment and material to authority having jurisdiction, inspection authorities for special approval before delivery to site.
 - .3 Submit test results of installed electrical systems and instrumentation.
 - .4 Permits and fees: in accordance with General Conditions of contract.
 - .5 Submit, upon completion of Work, load balance report as described in PART 3 - LOAD BALANCE.
 - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.

1.5 QUALITY
ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians who hold valid Master Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Act respecting manpower vocational training and qualification.

.1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.

.2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.

.3 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.15 - Health and Safety Requirements.

1.6 DELIVERY, STORAGE AND HANDLING

.1 Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.

.2 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling.

1.7 SYSTEM STARTUP

.1 Instruct Departmental Representative and operating personnel in operation, care and maintenance of systems, system equipment and components.

1.8 OPERATING INSTRUCTIONS

.1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.

.2 Operating instructions to include following:
.1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
.2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
.3 Safety precautions.
.4 Procedures to be followed in event of equipment failure.
.5 Other items of instruction as recommended by manufacturer of each system or item of equipment.

.3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.

.4 Post instructions where directed.

.5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.

- .6 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

PART 2 - PRODUCTS

2.1 MATERIALS AND EQUIPMENT

- .1 Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Material and equipment to be CSA certified. Where CSA certified material and equipment is are not available, obtain special approval from authority having jurisdiction inspection authorities before delivery to site and submit such approval as described in PART 1 - SUBMITTALS.
- .3 Factory assemble control panels and component assemblies.

2.2 WARNING SIGNS

- .1 Warning Signs: in accordance with requirements of authority having jurisdiction and Departmental Representative.
- .2 Porcelain enamel signs, minimum size 175 x 250 mm.

2.3 WIRING TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

2.4 EQUIPMENT IDENTIFICATION

- .1 Identify electrical equipment with nameplates and labels as follows:
 - .1 Nameplates: plastic laminate lamicaid 3 mm thick plastic engraving sheet melamine, black face, white core, lettering accurately aligned and engraved into core mechanically attached with self tapping screws.

.2 Sizes as follows:

NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .2 Labels: embossed plastic labels with 6 mm high letters unless specified otherwise.
- .3 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .4 Allow for minimum of twenty-five (25) letters per nameplate and label.
- .5 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .6 Identify equipment with Size 3 labels engraved "ASSET INVENTORY NO. [____]" as directed by Departmental Representative.
- .7 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .8 Terminal cabinets and pull boxes: indicate system and voltage.
- .9 Transformers: indicate capacity, primary and secondary voltages.

**2.5 WIRING
IDENTIFICATION**

- .1 Identify wiring with permanent indelible identifying markings, numbered plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.
- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour coding: to CSA C22.1.
- .4 Use colour coded wires in communication cables, matched throughout system.

**2.6 CONDUIT AND
CABLE
IDENTIFICATION**

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

Prime	Auxiliary	
Up to 250 V	Yellow	
Up to 600 V	Yellow	Green
Up to 5 kV	Yellow	Blue
Up to 15 kV	Yellow	Red
Telephone	Green	
Other	Green	Blue
Communication Systems		
Fire Alarm	Red	
Emergency	Red	Blue
Voice		
Other	Red	Yellow
Security Systems		

2.7 FINISHES

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
- .1 Paint outdoor electrical equipment "equipment green" finish.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.

**3.2 NAMEPLATES AND
LABELS**

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

**3.3 CONDUIT AND
CABLE INSTALLATION**

- .1 Install conduit and sleeves prior to pouring of concrete.
- .1 Sleeves through concrete: schedule 40 steel pipe, sized for free passage of conduit, and protruding 50 mm.

	.2	If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.
	.3	Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.
<u>3.4 LOCATION OF OUTLETS</u>	.1	Locate outlets in accordance with Section 26 05 32 - Outlet Boxes, Conduit Boxes and Fitting.
	.2	Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
	.3	Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation.
	.4	Locate light switches on latch side of doors. .1 Locate disconnect devices in mechanical and elevator machine rooms on latch side of floor.
<u>3.5 MOUNTING HEIGHTS</u>	.1	Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
	.2	If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
	.3	Install electrical equipment at following heights unless indicated otherwise. .1 Local switches: 1370 mm. .2 Wall receptacles: .1 General: 300 mm. .2 Above top of counters or counter splash backs: 175 mm. .3 Door bell pushbuttons: 1500 mm.
<u>3.6 CO-ORDINATION OF PROTECTIVE DEVICES</u>	.1	Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

**3.7 FIELD QUALITY
CONTROL**

- .1 Load Balance:
 - .1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
 - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
 - .3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct following tests in accordance with Section 01 45 00 - Quality Control.
 - .1 Circuits originating from branch distribution panels.
 - .2 Lighting and its control.
 - .4 Insulation resistance testing:
 - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
 - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
 - .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

3.8 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA-C22.2 No.18-F98(C2003), Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware.
 - .2 CSA C22.2 No.65-F93(C2008), Wire Connectors.
- .2 National Electrical Manufacturers Association (NEMA)

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Pressure type wire connectors to: CSA C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors to: CSA C22.2 No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
- .3 Bushing stud connectors: to NEMA to consist of:
 - .1 Connector body and stud clamp for stranded copper conductors.
 - .2 Clamp for copper conductors bar.
 - .3 Clamp for stranded aluminum conductors.
 - .4 Stud clamp bolts.
 - .5 Bolts for copper conductors.
 - .6 Sized for conductors as indicated.
- .4 Clamps or connectors for armoured cable and flexible conduit, as required to: CAN/CSA-C22.2 No.18.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Remove insulation carefully from ends of conductors and:
 - .1 Apply coat of zinc joint compound on aluminum conductors prior to installation of connectors.
 - .2 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2 No.65.
 - .3 Install fixture type connectors and tighten. Replace insulating cap.
 - .4 Install bushing stud connectors in accordance with NEMA.

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

Section 26 05 20 – Wire and box connectors 0-1000 V.

1.2 PRODUCT DATA

- .1 Provide product data in accordance with Section 01 33 00 - Submittal Procedures.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates, padding and packaging materials.

PART 2 - PRODUCTS

2.1 BUILDING WIRES

- .1 Conductors: stranded for 8 AWG and larger. Minimum size: 12 AWG.
- .2 Copper conductors: size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE for general installation.

PART 3 - EXECUTION

3.1 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform conductors tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.

3.2 GENERAL CABLE INSTALLATION

- .1 Terminate cables in accordance with Section [26 05 20 - Wire and Box Connectors - (0-1000 V).

- .2 Cable Colour Coding: to Section 26 05 00 Common Work Results for Electrical.
- .3 Branch circuit wiring for surge suppression receptacles and permanently wired computer and electronic equipment to be 2-wire circuits only, i.e. common neutrals not permitted.

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association, (CSA International)

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .2 Collect and separate for disposal in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility as approved by the Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 - PRODUCTS

2.1 EQUIPMENT

- .1 Insulated grounding conductors: green, type RW90.
- .2 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
 - .1 Grounding and bonding bushings.
 - .2 Protective type clamps.
 - .3 Bolted type conductor connectors.
 - .4 Bonding jumpers, straps.
 - .6 Pressure wire connectors.

PART 3 - EXECUTION

3.1 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including, conductors, connectors, accessories. Where EMT is used, run ground wire in conduit.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Protect exposed grounding conductors from mechanical injury.

- .4 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .6 Soldered joints not permitted.
- .7 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- .4 Disconnect ground fault indicator during tests.

PART 1 - GENERAL

1.1 WASTE MANAGEMENT AND DISPOSAL

- .1 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .2 Collect and separate for disposal in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .2 Divert unused metal materials from landfill to metal recycling facility as approved by the Departmental Representative.
- .2 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 - PRODUCTS

2.1 SUPPORT CHANNELS

- .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Support equipment, conduit using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
- .2 Fasten exposed conduit or cables to building construction or support system using straps.
 - .1 One-hole steel straps to secure surface conduits and cables 50 mm and smaller.
 - .2 Two-hole steel straps for conduits and cables larger than 50 mm.
 - .3 Beam clamps to secure conduit to exposed steel work.
- .3 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit.
- .4 Ensure adequate support for raceways or equipment where there is no wall support.

- .5 Do not use wire lashing or perforated strap to support or secure raceways.
- .6 Do not use supports or equipment installed for other trades for conduit support except with permission of other trade and approval of Departmental Representative.
- .7 Install fastenings and supports as required for each type of equipment and conduits, and in accordance with manufacturer's installation recommendations.

PART 1 - GENERAL

- | | |
|---|--|
| <u>1.1 REFERENCES</u> | .1 Canadian Standards Association (CSA International)
.1 CSA C22.1-10-F10, Canadian Electrical Code, Part 1, 21th Edition. |
| <u>1.2 SUBMITTALS</u> | .1 Product Data:
.1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations. |
| <u>1.3 DELIVERY, STORAGE AND HANDLING</u> | .1 Waste Management and Disposal:
.1 Separate waste materials for reuse and recycling. |

PART 2 - PRODUCTS

- | | |
|------------------------------------|--|
| <u>2.1 SPLITTERS</u> | .1 Construction: sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.

.2 Terminations: main and branch lugs to match required size and number of incoming and outgoing conductors as indicated. |
| <u>2.2 JUNCTION AND PULL BOXES</u> | .1 Construction:welded steel enclosure.

.2 Covers Flush Mounted: 25 mm minimum extension all around.

.3 Covers Surface Mounted: screw-on flat covers. |
| <u>2.3 CABINETS</u> | .1 Construction: welded, sheet steel, hinged door, handle, latch and catch

.2 Type E Empty: surface return flange] [flush overlapping sides] mounting. |

PART 3 - EXECUTION

3.1 SPLITTER INSTALLATION

- .1 Mount plumb, true and square to building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.
- .3 Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1.

3.3 IDENTIFICATION

- .1 Equipment Identification: to Section 26 05 00- Common Work Results for Electrical.
- .2 Identification Labels: size 2 indicating system name or as indicated.

PART 1 - GENERAL

- | | |
|---|--|
| <u>1.1 REFERENCES</u> | .1 Canadian Standards Association (CSA International)
.1 CSA C22.1-F10, Canadian Electrical Code, Part 1, 21th Edition. |
| <u>1.2 SUBMITTALS</u> | .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures. |
| <u>1.3 DELIVERY, STORAGE AND HANDLING</u> | .1 Waste Management and Disposal:
.1 Separate waste materials for recycling. |

PART 2 - PRODUCTS

- | | |
|---|---|
| <u>2.1 OUTLET AND CONDUIT BOXES GENERAL</u> | .1 Size boxes in accordance with CSA C22.1.
.2 102 mm square or larger outlet boxes as required.
.3 Gang boxes where wiring devices are grouped.
.4 Blank cover plates for boxes without wiring devices.
.5 347 V outlet boxes for 347 V switching devices.
.6 Combination boxes with barriers where outlets for more than one system are grouped. |
| <u>2.2 GALVANIZED STEEL OUTLET BOXES</u> | .1 One-piece electro-galvanized construction.
.2 Single gang flush device boxes for flush installation, minimum size 76 x 50 x 38 mm or as indicated. 102 mm square outlet boxes when more than one conduit enters one side with extension and plaster rings as required. |

- .3 Utility boxes for outlets connected to surface-mounted EMT conduit, minimum size 102 x 54 x 48 mm.
- .4 102 mm square or octagonal outlet boxes for lighting fixture outlets.

2.3 CONCRETE BOXES

- .1 Electro-galvanized sheet steel concrete type boxes for flush mount in concrete with matching extension and plaster rings as required.

2.4 CONDUIT BOXES

- .1 Cast FS aluminum boxes with factory-threaded hubs and mounting feet for surface wiring of devices.

2.5 FITTINGS - GENERAL

- .1 Bushing and connectors with nylon insulated throats.
- .2 Knock-out fillers to prevent entry of debris.
- .3 Conduit outlet bodies for conduit up to 35 mm and pull boxes for larger conduits.
- .4 Double locknuts and insulated bushings on sheet metal boxes.

2.6 SERVICE FITTINGS

- .1 'High tension' receptacle fitting made of 2 piece die-cast aluminum for 1 single, two duplex receptacles. Bottom plate with two knockouts for centered or offset installation.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Support boxes independently of connecting conduits.
- .2 For flush installations mount outlets flush with finished wall using plaster rings to permit wall finish to come within 6 mm of opening.
- .3 Provide correct size of openings in boxes for conduit, mineral insulated and armoured cable connections. Do not install reducing washers.

- .4 Vacuum clean interior of outlet boxes before installation of wiring devices.
- .5 Identify systems for outlet boxes as required.

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA C22.2 No. 18-98(R2003)], Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware, A National Standard of Canada.
 - .2 CSA C22.2 No. 45-M1981(R2003)], Rigid Metal Conduit.
 - .3 CSA C22.2 No. 56-04, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
 - .4 CSA C22.2 No. 83-M1985(R2003), Electrical Metallic Tubing.

1.2 WASTE MANAGEMENT AND DISPOSAL

- .1 Place materials defined as hazardous or toxic waste in designated containers.
- .2 Ensure emptied containers are sealed and stored safely for disposal away from children.

PART 2 - PRODUCTS

2.1 CONDUITS

- .1 Rigid metal conduit: to CSA C22.2 No. 45, galvanized steel threaded.
- .2 Electrical metallic tubing (EMT): to CSA C22.2 No. 83,[with couplings with expanded ends, liquid-tight.
- .3 Flexible metal conduit: to CSA C22.2 No. 56, steel, liquid-tight flexible metal.

2. CONDUIT FASTENINGS

- .1 One hole steel straps to secure surface conduits 50 mm and smaller.
 - .1 Two hole steel straps for conduits larger than 50 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits at Clearance distance according to the Code.

- .4 Threaded rods, 6 mm diameter, to support suspended channels.
- .5 Two-hole fastening flanges for rigid threaded conduits.

2.3 CONDUIT FITTINGS

- .1 Fittings: to CAN/CSA C22.2 No. 18, manufactured for use with conduit specified. Coating: same as conduit.
- .2 Ensure factory "ells" where 90 degrees bends for 25 mm and larger conduits.
- .3 Watertight connectors and couplings for EMT.
 - .1 Set-screws are not acceptable.

2.4 EXPANSION FITTINGS FOR RIGID CONDUIT

- .1 Weatherproof expansion fittings with internal bonding assembly suitable for 100 mm linear expansion.
- .2 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection.
- .3 Weatherproof expansion fittings for linear expansion at entry to panel.

2.6 FISH CORD

- .1 Polypropylene.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms and in unfinished areas.

- .3 Use rigid galvanized steel where specified otherwise.
- .4 Use electrical metallic tubing (EMT) except in cast concrete above 2.4 m not subject to mechanical injury.
- .5 Use flexible metal conduit for connection to recessed fixtures without prewired outlet box work in movable metal partitions.
- .6 Use liquid tight flexible metal conduit for vibrating equipment in damp or wet locations.
- .7 Install conduit sealing fittings.
- .8 Minimum conduit size for lighting and power circuits: 21 mm diameter.
- .9 Bend conduit cold: Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .10 Mechanically bend steel conduit over 219 mm diameter.
- .11 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .12 Install fish cord in empty conduits.
- .13 Remove and replace blocked conduit sections. Do not use liquids to clean out conduits.
- .14 Dry conduits out before installing wire.

3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on surface channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

3.4 CONCEALED
CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

3.5 CONDUITS IN
CAST-IN-PLACE
CONCRETE

- .1 Locate to suit reinforcing steel.
 - .1 Install in centre one third of slab.
- .2 Protect conduits from damage where they stub out of concrete.
- .3 Install sleeves where conduits pass through slab or wall.
- .4 Provide oversized sleeve for conduits passing through waterproof membrane, before membrane is installed.
 - .1 Use cold mastic between sleeve and conduit.
- .5 Conduits in slabs: minimum slab thickness 4 times conduit diameter.
- .6 Encase conduits completely in concrete with minimum 50 mm concrete cover.
- .7 Organize conduits in slab to minimize cross-overs.

3.6 CLEANING

- .1 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Switches, receptacles, wiring devices, cover plates and their installation.
<u>1.2 RELATED SECTIONS</u>	.1	Section 26 05 00 - Common Work Results - Electrical.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CSA-C22.2 No.42-99(R2009), General Use Receptacles, Attachment Plugs and Similar Devices. .2 CSA-C22.2 No.42.1-00(C2009), Cover Plates for Flush-Mounted Wiring Devices (Bi-national standard, with UL 514D).
<u>1.4 SHOP DRAWINGS AND PRODUCT DATA</u>	.1	Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
<u>1.5 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate and recycle waste materials.
	.2	Remove from site and dispose of all packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
	.4	Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

PART 2 - PRODUCTS

<u>2.1 SWITCHES</u>	.1	20 A, 120 V, single pole switches to: CSA-C22.2 No.55 and CSA-C22.2 No.111.
---------------------	----	---

- .2 Manually-operated general purpose ac switches with following features:
 - .1 Terminal holes approved for No. 10 AWG wire.
 - .2 Silver alloy contacts.
 - .3 Urea or melamine moulding for parts subject to carbon tracking.
 - .4 Suitable for back and side wiring.
 - .5 Ivory toggle.
- .3 Toggle operated fully rated for tungsten filament.
- .4 Switches of one manufacturer throughout project.
- .5 Acceptable materials: Hubbel.

2.2 COVER PLATES

- .1 Cover plates for wiring devices to: CSA-C22.2 No.42.1.
- .2 Cover plates from one manufacturer throughout project.
- .3 Sheet steel utility box cover for wiring devices installed in surface-mounted utility boxes.
- .4 Stainless steel, vertically brushed, 1 mm thick cover plates.
- .5 Sheet metal cover plates for wiring devices mounted in surface-mounted FS or FD type conduit boxes.
- .6 Weatherproof double lift spring-loaded cast aluminum cover plates, complete with gaskets for duplex receptacles as indicated.
- .7 Weatherproof spring-loaded [cast aluminum] cover plates complete with gaskets for single receptacles or switches.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Switches:
 - .1 Install single throw switches with handle in "UP" position when switch closed.
 - .2 Install switches in gang type outlet box when more than one switch is required in one location.
 - .3 Mount toggle switches at height Prescribed by the general requirements or shown on the plans.

- .2 Cover plates:
 - .1 Protect stainless steel cover plate finish with paper or plastic film until painting and other work is finished.
 - .2 Install suitable common cover plates where wiring devices are grouped.
 - .3 Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.

PART 1 - GENERAL

1.1 REFERENCES

- .1 American National Standards Institute (ANSI).
- .2 American National Standards Institute/Institute of Electrical and Electronics Engineers (ANSI/IEEE).
- .3 ASTM International Inc.
- .4 Canadian Standards Association (CSA International)
- .5 Underwriters' Laboratories of Canada (ULC)

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Provide complete photometric data prepared by independent testing laboratory for luminaires where specified, for review by Departmental Representative and Engineer.
 - .3 Photometric data to include: VCP Table where applicable and spacing criterion.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .4 Divert unused metal materials from landfill to metal recycling facility.
- .5 Disposal and recycling of fluorescent lamps as per local regulations.
- .6 Disposal of old PCB filled ballasts.

PART 2 - PRODUCTS

2.1 LED LIGHT FIXTURE

1. The light fixtures shall be designed to operate with a light source based on the use of light-emitting diodes (LED). Unless otherwise indicated, modification kits or the use of a LED lamp as a replacement for an incandescent, fluorescent or HIS lamp are not accepted.
2. LEDs must be designed and manufactured by a recognized company such as Cree, Lumileds, Nichia, Samsung or equivalent.
3. "Drivers" must be designed and manufactured by a recognized company such as Cree, Eldo LED, Lutron, Philips or equivalent. Drivers designed and manufactured by the device manufacturer are also acceptable.
4. LEDs must be assembled on mounting plates allowing replacement without specialized tools.
5. The "drivers" must be ready for use with the 0-10 volt dimming.
6. Heat dissipation must be ensured by natural convection without the use of mechanical systems with moving parts.
7. The lifespan of the LEDs must be at least 100,000 hours at L70 for outdoor units, established according to the LM-80 and TM-21 standards of the Illumination Engineering Society.
8. The color rendering index must be at least 80.
9. The color temperature for outdoor fixtures will be 4000 or 5000 K, as indicated in the appliance description.
10. The photometric data of the equipment shall be measured in accordance with LN-79 of the Illuminating Engineering Society and established by an independent or accredited NVLAP laboratory.
11. Power supply at 120, 208, 240 or 347 volts, as indicated. The fixtures can accept a voltage variation of $\pm 10\%$.
12. LEDs and drivers must be guaranteed for a minimum period of five (5) years.

<u>2.2 FINISHES</u>	.1	Light fixture finish and construction to meet ULC listing[s] and CSA certification[s] related to intended installation.
<u>2.3 OPTICAL CONTROL DEVICES</u>	.1	As indicated in luminaire schedule.
<u>2.4 LUMINAIRES</u>	.1	As indicated in luminaire schedule.
<u>PART 3 - EXECUTION</u>		
<u>3.1 INSTALLATION</u>	.1	Locate and install luminaires as indicated.
<u>3.2 WIRING</u>	.1	Connect luminaires to lighting circuits: .1 Install flexible or rigid conduit for luminaires as indicated.

