



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 1T3
Nova Scotia
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

THIS DOCUMENT CONTAINS A SECURITY
REQUIREMENT

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 3C9
Nova Scot

Title - Sujet Conference Roomtable	
Solicitation No. - N° de l'invitation W010V-17A061/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client W010V-17-A061	Date 2017-04-11
GETS Reference No. - N° de référence de SEAG PW-\$HAL-219-10069	
File No. - N° de dossier HAL-6-77209 (219)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-04-19	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Richard, Linda K.	Buyer Id - Id de l'acheteur hal219
Telephone No. - N° de téléphone (902) 496-5261 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT 4

This amendment is issued to answer the following questions:

Question 1:

What are the dimensions of the CSNI and DWAN computers?

Answer 1:

Approximate PC size for DWAN is 12x12x4. Size for the CSNI computers is pending.

Question 2:

Where should we position the control switch to lower and raise where the monitor is located? On the surface or below the surface?

Answer 2:

Below the surface

Question 3:

Table top must have drilled holes at each station to allow for telephone hookup at each station. What size of grommet would be acceptable to serve this purpose?

Answer 3:

½" grommet will suffice.

Question 4:

A total of 50 power outlets in total for the entire table with 5 power outlets available at each individual work station and 5 additional outlets that are located under the table top and easily accessible from the top side of the centre of the table.

How many electrical circuits will these outlets be fed from? Will some of those 50 outlets be used to power the monitor lift as well?

Answer 4:

Approx. 5 circuits. Some of the outlets will power the monitor lift.

Question 5:

j. Two electric cooling fans must be installed under the table for ventilation. One intake fan near the head of the table, and one exhaust fan near the opposite end and must be automated with temperature sensors.

Is there a minimum and a maximum CFM requirements for the fan?

Answer 5:

Fan should be able to move air at 1302 m³/h (or 766.33 CFM)

All other terms and conditions remain unchanged.