

- Q.30 MANUAL MOBILE STORAGE SHELVING Section 10 56 26.13 (3.2) Preparation: In the specification for this project it mention existing shelving. Is this shelving being dismantled and reinstalled at a temporary location? Or, is the plan to dismantle the shelving, moved to storage, and to be used in the new mobile system?
Is there any pictures or specification on the existing shelving, if it is to be used in the new mobile?
- A.30 Bidders shall delete reference to Sentence 10 56 26.13 (3.2) as there is no existing mobile shelving units to dismantle, move or reinstall. All Manual Mobile Storage Shelving for the Work shall be supplied new and installed in accordance with the Specification Section 10 56 26.13 and Contract Documents including A9.03 ENLARGED INTERIOR PLAN AND ELEVATION.