



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Réfection de la couverture et du système de chauffage, de ventilation et de conditionnement d'air (CVCA) du Centre des opérations, Parc national Banff		
Solicitation No.: / N° de l'invitation : 5P420-17-5026/A	Amendment No.: / N° de modification de l'invitation : 001	Date: April 24, 2017 Date : 24 avril 2017
GETS Reference No.: / N° de référence de SEAG : PW-17-00774622		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: May 2, 2017	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 2 mai 2017	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



MODIFICATION 001

Cette modification est apportée pour repousser la date de clôture, afficher la feuille de présence de la visite des lieux et modifier les spécifications et les dessins sous l'appel d'offres 5P420-17-5026/A :

A. DATE DE CLÔTURE DE L'APPEL D'OFFRES

La date de clôture de l'appel d'offres n° 5P420-17-5026/A, dont le sujet était Réfection de la couverture et du système de chauffage, de ventilation et de conditionnement d'air (CVCA) du Centre des opérations, Parc national Banff, est repoussée du 26 avril 2017 au 2 mai 2017 à 14 h, heure avancée des Rocheuses (HAR).

B. PRÉSENCE DE LA VISITE DES LIEUX

Voir le dossier DSP 2 – 17-5026 pour la feuille de présence.

C. MODIFICATIONS AUX SPÉCIFICATION

Cette modification fait partie des documents contractuels et modifie les dessins et les spécifications originales datés du 8 mars 2017 et doit être lu, interprété et coordonné avec toutes les autres parties. Le coût de tout ce qui est contenu ici doit être inclus dans la somme du contrat. Les révisions suivantes remplacent les informations contenues dans les dessins originaux et les spécifications émis pour le projet mentionné ci-dessus dans la mesure indiquée et en font partie.

A1 Architectural

1. Specifications

1.1 Section 01 11 00 - Summary of Work

Revise item 1.4.2 to read as follows:

“Complete Work by December 31, 2017”

1.2 Section 07 52 00 - Modified Bituminous Membrane Roofing

Revise item 1.4.2 to read as follows:

“Installer Qualifications: company or person specializing in application of modified bituminous roofing systems approved by membrane manufacturer”.

1.3 Section 07 84 00 – Fire stopping and Smoke seals

Revise item 1.6.1.1 to read as follows:

“Installer: company or person specializing in fire stopping installations and approved by manufacturer”

1.4 Section 07 92 00 – Sealants

Delete Item 1.3.1 and renumber remaining items.

1.5 Section 09 30 13 – Tiling

Revise Item 1.5.4 to read as follows:

“Installer Qualifications: Installer must be registered as a member in good standing with the Terrazzo, Tile and Marble Association of Canada.”

1.6 Section 09 91 00 – Painting

Delete Item 1.7.2.1 and renumber remaining items.



A2 Mechanical

1. General

- 1.1. Duct cleaning is required for all supply and return ventilation systems; refer to specifications section 23 01 31 Air Duct Cleaning for HVAC Systems.

2. Specifications

- 2.1. Section 23 01 31 - Air Duct Cleaning For HVAC Systems

Revise item 1.7.1 to read as follows:

“Contractor: verification of membership in NADCA.”

- 2.2. Section 23 01 31- Air Duct Cleaning For HVAC Systems

Revise item 1.7.2 to read as follows:

“Project Co-ordinator: Air System Cleaning Specialist (ASCS) certified by NADCA on full time basis.”

- 2.3. Section 23 07 13 – Duct Insulation

Revise item 1.4.1.1 to read as follows:

“Installer: specialist in performing work of this section.”

- 2.4. Section 23 07 14 – Thermal Insulation for Equipment

Revise item 1.3.4.1 to read as follows:

“Installer: specialist in performing work of this section.”

- 2.5. Section 23 07 15 - Thermal Insulation for Piping

Revise item 1.6.2 to read as follows: “Installer: specialist in performing work of this Section.”

- 2.6. Section 23 74 00 – Packaged Outdoor HVAC Equipment

Revise item 1.6.2 to read as follows: “Contractor hereby warrants that packaged rooftop HVAC units and refrigeration compressors will function and operate for no less than 60 months.”

Tous les autres termes et conditions resteront inchangés