




POLE & FIXTURE INSTALLATION DETAIL #1
SCALE: 1:25
NOTE:
1. TYPICAL FOR NEW POLES P4 AND P5.
2. ALL DIMENSIONS ARE IN MILLIMETERS.



POLE & FIXTURE INSTALLATION DETAIL #2
SCALE: 1:25
NOTE:
1. TYPICAL FOR NEW POLES P6 AND P7.
2. ALL DIMENSIONS ARE IN MILLIMETERS.
3. FOR CLARITY PURPOSES ONLY 1 LED FLOOD LIGHT IS SHOWN.




FIXTURE INSTALLATION DETAIL #3
SCALE: 1:20
NOTE:
1. TYPICAL FOR EXISTING POLES P1, P2 AND P3.




LUMINAIRE MOUNTING DETAIL #6
SCALE: N.T.S.




ELEVATION - POLE MOUNTED JUNCTION BOX #5
SCALE: 1:20
NOTE: TYPICAL FOR POLES P4 & P5.



LUMINAIRE MOUNTING DETAIL #7
SCALE: N.T.S.
NOTE: FOR CLARITY PURPOSES ONLY 1 LED FLOOD LIGHT IS SHOWN.



DETAIL - POLE P5
SCALE: 1:20
NOTE: TYPICAL FOR POLES P4 & P5.



WHARF & FLOATING DOCK LIGHTING WIRING DIAGRAM & CONTROL SCHEMATIC
SCALE: N.T.S.
NOTES:
1. CONTACTS RATED FOR 15 AMP, 120V
2. 20 AMP COIL

- MOUNTING NOTES:**
- ALL TECK CABLE OR METALLIC CONDUIT TERMINATED ON FIBREGLASS OR PVC BOXES SHALL UTILIZE BONDING LOCKNUTS. ALL BONDING LOCKNUTS SHALL BE CONNECTED TO GROUND USING A #14 AWG GREEN INSULATED CONDUCTOR.
 - CONTRACTOR TO SUPPLY AND INSTALL PVC COATED CABLE GLAND FOR ALL CABTIRE CONNECTIONS.
 - CONTRACTOR TO SUPPLY AND INSTALL PVC COATED TECK CONNECTORS FOR ALL TECK CABLE CONNECTIONS.
 - CONTRACTOR TO SUPPLY AND INSTALL BIRD DETERRENTS (SPIKES) ON ALL POLES AND LIGHT FIXTURES.

0	ISSUED FOR TENDER	APR. 2017
revisions		date

**WHARF EXTENSION
EASTERN PASSAGE
HALIFAX COUNTY
NOVA SCOTIA**

drawing: design
LIGHTING DETAILS

designed	G. BOWSER	conçu
date	MARCH 2017	
drawn	K. WOLFE	dessiné
date	MARCH 2017	
approved		approuvé
date		
Tender		Submission
PWSC Project Manager	Administrateur de projets TPSOC	
project number		no. du projet
	R.082417.001	
drawing no.		no. du dessin
	E4	