















- GENERAL NOTES

1. ALL WORK SHALL BE DONE IN ACCORDANCE WITH THE LATEST EDITION OF THE CANADIAN ELECTRICAL CODE AND/OR LOCAL INSPECTION AUTHORITIES. THE ELECTRICAL CONTRACTOR SHALL OBTAIN ALL PERMITS AND INSPECTIONS REQUIRED BY LAWS, ORDINANCES, RULES AND REGULATIONS OF PUBLIC AUTHORITIES HAVING JURISDICTION OF THIS DISTRICT AND SHALL OBTAIN CERTIFICATES ON SUCH INSPECTIONS AND SUBMIT SAME AND PAY ALL CHARGES IN CONNECTION THEREWITH.
2. ELECTRICAL CONTRACTOR TO COORDINATE ALL WORK WITH THE EASTERN PASSAGE HARBOUR AUTHORITY PRIOR TO STARTING WORK.
3. CONTRACTOR SHALL VISIT SITE PRIOR TO TENDER TO ASSESS EXISTING CONDITIONS, OBSTRUCTIONS, MATERIALS, ETC.
4. ON COMPLETION, ALL EQUIPMENT SHALL BE THOROUGHLY CLEANED. ALL WORK CHECKED OVER AND LEFT IN WORKING ORDER.
5. ALL RUBBISH, UNUSED MATERIALS ETC., SHALL BE REMOVED AND THE PREMISES LEFT CLEAN.
6. MAKE GOOD ALL AREAS AFFECTED BY CONSTRUCTION.
7. CONTRACTOR SHALL SUPPLY AND INSTALL ALL LIGHT FIXTURES, JUNCTION BOXES, WIRING DEVICES, ETC. FOR A COMPLETE AND FINISHED JOB AS DETAILED.
8. EQUIPMENT AND MATERIAL TO BE CSA CERTIFIED.

**LEGEND:**

-  TYPE 'A' 120V, 138 WATT LED AREA LIGHTING FIXTURE, MOUNTED ON A NEW TREATED TIMBER POLE. SEE SPECIFICATION FOR AREA LIGHT AND POLE DESCRIPTION.  
 TYPE 'A' 120V, 138 WATT LED AREA LIGHTING FIXTURE, ON AN EXISTING ALUMINUM POLE. SEE SPECIFICATION FOR AREA LIGHT DESCRIPTION.  
 TYPE 'B' 120V, 138 WATT LED FLOODLIGHTING FIXTURE, MOUNTED ON A NEW TREATED TIMBER POLE. SEE SPECIFICATION FOR FLOODLIGHT AND POLE DESCRIPTION.  
 EXISTING 120/240 VOLT DISTRIBUTION PANEL.  
 NEW 125 VOLT, 20 AMP, SINGLE TWIST LOCK RECEPTACLE, CSA CONFIGURATION L5-20R C/Y HINGED AND GASKETED COVERPLATE, PROTECTED BY A BLANK FACE GFCI MODULE, MOUNTED ON A 200 x 200 TREATED TIMBER POST.  
 EXISTING 20A, 125V DUPLEX RECEPTACLE, T-SLOT (NEMA 5-20) PROTECTED BY A BLANK FACE GFCI MODULE.  
 EXISTING 20A, 125V TWIST-LOCK RECEPTACLE, (NEMA L5-20R) PROTECTED BY A BLANK FACE GFCI MODULE.  
 EXISTING 30A, 125V TWIST-LOCK RECEPTACLE, (NEMA L5-30R).  
 EXISTING 20A, 125V DUPLEX RECEPTACLE, T-SLOT (NEMA 5-20) WITH GFCI PROTECTION MOUNTED ON DERRICK  
 BOLLARD – GROUT FILLED METAL PIPES FOR PANEL A PROTECTION. SEE DRAWING E3 FOR LAYOUT AND DETAILS.  
 FEEDER IDENTIFICATION – REFER TO FEEDER SCHEDULE ON DRAWING E3  
 EXISTING NSPI METER




### EXISTING SERVICE BACKBOARD DEMOLITION

SCALE : 1:20


DEMOLITION NOTES:

1. DISCONNECT MAIN SERVICE POWER TO PANEL.
2. SERVICE FEEDERS TO BE DISCONNECTED AND RECONNECTED BY NSPL. O/H LIGHTING CIRCUIT TO BE COMPLETELY REMOVED.
3. REMOVE MASTHEAD, CONDUIT, DISCONNECT SWITCH AND ASSOCIATED WIRING/CABLE FOR LIGHTING.
4. DISCONNECT BRANCH CIRCUIT WIRING/CABLES FROM PANEL.
5. DISCONNECT AND REMOVE METER AND BASE, PANEL AND ENCLOSURE AND RECEPTACLES (2) FROM EXISTING BACKBOARD TO FACILITATE REMOVAL OF BACKBOARD. REINSTALL UPON COMPLETION OF NEW MAIN SERVICE BACKBOARD. REFER TO DETAIL 1, DRAWING E2 FOR NEW LAYOUT.





SECTION - RGS CONDUIT ON WHEELGUARD

SCALE : 1:10



## SECTION - DIRECT BURIED CONDUIT

SCALE : 1:10




### SECTION - DIRECT BURIED CONDUIT

SCALE : 1:10

NOTE: ALL DIMENSIONS ARE IN MILLIMETERS


NOTE: ALL DIMENSIONS ARE IN MILLIMETERS.



SECTION - PVC CONDUIT IN DECK



SCALE : 1:10

100 200 300 400 500 600 700 800 900 1000




## SECTION - RGS CONDUIT ON WHEELGUARD

SCALE : 1:10



## SECTION - RGS CONDUIT ON WHEEL GUARD

SCALE : 1:10



0mm 100 200 300 400 500 600 700 800 900 1000mm