

**PART 1**      **GENERAL**

**1.1**      **SUMMARY**

- .1      Section Includes:
  - .1      Operating dampers for mechanical forced air ventilation and air conditioning systems.

**1.2**      **REFERENCES**

- .1      American Society for Testing and Materials International (ASTM)
  - .1      ASTM A 653/A653M-04a, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by Hot-Dip Process.
- .2      Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1      Material Safety Data Sheets (MSDS).

**1.3**      **SUBMITTALS**

- .1      Product Data:
  - .1      Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
    - .1      Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
  - .2      Indicate the following:
    - .1      Performance data.
    - .2      Specifications
- .2      Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
  - .1      Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
  - .2      Instructions: submit manufacturer's installation instructions.
- .3      Closeout Submittals:
  - .1      Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals

**1.4**            **QUALITY ASSURANCE**

- .1      Health and Safety Requirements: Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.
- .2      Certificates:
  - .1      Catalogue or published ratings those obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency.

**1.5**            **DELIVERY, STORAGE, AND HANDLING**

- .1      Packing, shipping, handling and unloading:
  - .1      Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.
  - .2      Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2      Waste Management and Disposal:
  - .1      Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

**PART 2**        **PRODUCTS**

**2.1**            **MULTI-LEAF DAMPERS**

- .1      Opposed or parallel blade type as indicated.
- .2      Structurally formed steel or extruded aluminum, interlocking blades, complete with extruded vinyl seals, spring stainless steel side seals, structurally formed and welded galvanized steel or extruded aluminum frame.
- .3      Pressure fit self-lubricated bronze bearings.
- .4      Linkage: plated steel tie rods, brass pivots and plated steel brackets, complete with plated steel control rod.
- .5      Operator: to Section 25 30 02 – EMCS: Field Control Devices.
- .6      Performance:
  - .1      Leakage: in closed position to be less than 2% of rated air flow at 500 Pa differential across damper.
  - .2      Pressure drop: at full open position to be less than 25 Pa differential across damper at 10 m/s.
- .7      Insulated aluminum dampers:

- .1 Frames: insulated with extruded polystyrene foam with RSI factor of 5.0.
- .2 Blades: constructed from aluminum extrusions with internal hollows insulated with polyurethane or polystyrene foam, RSI factor of 5.0.

## 2.2 DISC TYPE DAMPERS

- .1 Frame: insulated brake formed, welded, 1.6 mm thick, galvanized steel to ASTM A 653M.
- .2 Disc: insulated spin formed, 1.6 mm thick, galvanized steel to ASTM A 653M.
- .3 Gasket: extruded neoprene, field replaceable, with 10-year warranty.
- .4 Bearings: roller self lubricated and sealed.
- .5 Operator: compatible with damper, spring loaded actuator.
- .6 Performance:
  - .1 Leakage: in closed position to be less than 2% of rated air flow at 500 Pa pressure differential across damper.
  - .2 Pressure drop: at full open position to be less than 25 Pa differential across damper at 10 m/s.

## 2.3 BACK DRAFT DAMPERS

- .1 Automatic gravity operated, multi leaf, aluminum or steel construction with nylon bearings, centre pivoted, spring assisted or counterweighted.

## 2.4 RELIEF DAMPERS

- .1 Automatic multi-leaf steel or aluminum dampers with ball bearing centre pivoted and counter-weights set to open as indicated.

## PART 3 EXECUTION

### 3.1 INSTALLATION

- .1 Install where indicated.
- .2 Install in accordance with recommendations of SMACNA and manufacturer's instructions.
- .3 Seal multiple damper modules with silicon sealant.
- .4 Install access door adjacent to each damper. See Section 23 33 00 – Air Duct Accessories.
- .5 Ensure dampers are observable and accessible.

**3.2            CLEANING**

- .1        Proceed in accordance with Section 01 74 11 - Cleaning.
- .2        Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**