

PART 1 **GENERAL**

1.1 **SUMMARY**

.1 Section Includes:

.1 Fans, motors, accessories, and hardware for commercial use.

1.2 **RELATED SECTIONS**

.1 Section 01 33 00 – Submittal Procedures

.2 Section 01 35 29.06 – Health and Safety Requirements.

.3 Section 01 74 21 – Construction/Demolition Waste Management and Disposal.

.4 Section 01 78 00 – Closeout Submittals

.5 Section 23 05 13 – Common Motor Requirements for HVAC Equipment.

.6 Section 23 05 48 – Vibration and Seismic Control for HVAC Piping and Equipment.

.7 Section 23 33 00 – Air Duct Accessories.

1.3 **REFERENCES**

.1 Air Conditioning and Mechanical Contractors (AMCA)

.1 AMCA Publication, Standards Handbook.

.2 AMCA 300, Reverberant Room Method for Sound Testing of Fans.

.3 AMCA 301, Methods for Calculating Fan Sound Ratings from Laboratory Test Data.

.2 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME)

.1 ANSI/AMCA 210, Laboratory Methods of Testing Fans for Aerodynamic Performance Rating.

.3 Canadian General Standards Board (CGSB)

.1 CAN/CGSB 1.181, Ready-Mixed Organic Zinc-Rich Coating.

.4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)

.1 Material Safety Data Sheets (MSDS).

.5 National Electrical Manufacturers Association (NEMA)

.1 NEMA MG 1 Motors and Generators

- .2 NEMA ICS 7.1 Safety Standard for Construction and Guide for Selection, Installation and Operation of Adjustable Drive Systems.

1.4 SYSTEM DESCRIPTION

- .1 Performance Requirements:
 - .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards in force.
 - .2 Capacity: flow rate, total static pressure, bhp W, efficiency, revolutions per minute, power, model, size, sound power data as specified.
 - .3 Fans: statically and dynamically balanced, constructed in conformity with AMCA 99.
 - .4 Sound ratings: comply with AMCA 301, tested to AMCA 300. Supply unit with AMCA certified sound rating seal.
 - .5 Performance ratings: based on tests performed in accordance with ANSI/AMCA 210. Supply unit with AMCA certified rating seal, except for propeller fans smaller than 300 mm diameter.

1.5 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Provide:
 - .1 Fan performance curves showing point of operation, BHP kW and efficiency.
 - .2 Sound rating data at point of operation.
 - .3 Dimensional data.
 - .4 Installation procedures.
- .4 Indicate:
 - .1 Motors, sheaves, bearings, shaft details
 - .2 Minimum performance achievable with variable speed controllers and variable inlet vanes as appropriate.

- .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
- .6 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.6 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.7 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .1 Spare parts to include:
 - .1 Matched sets of belts.
 - .2 Furnish list of individual manufacturer's recommended spare parts for equipment, include:
 - .1 Bearings and seals.
 - .2 Belts
 - .3 Addresses of suppliers.
 - .4 List of specialized tools necessary for adjusting, repairing or replacing.

1.8 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2

PRODUCTS

2.1

FANS GENERAL

- .1 Capacity: flow rate, static pressure, bhp, efficiency, revolutions per minute, power, model, size, sound power data as specified.
- .2 Fans: statically and dynamically balanced, constructed in conformity with AMCA 99.
- .3 Sound ratings: comply with AMCA 301, tested to AMCA 300. Unit shall bear AMCA certified sound rating seal.
- .4 Performance ratings: based on tests performed in accordance with ANSI/AMCA 210, and ANSI/ASHRAE 51. Unit shall bear AMCA certified rating seal, except for propeller fans smaller than 300 mm diameter.
- .5 Motors:
 - .1 Open drip proof outside of air stream, TEFC when in air stream, in accordance with NEMA MG1.
 - .2 In accordance with Section 23 05 13 – Common Motor Requirements for HVAC Equipment supplemented as specified herein.
 - .3 For use with variable speed controllers where specified.
 - .4 Sizes as specified.
 - .5 Two speed with two windings and speeds of approximately 1200 or 900 r/min low and 1800 r/min high as indicated.
 - .6 Two speeds when indicated with split winding, constant horsepower or constant or variable torque as specified and speeds as indicated.
- .6 Accessories and hardware: matched sets of V-belt drives, adjustable slide rail motor bases, belt guards, coupling guards, fan inlet and/or outlet safety screens as indicated and as specified in Section 23 05 13 – Common Motor Requirements for HVAC Equipment, inlet or outlet dampers and vanes and as indicated.
- .7 Factory primed before assembly in colour standard to manufacturer.
- .8 Scroll casing drains: as indicated.
- .9 Bearing lubrication systems plus extension lubrication tubes where bearings are not easily accessible.
- .10 Vibration isolation: to Section 23 05 48 - Vibration and Seismic Control for HVAC Piping and Equipment.
- .11 Flexible connections: to Section 23 33 00 – Air Duct Accessories.

2.2 CENTRIFUGAL FANS

- .1 Fan wheels:
 - .1 Welded steel or aluminum construction.
 - .2 Maximum operating speed of centrifugal fans not more than 40 % of first critical speed.
 - .3 Air foil or backward inclined blades, as indicated.
- .2 Bearings: air handling quality, heavy duty, split pillow-block, flange mounted grease lubricated ball or roller self aligning type with oil retaining, dust excluding seals and a certified minimum rated life to ABMA L10 of 100,000 hours. Shaft seals on laboratory fume hood and biological safety cabinet exhaust fans:
 - .1 Single disc or stuffing box seals.
- .3 Housings:
 - .1 Volute with inlet cones: fabricated steel for wheels 300 mm or greater, cast iron, or steel, for smaller wheels, braced, and with welded supports.
 - .2 For horizontally and vertically split housings provide flanges on each section for bolting together, with gaskets of non-oxidizing non-flammable material.
 - .3 Provide bolted latched airtight access doors with handles.
 - .4 Spark resistant construction Type B minimum where indicated.

2.3 AXIAL FLOW FANS

- .1 Casings: welded steel with welded motor support, hinged or bolted access plates, streamlined inlet cone and discharge bell sections.
- .2 Blade material: steel or aluminum. Hub material: steel or aluminum.
- .3 Supports:
 - .1 Floor mounted units: reinforced legs.
 - .2 Ceiling suspended units: support brackets welded to side of casing. Extend grease lubrication facilities to outside of casing.
- .4 Bearings: ball or roller with extension tubes to outside of casing.
- .5 Direct drive:
 - .1 Adjustable or fixed blade wheels as indicated: totally-enclosed, air over motors.
 - .2 Diameter of wheel hub: at least equal to that of motor frame.
 - .3 Adjustable blades for varying range of volume and pressure. Provide permanent pitch angle indication vernier scale on hub. Provide for

automatic adjustment while in motion. Provide adjustment stops to avoid overloading motor.

- .4 Variable speed drives: to NEMA ICS 7.1.

2.4 IN-LINE CENTRIFUGAL CABINET FANS

- .1 Characteristics and construction: as for centrifugal fan wheels, with axial flow construction and direct drive as indicated.
- .2 Provide AMCA arrangements 1 or 9 as indicated with stiffened flanges, smooth rounded inlets, and stationary guide vanes.
- .3 Cabinet hung single or multiple wheels with DWDI centrifugal fans in factory fabricated casing complete with vibration isolators, motor, direct drive and guard outside casing.
- .4 Fabricate casing of zinc coated or phosphate treated steel reinforced and braced for rigidity. Provide removable panels for access to interior. Uncoated, steel parts shall be painted over with corrosion resistant paint to CGSB 1.181. Finish inside and out, over prime coat, with rust resistant enamel to Section 09 91 13 – Exterior Painting. Internally line cabinet with 12-25 mm thick rigid acoustic insulation, pinned and cemented, complete with metal nosings on all exposed edges.
- .5 EF-1: 45 l/s @ 64Pa TSP. 950 RPM, 115V/60Hz/1Ph, 20.3W, 0.8 sonos. C/w reverse acting thermostat.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 FAN INSTALLATION

- .1 Install fans as indicated, complete with resilient mountings specified in Section 23 05 48 - Vibration and Seismic Control for HVAC and Piping Equipment, flexible electrical leads and flexible connections in accordance with Section 23 33 00 – Air Duct Accessories.
- .2 Provide sheaves and belts required for final air balance.
- .3 Bearings and extension tubes to be easily accessible.
- .4 Access doors and access panels to be easily accessible.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

3.4 COMMISSIONING

- .1 Commissioning in accordance with Section 01 91 13 – General Commissioning (Cx) Requirements.

END OF SECTION