

## **1 GENERAL**

### **1.1 SUMMARY**

- .1 Section Includes:
  - .1 Materials and requirements for the identification of piping systems, duct work, valves and controllers, including the installation and location of identification systems.
  - .2 Sustainable requirements for construction and verification.

### **1.2 RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 02 41 99 – Demolition for Minor Works.
- .3 Section 09 91 99 – Painting for Minor Works.

### **1.3 REFERENCES**

- .1 Canadian Gas Association (CGA)
  - .1 CSA/CGA B149.1, Natural Gas and Propane Installation Code.
  - .2 CSAZ7396.1 Medical Gas pipeline Systems – Part 1: Pipelines for medical gases and vacuum.
- .2 Canadian General Standards Board (CGSB)
  - .1 CAN/CGSB-1.60, Interior Alkyd Gloss Enamel.
  - .2 CAN/CGSB-24.3, Identification of Piping Systems.
- .3 National Fire Protection Association (NFPA)
  - .1 NFPA 13, Standard for the Installation of Sprinkler Systems.
  - .2 NFPA 14, Standard for the Standpipe and Hose Systems.

### **1.4 SUBMITTALS**

- .1 Product Data:
  - .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product data to include paint colour chips, other products specified in this section.
  - .3 Samples:
    - .1 Submit samples in accordance with Section 01 33 00 – Submittal Procedures.
    - .2 Samples to include nameplates, labels, tags, lists of proposed legends.

**1.5**      **QUALITY ASSURANCE**

- .1      Quality assurance submittals: submit following in accordance with Section 01 33 00 – Submittal Procedures.
- .2      Health and Safety:
  - .1      Do construction occupational health and safety in accordance with Section 01 35 29.06 – Health and Safety Requirements.

**1.6**      **DELIVERY, STORAGE, AND HANDLING**

- .1      Packing, shipping, handling and unloading:
  - .1      Deliver, store and handle in accordance with Section 01 61 00 – Common Product Requirements.
  - .2      Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2      Waste Management and Disposal:
  - .1      Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 02 41 99 – Demolition for Minor Works.
  - .2      Dispose of unused paint coating material at official hazardous material collections site approved by Engineer / Architect.
  - .3      Do not dispose of unused paint coating material into sewer system, into streams, lakes, onto ground or in locations where it will pose health or environmental hazard.

**2**      **PRODUCTS**

**2.1**      **MANUFACTURER'S EQUIPMENT NAMEPLATES**

- .1      Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2      Lettering and numbers to be raised or recessed.
- .3      Information to include, as appropriate:
  - .1      Equipment: Manufacturer's name, model, size, serial number, capacity.
  - .2      Motor: voltage, Hz, phase, power factor, duty, frame size.

**2.2**      **SYSTEM NAMEPLATES**

- .1      Colours:
  - .1      Hazardous: red letters, white background.
  - .2      Elsewhere: black letters, white background (except where required otherwise by applicable codes).

.2 Construction:

- .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.

.3 Sizes:

- .1 Conform to following table:

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

- .2 Use maximum of 25 letters/numbers per line.

.4 Locations:

- .1 Terminal cabinets, control panels: Use size # 5.  
.2 Equipment in Mechanical Rooms: Use size # 9.

## 2.3 **EXISTING IDENTIFICATION SYSTEMS**

- .1 Apply existing identification system to new work.  
.2 Where existing identification system does not cover for new work, use identification system specified this section.  
.3 Before starting work, obtain written approval of identification system from Owner's Representative.

## 2.4 **IDENTIFICATION DUCTWORK SYSTEMS**

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.  
.2 Colours: Black, or co-ordinated with base colour to ensure strong contrast.  
.3 Identify system : e.g. Supply AHU-1, Exhaust F-7.

**2.5**            **CONTROLS COMPONENTS IDENTIFICATION**

- .1        Identify all systems, equipment, components, controls, sensors with system nameplates specified in section 25 05 54 – EMCS: Identification. If no EMCS included in project, identification as per this section.
- .2        Inscriptions to include function and (where appropriate) fail-safe position, component ID name.

**2.6**            **LANGUAGE**

- .1        Identification to be in English.

**3**            **EXECUTION**

**3.1**            **MANUFACTURER'S INSTRUCTIONS**

- .1        Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

**3.2**            **TIMING**

- .1        Provide identification only after all painting specified in Section 09 91 99 Painting for Minor Works has been completed.

**3.3**            **INSTALLATION**

- .1        Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2        Provide ULC and/or CSA registration plates as required by respective agency.

**3.4**            **NAMEPLATES**

- .1        Locations:
  - .1        In conspicuous location to facilitate easy reading and identification from operating floor.
- .2        Standoffs:
  - .1        Provide for nameplates on hot and/or insulated surfaces.
- .3        Protection
  - .1        Do not paint, insulate or cover in any way.

**3.5**

**LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS**

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: At not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, dampers, etc. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification to be easily and accurately readable from usual operating areas and from access points.
  - .1 Position of identification to be approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.
  - .2

**3.6**

**CLEANING**

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, rubbish, tools and equipment.

**END OF SECTION**