

Part 1 GENERAL

1.1 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop drawings: submit drawings stamped and signed for approval by Departmental Representative.
- .3 Submit shop drawings and product data for following items:
 - .1 Filters, fan accessibility.
 - .2 Suspension of cabinet.
 - .3 Thermostat, transformer, controls where integral.
 - .4 kW rating, voltage, phase.
 - .5 Cabinet material thicknesses.
- .4 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.
- .5 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals

1.2 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 02 41 13 Selective Site Demolition

Part 2 PRODUCTS

2.1 VRF INDOOR FAN COIL UNITS

- .1 Cabinet: steel, 1.2 mm thick, ceiling mounting, recessed. Back inlet/ front outlet.
- .2 Coil: nonferrous constructions with smooth plate fins on copper tubing. Tubing shall have inner grooves. All tube joints shall be brazed with phos-copper or silver alloy. Condensate pan and drain shall be provided with unit. Refrigerant lines to coil shall be insulated.
- .3 Fan: assembly with one or two Sirocco fans direct driven by a single motor. Shall be statically and dynamically balanced to run on a motor with permanently lubricated bearings.
- .4 Wall mounted thermostats: type low voltage, to Section 23 09 33 - Electric and Electronic Control System for HVAC.
- .5 Fan delay switch.
- .6 Electronic modulating linear expansion device.
- .7 External static pressure settings up to 199 Pa.
- .8 Supplemental heat control capability
- .9 Ducted air outlet system and ducted return air system.
- .10 Filter: return air filtered with field supplied filter.
- .11 Assembly fully wired to one outlet location.
- .12 Multiple knockouts for up to 38 mm diameter conduit.
- .13 Performance data: as indicated on drawings.

Part 3 EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for fan coil units installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Mount units.
- .2 Make electrical and control connections.
- .3 Co-ordinate ducting of fresh air with Division 23.
- .4 Pipe condensate to nearest drain. Install external trap in a heated space for proper condensate drainage for each indoor fan coil unit.

3.3 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.

3.4 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

END OF SECTION