



GENERAL NOTES:

1. GALVANIZED STAIRS AND HANDRAIL TO BE DESIGNED AND SEALED BY A PROFESSIONAL ENGINEER LICENSED TO PRACTICE IN THE PROVINCE OF NEW BRUNSWICK.
2. ALL STEEL USED IN STAIRS, INCLUDING TREADS AND HANDRAIL, MUST HAVE A MINIMUM THICKNESS OF 8mm.