



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Radium HS Site Rehabilitation	
<b>Solicitation No. - N° de l'invitation</b> EP922-180017/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b> PARKS EP922-180017	<b>Date</b> 2017-05-19
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-066-11070	
<b>File No. - N° de dossier</b> PWU-7-40014 (066)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-05-25</b>	
<b>Time Zone</b> Fuseau horaire Mountain Daylight Saving Time MDT	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lee, Mony	<b>Buyer Id - Id de l'acheteur</b> pww066
<b>Telephone No. - N° de téléphone</b> (780) 224-6675 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP922-180017/A  
Client Ref. No. - N° de réf. du client  
PC EP922-180017

Amd. No. - N° de la modif.  
007  
File No. - N° du dossier  
PWU-7-40014

Buyer ID - Id de l'acheteur  
pwu066  
CCC No./N° CCC - FMS No/ N° VME

---

## **SOLICITATION AMENDMENT No. 007**

### **Revision 1:**

#### **ANNEX A - CERTIFICATE OF INSURANCE**

DELETE: Original

INSERT: Attached Annex A.

### **Revision 2:**

See attached question and answer.

**All other terms and conditions to remain unchanged.**

**ANNEX A - CERTIFICATE OF INSURANCE** (Not required at solicitation closing)

**CERTIFICATE OF INSURANCE**



Travaux publics et  
 Services gouvernementaux  
 Canada

Public Works and  
 Government Services  
 Canada

Description and Location of Work Public Works and Government Services Canada (PWGSC) on behalf of Parks Canada is seeking tenders for the provision of all materials, equipment, labour and supervision for Radium Hot Springs Site Rehabilitation as detailed in the specifications, drawings and Invitation to tender document.  Work comprises of demolition of existing concrete ramps and bridge, construction of new structures, and installation and commissioning of electrical/ lighting, hydronic heating, and drainage piping system.	Contract No. EP922-180017
	Project No. R. 072512.001

Name of Insurer, Broker or Agent	Address (No., Street)	City	Province	Postal Code
----------------------------------	-----------------------	------	----------	-------------

Name of Insured (Contractor)	Address (No., Street)	City	Province	Postal Code
------------------------------	-----------------------	------	----------	-------------

Additional Insured

**Her Majesty the Queen in Right of Canada as represented by the Minister of Public Works and Government Services**

Type of Insurance	Insurer Name and Policy Number	Inception Date D / M / Y	Expiry Date D / M / Y	Limits of Liability		
				Per Occurrence	Annual General Aggregate	Completed Operations Aggregate
<b>Commercial General Liability</b> <b>Umbrella/Excess Liability</b>				\$	\$	\$
				\$	\$	\$
<b>Pollution Liability</b>				\$ <input type="checkbox"/> Per Incident <input type="checkbox"/> Per Occurrence		Aggregate \$

I certify that the above policies were issued by insurers in the course of their Insurance business in Canada, are currently in force and include the applicable insurance coverage's stated on page 2 of this Certificate of Insurance, including advance notice of cancellation / reduction in coverage.

Name of person authorized to sign on behalf of Insurer(s) (Officer, Agent, Broker)

Telephone number

Signature

Date D / M / Y

CERTIFICATE OF INSURANCE Page 2 of 2

**General**

The insurance policies required on page 1 of the Certificate of Insurance must be in force and must include the insurance coverage listed under the corresponding type of insurance on this page.

The policies must insure the Contractor and must include Her Majesty the Queen in Right of Canada as represented by the Minister of Public Works and Government Services as an additional Insured.

The insurance policies must be endorsed to provide Canada with not less than thirty (30) days notice in writing in advance of a cancellation of insurance or any reduction in coverage.

Without increasing the limit of liability, the policies must protect all insured parties to the full extent of coverage provided. Further, the policies must apply to each Insured in the same manner and to the same extent as if a separate policy had been issued to each.

**Commercial General Liability**

The insurance coverage provided must not be substantially less than that provided by the latest edition of IBC Form 2100.

The policy must either include or be endorsed to include coverage for the following exposures or hazards if the Work is subject thereto:

- (a) Blasting.
- (b) Pile driving and caisson work.
- (c) Underpinning.
- (d) Removal or weakening of support of any structure or land whether such support be natural or otherwise if the work is performed by the insured contractor.

The policy must have the following minimum limits:


- (a) **\$5,000,000** Each Occurrence Limit;
- (b) **\$10,000,000** General Aggregate Limit per policy year if the policy contains a General Aggregate; and
- (c) **\$5,000,000** Products/Completed Operations Aggregate Limit.

Umbrella or excess liability insurance may be used to achieve the required limits.

**Contractors Pollution Liability**

The policy must have a limit usual for a contract of this nature, but not less than **\$1,000,000** per incident or occurrence and in the aggregate.

Radium Hot Springs Lighting Upgrades and Site Rehabilitation Kootenay National Park  
 The following outlines responses to requests for information:

#	Question	Answer	Date
11	<p>Question:</p> <p>Here is what I have been asked to quote on, with relevant sections cut out below for convenience. I can certainly provide heat trace for this. The spec calls for Urecon product, or approved equal. Our constant wattage cable is MI (minerally insulated) cable. Sample data sheet attached. We use this for all types of industrial pipe heat tracing. My self-regulating heat trace cable is Raychem XL-Trace. This is the standard for pipe freeze protection, but is a different technology that the constant wattage that is called for.</p> <p>My guess would be to quote MI Cable as an approved equal, but would like to confirm with you before proceeding. Thank you.</p>  <p><b>D</b> CONSTANT WATTAGE HEAT TRACE SYSTEM      SCALE N.T.S.</p> <p><b>D</b> CONSTANT WATTAGE HEAT TRACE SYSTEM      SCALE N.T.S.</p> <p><b>DETAIL "D" NOTES:</b></p> <ol style="list-style-type: none"> <li>HEAT TRACE INSTALLATION SHOWN SCHEMATICALLY ONLY, INSTALL AS PER MANUFACTURE RECOMMENDATION.</li> <li>CONDUITS TO BE RIDGE PVC c/w EXPIRATION JOINTS AT EACH SUPPORTED END, MINIMUM DIAMETER OF 25mm (CONDUIT SIZED TO MEET CANADIAN ELECTRICAL CODE) AND SUPPORTED AS PER THE CANADIAN ELECTRICAL CODE WITH TWO HOLE STRAPS (PVC OR STAINLESS STEEL) AS SUPPLIED BY ROYAL IPEX OR APPROVED EQUAL.</li> <li>MINIMUM ACCEPTABLE HEAT TRACE SYSTEM IS THERMOCABLE AND ASSOCIATED CONTROLLER, AS SUPPLIED BY URECON CANADA, OR APPROVED EQUAL.</li> <li>CONTRACTOR TO PROVIDE SHOP DRAWING FOR APPROVAL PRIOR TO CONSTRUCTION.</li> </ol>	<p>Re: Mineral wool insulation (prop alternative to urethan insulation) this is not an approved equal. as the pipe is exposed and low to the ground in some places and in a public place.</p> <p>re: Self regulating heat trace (prop alternative to constant wattage heat trace) - these are not approved equivalents for the purpose of this tender.</p>	2017-May-19



Radium Hot Springs Lighting Upgrades and Site Rehabilitation Kootenay National Park