



1 BASEMENT ELECTRICAL  
E3 SCALE: 1:100




2 FIRST FLOOR ELECTRICAL  
E3 SCALE: 1:100



PWGSC A1 (2004)

LIGHTING FIXTURE SCHEDULE				
TYPE	SYMBOL	MANUFACTURER	DESCRIPTION	LAMP
A		PHILIPS DAY-BRITE 2FGG41B8404DSUNV	1'x4' LED RECESSED TROFFER	4000 LUMEN LED, 4000K
A1		PHILIPS DAY-BRITE 2FGR38B8404DSUNV	2'x2' LED RECESSED TROFFER	4000 LUMEN LED, 4000K
B		PHILIPS SF4C38A50UUS C/W MOTION SENSOR	LED STRIP LIGHT C/W MOTION SENSOR W/ 50% DIMMING	4000 LUMEN LED, 4000K
C		LIGHTOLIER CORE PRO CPSRB08840WCP5RR	LED DOWNLIGHT	900 LUMEN LED, 4000K
D		LYTECASTER L5RREUVA/L5R108040VA/L5RDW	LED DOWNLIGHT, WET LOCATION RATED	900 LUMEN LED, 4000K
D1		LYTECASTER L5RREUVA/L5R108040VA/L5RDW	LED WALL WASHER DOWNLIGHT, WET LOCATION RATED	900 LUMEN LED, 4000K
E		SPECTRUM SPC0624SQU13LND13LND40KEX 5D6FTCYGLWMMB	LED WALL MOUNTED UP/DOWN LIGHT	2000 LUMEN LED, 4000K
F		LEDALITE 24G5-L-A-C-A-G-XX-1-1-W	LED SUSPENDED FIXTURE AT 4500mm	650 LUMEN LED, 4000K
G		COREPRO LT-08-RNF-930-WH TRACK: 6008NWH C/W HARDWARE	TRACK	
L		LUMEC MPTR 55W48LED4KRLE2-120-DMG-APR4-LBC3 -12-BKTX	LED POLE MOUNTED LIGHT TYPE 2 DISTRIBUTION, 12' TAPERED ROUND STEEL POLE, EPA TO 100 MPH +1.3 WIND GUST	3300 LUMEN LED, 6000K
D		AIMLITE CARPW1250-2-M-2MD OR PRE-APPROVED ALTERNATE	GREEN RUNNING MAN EXIT SIGN AND DUAL LAMP EMERGENCY LIGHT C/W 2 HOUR EMERGENCY BACKUP	2-4LR
E		AIMLITE EBST-12050-2MD-4WLR OR PRE-APPROVED ALTERNATE	12VDC/120VAC, 44W, 10YR MAINTENANCE FREE BATTERY	2-4WLR
		AIMLITE EBST-REMOTE HEAD	REMOTE HEAD COMPATIBLE WITH SPECIFIED BATTERY UNIT	2-4WLR
			PHOTOCELL, 120V, FOR EXTERIOR LIGHTING	



3 LIGHTING CONTACTOR  
E3 SCALE: NTS

THIS DRAWING IS PROVIDED TO REFLECT THE GENERAL EXTENT OF WORK AND AS SUCH DOES NOT NECESSARILY INDICATE THE ENTIRE SCOPE OF WORK. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH RELATED ARCHITECTURAL, STRUCTURAL, ELECTRICAL AND/OR MECHANICAL DRAWINGS/DETAILS, SPECIFICATIONS, TENDER AND/OR OTHER CONTRACT DOCUMENTS, AS APPLICABLE.

THIS DRAWING AND ITS RELATED DESIGNS, CALCULATIONS AND SPECIFICATIONS ARE INSTRUMENTS OF PROFESSIONAL SERVICE FOR THE EXECUTION OF THE WORK ON THIS PROJECT ONLY. THIS DRAWING SHALL NOT BE USED FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN CONSENT OF THE ENGINEER. THE ENGINEER ACCEPTS NO RESPONSIBILITY FOR LOSSES, DAMAGES OR COSTS ARISING OUT OF ANY USE OR REUSE OF THIS DRAWING NOT SPECIFICALLY AUTHORIZED BY THE ENGINEER IN WRITING.

"RECORD" OR "AS-BUILT" VERSIONS OF THIS DRAWING ARE BASED ON INFORMATION PROVIDED BY OTHERS AND THE ENGINEER NEITHER EXPRESSLY NOR IMPLICITLY WARRANTS THE ACCURACY OR COMPLETENESS OF SAID DOCUMENTS.

EXCEPT AS MAY BE CERTIFIED OTHERWISE IN WRITING BY THE ENGINEER, ONLY THE REPRODUCIBLE HARD COPY BEARING THE ENGINEER'S SEAL AND ORIGINAL SIGNATURE SHALL CONSTITUTE THE ORIGINAL OF THIS DRAWING.

THIS DRAWING IS NOT TO BE SCALED. OBTAIN ACCURATE DIMENSIONS FROM ARCHITECTURAL DRAWINGS OR SITE MEASUREMENTS.

83 Frying Street  
P.O. Box 1719  
Charlottetown PE  
Canada C1A 1R4  
Ph: (800-566-4440)  
Fax: (800-566-1232)  
architects@bjh.com  
www.bjh.com

**BERGMARK  
JONES  
ARCHITECTS**

**FUNDY Engineering**

27 Wellington Row  
P.O. Box 6626  
Saint John, NB  
E2L 4S1  
Tel: (506) 635-1566  
Fax: (506) 635-0206  
fundy@fundyeng.com  
www.fundyeng.com  
Serving Our Clients' Needs First



4	ISSUED FOR TENDER	05/08 2017
3	ISSUED FOR 99% REVIEW	04/07 2017
2	ISSUED FOR 99% REVIEW	01/19 2017
1	ISSUED FOR 50% REVIEW	11/01 2016
0	DESIGN DEVELOPMENT	09/09 2016
revisions		date

project project

**WEST GATE ENTRANCE  
VISITOR RECEPTION CENTER  
WOLFE LAKE  
FUNDY, NB  
ALBERT COUNTY**

drawing dessin  
**ELECTRICAL  
LIGHTING PLAN**

designed KMC conçu

date

drawn JDB dessiné

date

approved approuvé

date

Tender Soumission

PWGSC Project Manager Administrateur de projets TPSCG

project number no. du projet

**R.075853.001**

drawing no. no. du dessin

**E3**

E-DRM/GDD-E: 547463 Version 1