



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des
soumissions/Travaux publics et Services
gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Crystal Bysterveldt, either by facsimile or by e-mail at:
crystal.bysterveldt@pwgsc.gc.ca.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet HVAC Upgrade - Ardgowan, PEI	
Solicitation No. - N° de l'invitation ED001-180039/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.080258.002	Date 2017-05-25
GETS Reference No. - N° de référence de SEAG PW-\$PWC-024-4128	
File No. - N° de dossier PWC-7-40013 (024)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-05-30	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bysterveldt (PWC), Crystal	Buyer Id - Id de l'acheteur pwc024
Telephone No. - N° de téléphone (902) 626-2831 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

THIS ADDENDUM IS RAISED TO PROVIDE THE FOLLOWING ANSWERS TO QUESTIONS PROVIDED BY BIDDERS.

1. QUESTION

Are the existing intake dampers and actuators on the intake louvers in the attic to remain? If so, who controls these? Do the ERV's come with outdoor dampers and will they be in conjunction with the existing intake dampers?

ANSWER

Existing intake motorized dampers to remain. ERV's to control them.

2. QUESTION

Please provide a specification for the Intelligent Motorized Dampers (IMD), including actuator requirements. Are access hatches required when these IMD's are to be concealed in bulkheads, ceilings or walls?

ANSWER

Dampers are specified under section 23 33 15, actuators specified under section 25 30 01, paragraphs 2.2.1 to 2.2.4 Access hatches are required as per spec section 23 33 15.

3. QUESTION

Will the new ductwork in room 107 and 108 be exposed?

ANSWER

Ducts are to be exposed.

4. QUESTION

How will the tandem hood for ERV-3 be installed if grade is too high? Will a window-well be installed and core drilling be done?

ANSWER

Provide window well and core drilling as required.

5. QUESTION

Do ERV-1 and 2 require drains?

ANSWER

No drains required for an ERV.

6. QUESTION

How are we to provide a drain to ERV-3?

ANSWER

No drains required for an ERV.

SPECIFICATIONS

Reference Section 23 72 00 2.2 Air to Air Fixed Plate Energy Recovery Ventilator (ERV)

Paragraph 2.2.4

Delete: Condensate drain: shall be provided.

Replace with: Condensate drain: not required.