



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Wharf Construction - Caraquet,NB	
Solicitation No. - N° de l'invitation EC015-180071/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.081895.001	Date 2017-05-29
GETS Reference No. - N° de référence de SEAG PW-\$PWB-007-4124	
File No. - N° de dossier PWB-7-40012 (007)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-20	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ellis-Herring , Alison PWB	Buyer Id - Id de l'acheteur pwb007
Telephone No. - N° de téléphone (506) 636-3908 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. four (4) is raised to include the following addendum no. 4.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 4.

1. QUESTIONS AND ANSWERS

Q.1 Why is the timeframe for this project so long? The completion date is the 20th, November, 2020.

A.1 The completion date was estimated based on scheduling from similar projects completed in the past.

Q.2 The beginning of construction is planned for what date?

A.2 Construction can begin following the award of the contract and approval of the contractor's work schedule and site specific safety plan.

Q.3 It is mentioned that the daily activities at the port are coordinated and approved by Mr. Daniel Landry. (paragraph 1.5.1, section 01 10 10). We would like to receive, in writing, for the tender the relevant requirements (on the surface of the wharf itself) for the construction of wharf 410P.

A.3 Once construction begins structure 405 will be available to the contractor until completion of the work.

Q.4 Will the daily activities on this wharf continue during construction? Will it be impossible for us to carry-out work during certain months?

A.4 Once work begins on structure 405 this structure will be under the control of the contractor until completion of the work. Activities on other structures in the harbour will continue. For safety reasons, access to structure 405 through the other structures, will be coordinated with the harbour manager, Daniel Landry.

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

- Q.5 On item 15 of the unit price table, titled "Concrete Anchor Blocks", we believe the unit of measure should be Each instead of CU.M.
- A.5 The unit of measure for this item has been changed to Ea. and is reflected in the revised price table.
- Q.6 What is the thickness of the existing concrete deck on the wharf?
- A.6 Refer to the 'Concrete Wharf Inspection Report' by GEMTEC for guidance on the concrete thickness. The contractor is required to make assumptions to satisfy the complete removal of the concrete.
- Q.7 Is the 150 mm granular infill material specified in item 9 of the unit price table gravel or crushed rock of 0-150mm grading?
- A.7 Item 9 should read '150 mm Minus Crushed Rock Infill between SSP Walls' – this has been updated in the price table. See structural drawings and specification section 31 23 33 paragraph 2.1.3 for more information.
- Q.8 Is the 75mm or 150mm crushed rock specified in item 10 of the unit price table crushed rock of 0-75 mm or 0-150mm?
- A.8 Item 10 should read '75 mm Minus Crushed Rock' – this has been updated in the price table. See specification section 31 23 33 paragraph 2.1.1 for more information.
- Q.9 Is the 31.5 mm crush rock specified in item 11 of the unit price table crushed rock with a grading of 0-31.5 mm?
- A.9 Item 11 should read '31.5 mm Minus Crushed Rock' – this has been updated in the price table. See specification section 31 23 33 paragraph 2.1.1 for more information.
- Q.10 In section 01 29 00, page 7, division 3, .3... it is indicated that concrete light bases will be measured for payment for EACH. However there is no item on the unit price table for concrete light bases.
- A.10 The price table has been updated to reflect this.

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

Q.11 Does the construction have to be performed in phases?

A.11 No

Q.12 Does work have to be performed in 2017

A.12 There is money budgeted for construction for this year (2017).

2. APPENDIX 1 – COMBINED PRICE FORM

Remove Appendix 1 – Combined Price Form **and replace with** Revised Appendix 1 – Combined Price Form dated May 29, 2017.

Note: The Revised Appendix 1 – Combined Price Form dated May 29, 2017 attached in this amendment is the unit price table that **MUST** be submitted as your bid. Failure to comply with this requirement will result in your bid being deemed non-responsive.

APPENDIX 1 - REVISED MAY 29, 2017 COMBINED PRICE FORM (2 pages)

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

LUMP SUM AMOUNT (LSA) Excluding applicable tax(es)	Not applicable
--	----------------

UNIT PRICE TABLE

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- (a) Work included in each item is as described in the referenced specification section.
 (b) The Price per Unit shall not include any amounts for Work that is not included in that unit price Item.

	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit applicable tax(es) extra (PU)	Extended amount (EQ x PU) applicable tax(es) extra
1	Division 01	Site Organization, Demolition, and/or Waste Disposal	Lump sum	1		
2	Division 26	Electrical	Lump sum	1		
3	Division 33	Mechanical Installations	Lump sum	1		
4	03 30 00	Concrete Filling of Sheet Pile	meter	913		
5	03 30 00	Concrete deck and Bollard Bases	Square meter	1553		
6	03 30 00	Concrete Light Bases	Each	5		
7	Division 05	Wheel Guard	Meter	242		
8	Division 05	Net Guard	Meter	11		
9	31 23 33	Excavation and Disposal of Soils	Cubic meter	6150		
10	31 23 33	150mm Minus Crushed Rock Infill between SSP Walls	Tonne	5083		
11	31 23 33	75mm Minus Crushed Rock	Tonne	9021		
12	31 23 33	31.5mm Minus Crushed Rock	Tonne	1696		
13	31 32 21	Non-Woven Geotextile	Square meter	3235		
14	31 62 16	Steel Sheet Pile	Square meter	7310		

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit applicable tax(es) extra (PU)	Extended amount (EQ x PU) applicable tax(es) extra
15	31 62 16	Tie rods	Meter	1583		
16	31 62 16	Concrete Anchor Blocks	Each	2		
17	31 62 16	456 Diameter Pipe Piles	Each	2		
18	32 12 16	Asphalt (100mm thick)	Square meter	1891		
19	35 59 13	Rubber Tire Fenders	Each	73		
20	35 59 13	Rubber D-Fender System	Each	41		
21	35 59 29	10 tonne mooring cleats	Each	46		
22	35 59 29	50 tonne mooring bollards	Each	22		
23	35 70 00	Ladders	Each	24		
TOTAL EXTENDED AMOUNT (TEA) Excluding applicable tax(es)						

TOTAL BID AMOUNT (LSA +TEA) Excluding applicable tax(es)
--