


**PUBLIC WORK AND
GOVERNMENT SERVICES
CANADA**

Project title	Project
CRA WINNIPEG TAX-CENTRE FIT-UP	
-	
WINNIPEG, MANITOBA	


Designed by DR	Conçu par
Drawn by EB	Dessiné par
Approved by DS	Approuvé par
PWGSC Project Manager Jason Frezza	Administrateur de Projets TPSGC
Drawing Title	Titre du dessin

Project no./No. du projet	Drawing no./No. du dessin	Revision no.
R.078618	M4.1	
	OF	




VAV TERMINAL ACOUSTIC INSULATION

SCALE: N.T.S.




OBSTRUCTIONS

SCALE: N.T.S.




FIRE DAMPER - FUSIBLE LINK

SCALE: N.T.S.



OFFSETS AND TRANSITIONS

SCALE: N.T.S.




LOW PRESSURE DUCT

MAX. SIDE *	GAUGE	MAX. LENGTH	TRANSVERSE JOINT	BRACING ANGLE
UP TO 12"	26	94"	REINF. 'S' & DRIVE SLIP	NONE
13" TO 24"	24	94"	REINF. 'S' & DRIVE SLIP	NONE
25" TO 30"	24	45"	1 1/8" T	NONE
31" TO 40"	22	45"	1 1/8" T	NONE
41" TO 60"	22	44"	1 5/8" T	NONE
61" TO 90"	20	44"	1 5/8" T	1 1/2" x 1 1/2" x 1/8"
91" & WIDER	18	44"	1 5/8" T	1 1/2" x 1 1/2" x 1/8"

- BRACING ANGLE IRON BETWEEN JOINTS

LOW PRESSURE DUCTWORK GAUGE SCHEDULE


SCALE: N.T.S.



ACOUSTIC ELBOW DETAIL

SCALE: N.T.S.

NOTE: FLEX DUCT SHALL NOT
BE USED IN ELBOWS



SQUARE DIFFUSER INSTALLATION DETAIL

SCALE: N.T.S

