



# TENDER AMENDMENT

**RETURN BIDS TO:**

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3  
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

**Issuing Office:**

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

# MODIFICATION D'APPEL D'OFFRES

**RETOURNER LES SOUMISSIONS À :**

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300,  
Calgary, AB T2P 3M3  
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Bureau de distribution :**

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300  
Calgary (AB) T2P 3M3

<b>Title:</b> Mount Edith Cavell Parking Lot and Road Reconstruction, Jasper National Park		
<b>Solicitation No.: / N° de l'invitation :</b> 5P420-17-5061/A	<b>Amendment No.: / N° de modification de l'invitation :</b> 006	<b>Date:</b> May 31, 2017  <b>Date :</b> 31 mai 2017
<b>GETS Reference No.: / N° de référence de SEAG :</b> PW-17-00776653		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> June 6, 2017	<b>Time Zone:</b> Mountain Daylight Time (MDT)
<b>À :</b> 14h00	<b>Le :</b> 6 juin 2017	<b>Fuseau horaire :</b> Heure avancée des Rocheuses (HAR)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b> Nicole Levesque-Welch		
<b>Telephone No.: / N° de téléphone :</b> (403) 292-4691	<b>Fax No.: / N° de télécopieur :</b> (403) 292-4475	<b>Email Address: / Courriel :</b> <a href="mailto:nicole.levesque-welch@pc.gc.ca">nicole.levesque-welch@pc.gc.ca</a>
<b>TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)</b>		
<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>		
<b>Address - Adresse</b>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		
<b>Title - Titre</b>		
<b>Signature</b>		<b>Date</b>



## AMENDMENT 006

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-17-5061/A:

### A. QUESTIONS AND ANSWERS

Q11. The sewage storage tank on the drawings identifies a fiber glass holding tank, can we use a concrete holding tank? Most of the local suppliers that have previously supplied these to the Park, do not carry fiber glass tanks.

A11. Bidder is to provide bid price for the specified product (Section 33 33 14 Sewage Storage Tank) in their bid. No, concrete tank will be accepted.

Q12. With respect to the washed rock required in the sub drain trenches under the parking lot, is this material available at the Marmot Pit?

A12. No, contractor to supply.

Q13. With respect to both the asphalt trail repairs and new proposed trail, is this Hot Mix Asphalt or Cold Mix Asphalt?

A13. Hot Mix Asphalt as per Section 32 12 16 Asphalt Paving in the contract.

Q14. Will Parks Canada be doing the QC and QA testing with respect to earthworks and the asphalt?

A14. Please refer to section 01 45 00 Quality Control.

***All other terms and conditions remain the same.***