



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Solicitation Amendment 001 is issued to release the
specifications and drawings that were not issued
with the original solicitation documents.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Infrastructure Improvements Phase 2	
Solicitation No. - N° de l'invitation EZ899-173322/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client	Date 2017-06-02
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8054	
File No. - N° de dossier PWY-7-40004 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-07	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Infrastructure Improvements Phase 2 - Glacier National Park - Rogers Pass, BC Maintenance Compound	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-173322/A

Amd. No. - N° de la modif.
008

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

The Solicitation Amendment 008 is raised to issue Addendum #6.

1) Please find Addendum #6 herein.

All other terms and conditions remain unchanged.

GENERAL

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

SPECIFICATIONS

n/a

DRAWINGS

n/a

CLARIFICATIONS

Questions Received by PWGSC to June 02, 2017

1. *Section 33 05 16, Maintenance Holes and Catch Basin Structures, Part 2.2 – Pre-Cast Vaults and Chambers. 2.2.2 [requires] “Manufacture to have AASHTO recognized third party certificate”. Could that be amended to add or an approved equal?*

Yes. Products from precast plants with approved equivalent third party certifications may be used.

Additional Questions Received to June 02, 2017

1. *The specifications are a bit confusing in regards to cast in place concrete and asphalt testing. Can you please clarify who is responsible for what testing and who will be covering what costs.*

Cast-In-Place Concrete

The proponent is responsible for all testing requirements and is required to cover all associated costs. The proponent may select a CSA certified testing laboratory of their choosing.

Hot Mix Asphalt:

The proponent is NOT responsible for testing of HMA. Testing and costs for review of HMA mix designs, reviewing paving activity, testing during placement, and field coring will be the responsibility of a third party retained by the Departmental Representative.

The cost of any work required due to failed tests WILL be the responsibility of the proponent.

END OF ADDENDUM #6