



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Solicitation Amendment 001 is issued to release the  
specifications and drawings that were not issued  
with the original solicitation documents.

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

|                                                                                                                                                                                                                                          |                                                                           |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|
| <b>Title - Sujet</b><br>Infrastructure Improvements Phase 2                                                                                                                                                                              |                                                                           |
| <b>Solicitation No. - N° de l'invitation</b><br>EZ899-173322/A                                                                                                                                                                           | <b>Amendment No. - N° modif.</b><br>008                                   |
| <b>Client Reference No. - N° de référence du client</b>                                                                                                                                                                                  | <b>Date</b><br>2017-06-02                                                 |
| <b>GETS Reference No. - N° de référence de SEAG</b><br>PW-\$PWY-028-8054                                                                                                                                                                 |                                                                           |
| <b>File No. - N° de dossier</b><br>PWY-7-40004 (028)                                                                                                                                                                                     | <b>CCC No./N° CCC - FMS No./N° VME</b>                                    |
| <b>Solicitation Closes - L'invitation prend fin<br/>at - à 02:00 PM<br/>on - le 2017-06-07</b>                                                                                                                                           | <b>Time Zone</b><br>Fuseau horaire<br>Pacific Daylight Saving<br>Time PDT |
| <b>F.O.B. - F.A.B.</b><br><b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>                                                              |                                                                           |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br>Lam (PWY), Tian                                                                                                                                                           | <b>Buyer Id - Id de l'acheteur</b><br>pwy028                              |
| <b>Telephone No. - N° de téléphone</b><br>(604) 363-7968 ( )                                                                                                                                                                             | <b>FAX No. - N° de FAX</b><br>(604) 775-6633                              |
| <b>Destination - of Goods, Services, and Construction:</b><br><b>Destination - des biens, services et construction:</b><br>PWGSC - Infrastructure Improvements Phase 2 - Glacier National Park - Rogers Pass, BC<br>Maintenance Compound |                                                                           |

Instructions: See Herein

Instructions: Voir aux présentes

|                                                                                                                                                                                                                                                    |                                              |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|
| <b>Delivery Required - Livraison exigée</b>                                                                                                                                                                                                        | <b>Delivery Offered - Livraison proposée</b> |
| <b>Vendor/Firm Name and Address</b><br><b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>                                                                                                                                           |                                              |
| <b>Telephone No. - N° de téléphone</b><br><b>Facsimile No. - N° de télécopieur</b>                                                                                                                                                                 |                                              |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm<br/>(type or print)</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/<br/>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b> |                                              |
| <b>Signature</b>                                                                                                                                                                                                                                   | <b>Date</b>                                  |

Solicitation No. - N° de l'invitation  
EZ899-173322/A

Amd. No. - N° de la modif.  
008

Buyer ID - Id de l'acheteur  
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

---

The Solicitation Amendment 008 is raised to issue Addendum #6.

- 1) Please find Addendum #6 herein.

All other terms and conditions remain unchanged.

## **GENERAL**

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

## **SPECIFICATIONS**

n/a

## **DRAWINGS**

n/a

## **CLARIFICATIONS**

### Questions Received by PWGSC to June 02, 2017

1. *Section 33 05 16, Maintenance Holes and Catch Basin Structures, Part 2.2 – Pre-Cast Vaults and Chambers. 2.2.2 [requires] “Manufacture to have AASHTO recognized third party certificate”. Could that be amended to add or an approved equal?*

**Yes. Products from precast plants with approved equivalent third party certifications may be used.**

### Additional Questions Received to June 02, 2017

1. *The specifications are a bit confusing in regards to cast in place concrete and asphalt testing. Can you please clarify who is responsible for what testing and who will be covering what costs.*

#### **Cast-In-Place Concrete**

**The proponent is responsible for all testing requirements and is required to cover all associated costs. The proponent may select a CSA certified testing laboratory of their choosing.**

#### **Hot Mix Asphalt:**

**The proponent is NOT responsible for testing of HMA. Testing and costs for review of HMA mix designs, reviewing paving activity, testing during placement, and field coring will be the responsibility of a third party retained by the Departmental Representative.**

**The cost of any work required due to failed tests WILL be the responsibility of the proponent.**

**END OF ADDENDUM #6**