



LEVEL 1 - POWER & SYSTEMS 1
SCALE: 1:125

EQUIPMENT LIST SCHEDULE								
EQUIPMENT TAG	DESCRIPTION	VOLTS	PHASE	WIRES	AMPS/KW/HP	CONNECTION	DISCONNECT	COMMENTS
E3	FLIGHT INFORMATION DISPLAY	120	1	-	-	-	-	-
E6	VENDING MACHINE	120	1	-	-	-	-	-
E7	PARKING PAY	120	1	-	-	-	-	-
E8	BEVERAGE COOLER	120	1	-	-	-	-	-
E9	WALL MOUNTED TELEVISION	120	1	-	-	-	-	-
E11	BEVERAGE COOLER	120	1	-	-	-	-	-
E12	GRAB-N-GO	120	1	-	-	-	-	-
E13	DESSERTS	120	1	-	-	-	-	-
E14	ELECTRIC FRYER	120	1	-	-	-	-	-
E15	POINT OF SALE	120	1	-	-	-	-	-
E16	SANDWICH/SALAD PREP + PLATE SHELF	120	1	-	-	-	-	-
E17	DISHWASHER	120	1	-	-	-	-	-
E18	TOASTER	120	1	-	-	-	-	-
E22	COMBI OVEN	120	1	-	-	-	-	-
E23	ELECTRIC FRYER	120	1	-	-	-	-	-
E24	RANGE/GRILLE	120	1	-	-	-	-	-
E25	MECHANICAL HOOD	120	1	-	-	-	-	-
E26	REFRIGERATOR	120	1	-	-	-	-	-
E28	ICE CREAM COOLER	120	1	-	-	-	-	-
E29	CHEST COOLER	120	1	-	-	-	-	-
E30	PARKING PAY	120	1	-	-	-	-	-
E32	MULTI-MEDIA SCREEN	120	1	-	-	-	-	-
E36	SCALE	120	1	-	-	-	-	-
E37	A/V SCREEN	120	1	-	-	-	-	-
E38	ICE MACHINE	120	1	-	-	-	-	-
E39	PAY PHONE	120	1	-	-	-	-	-
E40	TRAINING COMPUTER	120	1	-	-	-	-	-
E43	TIME ZONE CLOCK	120	1	-	-	-	-	-

GENERAL NOTES

1. ALL ELECTRICAL EQUIPMENT (E14, E22, E23, E24) UNDER THE MECHANICAL HOOD (E25) ARE TO BE DE-ENERGIZED IF HOOD FIRE SUPPRESSION SYSTEM IS ACTIVATED. PROVIDE CONTACTOR ABOVE ACCESSIBLE CEILING SPACE TO ACHIEVE THIS. PROVIDE ALL LINE VOLTAGE WIRING REQUIRED FOR CONNECTION OF MICRO SWITCH AND ETC. ASSOCIATED WITH THE FIR SUPPRESSION SYSTEM.



Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

PERMIT HOLDER CLASS "A" This Permit Allows WSP CANADA INC. Member in Responsible Charge: CRAIG MACINTYRE, P.Eng. To practice Professional Engineering in Newfoundland and Labrador. Permit No. as issued by PEBC: 10075. Which is valid for the year 2017.

PROFESSIONAL ENGINEER CRAIG MACINTYRE, P.Eng. MAR 30 2017

prime consultant: **ARCHITECTURE 49**

WSP

APPROX. NORTH

F	ISSUED FOR TENDER	MAR 30 2017
E	ISSUED FOR 99% REVIEW	FEB 10 2017
D	ISSUED FOR 66% REVIEW	NOV 4 2016
C	ISSUED FOR 33% REVIEW	AUG 5 2016
B	DESIGN DEVELOPMENT	MAY 27 2016
A	DESIGN DEVELOPMENT	MAR 26 2016

revisions: _____ date: _____

project: **WABUSH ATB RENOVATIONS**

WABUSH AIRPORT WABUSH, NL

drawing: **LEVEL 1 - POWER & SYSTEMS AND ENLARGED KITCHEN & EQUIPMENT SCHEDULE** design

designed: C.MACINTYRE congn
date: MAY 2016
drawn: M.KAMPHUIS design
date: MAY 2016
approved: C.MACINTYRE approve
date: MAY 2016
Tender: _____ Soumission: _____
PWSC Project Manager: _____ Administrateur de projets TPSC: _____
project number: **R.076412.001** no. du projet
drawing no.: **E8** no. du dessin

E-DRM/gdb-E: 540135