


FLOOR PLAN - FIRE PROTECTION DEMOLITION, LEVEL 2
SCALE: 1:125

- ### SPRINKLER GENERAL NOTES
1. THESE PLANS HAVE BEEN PREPARED TO PROVIDE GUIDANCE FOR BIDDING. REFER TO SPECIFICATIONS FOR ADDITIONAL REQUIREMENTS. OBTAIN APPROVAL OF SHOP DRAWINGS FROM THE AUTHORITY HAVING JURISDICTION PRIOR TO FABRICATION & INSTALLATION. SUBMIT SHOP DRAWINGS TO AND COMPLY WITH REQUIREMENTS OF THIRD PARTY CONSULTANT AS PER SPECIFICATIONS.
 2. CONTRACTOR IS RESPONSIBLE FOR PROVIDING A COMPLETE WET SPRINKLER SYSTEM INSTALLED AND TESTED SYSTEM IN ACCORDANCE WITH NFPA 13 AND LOCAL CODES. CONTRACTOR IS RESPONSIBLE FOR DESIGN AND ENGINEERING OF THIS SYSTEM.
 3. SHOP DRAWINGS SHALL INCLUDE ELEVATION, HANGER LOCATIONS, PIPE LENGTHS, DIMENSIONS, FABRICATION METHODS, MATERIAL DATA, AND ADDITIONAL INFORMATION NECESSARY TO CLARIFY THE INTENT OF INSTALLATION.
 4. COORDINATE LOCATIONS OF FIRE PROTECTION COMPONENTS, INCLUDING PIPING, ALARMS, DRAINS, TEST POINTS, ETC. WITH ARCHITECTURAL, STRUCTURAL, MECHANICAL, AND ELECTRICAL. OBSTRUCTION TO SPRINKLER DISCHARGE MUST BE CONSIDERED DURING SHOP DRAWING PRODUCTION.
 5. SUBMIT A REQUEST FOR INFORMATION FOR QUESTIONS REGARDING THE FIRE PROTECTION DOCUMENTS.
 6. CONTRACTOR TO PROVIDE UPRIGHT OR PENDANT SPRINKLER HEADS BASED ON ARCHITECTURAL REFLECTED CEILING PLAN AS FOLLOWS: UPRIGHT SPRINKLER HEADS FOR AREAS WITHOUT CEILING AND PENDENT SPRINKLER HEADS FOR AREAS WITH CEILING.
 7. SEISMIC RESTRAINTS SHALL BE PROVIDED AS REQUIRED BY LOCAL CODE. CONTRACTOR TO PROVIDE ENGINEER TO REVIEW DOCUMENTS AS REQUIRED.
 8. CONTRACTOR TO FOLLOW OBSTRUCTION RULES AS PER NFPA 13.

- ### DRAWING NOTES
1. EXISTING SPRINKLERS AND PIPING TO BE REMOVED.
 2. EXISTING STANDPIPE SYSTEM TO BE REMOVED.



EXISTING RISER DETAIL
SCALE: NTS

0	ISSUED FOR TENDER	APR 12, 2017
revisions		date
project	WABUSH ATB RENOVATION WABUSH AIRPORT WABUSH, NL	
drawing	FLOOR PLAN LEVEL 2 SPRINKLER DEMOLITION	
designed	MB	comp
date	FEB. 2017	
drawn	MB	desaf
date	FEB. 2017	
approved	MB	approved
date	FEB. 2017	
Tender	2017/05/10	
PWSSC Project Number	R.076412.001	
project number	no. du projet	
drawing no.	no. du dessin	
	FP-2	

2017-05-10 10:00 AM PWSSC Project Number R.076412.001