

FLOOR PLAN - FIRE PROTECTION DEMOLITION, LEVEL 1

SCALE: 1:125

1 | FA-1

FIRE ALARM SYSTEM

SYMBOL	DESCRIPTION
F	ADDRESSABLE FIRE ALARM PULL STATION
P	FIRE ALARM HORN - WALL MOUNTED
V	COMBINATION HORN / STROBE LIGHT - WALL MOUNTED
V	COMBINATION HORN / STROBE LIGHT - CEILING MOUNTED
P	HORN - CEILING MOUNTED
SD	ADDRESSABLE TRUE ALARM PHOTO-ELECTRIC SMOKE DETECTOR
	ADDRESSABLE PROGRAMMABLE HEAT DETECTOR
OCM	ADDRESSABLE OUTPUT CONTROL MODULE
DSD	ADDRESSABLE DUCT MOUNTED SMOKE DETECTOR
FANN	FIRE ALARM ANNUNCIATOR
IAM	ADDRESSABLE MODULE
TS	TAMPER SWITCH
FS	FLOW SWITCH
LPA	LOW PRESSURE ALARM
LPS	LOW PRESSURE SWITCH
N	SYMBOLS WITH SUFFIX 'N' INDICATES EXISTING EQUIPMENT OR OUTLETS REMOVED & RE-INSTALLED IN NEW LOCATIONS
RR	SYMBOLS WITH SUFFIX 'RR' INDICATES EXISTING EQUIPMENT OR OUTLETS TO BE REMOVED & RELOCATED IN NEW LOCATIONS
	EXCEPT AS NOTED OTHERWISE, ALL EXISTING EQUIPMENT TO REMAIN IS SHOWN IN THIN SOLID LINES.
	EXCEPT AS NOTED OTHERWISE, ALL EXISTING EQUIPMENT TO BE DEMOLISHED OR RELOCATED IS SHOWN IN THICK DASHED LINES. RELOCATED ITEMS ARE WITH SUFFIX 'RR' OR 'N'
	EXCEPT AS NOTED OTHERWISE, ALL NEW EQUIPMENT IS SHOWN IN THICK SOLID LINES.

GENERAL NOTES

A. CO-ORDINATE DEMOLITION WORK WITH ARCHITECTURAL PHASING NOT SHOWN ON THIS DRAWING. REFER TO ARCHITECTURAL DRAWINGS FOR DETAILS.

B. FIRE ALARM WORK IN SPECIFIC CONSTRUCTION ZONE SHOULD NOT IMPACT REMAINING PORTION OF THE FIRE ALARM SYSTEM IN THE FACILITY. PROVIDE TEMPORARY BY-PASSES AS REQUIRED.

C. FIRE ALARM SYSTEM MUST BE FULLY OPERATIONAL AT THE END OF THE END OF EACH WORKING DAY.

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

PROVINCE OF NEWFOUNDLAND AND LABRADOR
pegnl PERMIT HOLDER CLASS "A" This Permit Allows
WSP CANADA INC.
Member in Responsible Charge: MANJUSHA NAIDU, P.Eng. No. 07734
To practice Professional Engineering in Newfoundland and Labrador.
Permit No. as issued by PEGNL LO075 which is valid for the year 2017.

REGISTERED PROFESSIONAL ENGINEER
PEGNL
MANJUSHA NAIDU
SIGNATURE
12/04/2017
DATE
NEWFOUNDLAND & LABRADOR

prime consultant:

ARCHITECTURE | 49

sub consultant:

WSP

revisions		date
0	ISSUED FOR TENDER	APR. 12, 2017

project / projet

WABUSH ATB RENOVATION

WABUSH AIRPORT

WABUSH, NL

drawing / dessin

FLOOR PLAN
LEVEL 1 FIRE ALARM DEMOLITION

designed / conçu: BH
date: FEB. 2017
drawn / dessiné: GG
date: FEB. 2017
approved / approuvé: JH
date: FEB. 2017
Tender / Soumission: 2017/05/12
PWGSC Project Manager / Administrateur de projets TPSGC

project number / no. du projet: R.076412.001

drawing no. / no. du dessin: FA-1

PWGSC B1 (2004)

E-DRM/GDD-E: 540135 Version 1

Z:\5.1 DELTEK PROJECTS\2016 PROJECTS\16\0001\00 WABUSH ATB\D - DESIGN\1 - DRAWINGS & SPECS\4 - MILESTONE SUBMITTALS\4 - TENDER SPECS AND DRAWINGS\2017-04-06\FA1101-0001\00_FA1-FA4_NEW & DEMO.DWG