



1. ALL RUN OUTS TO BE 18mm UNLESS OTHERWISE NOTED. MINIMUM PIPE SIZE SHALL BE 19mm.
2. ALL PIPING PENETRATING FIRE WALLS ARE TO HAVE PROPER PIPE SLEEVES AND SEALED WITH AN APPROVED FIRE RETARDANT SEALER.
3. PROVIDE CHROME PLATED ESCUTCHEON PLATES ON ALL PIPES PASSING THRU WALLS, PARTITIONS, FLOORS & CEILINGS IN FINISHED AREAS.
4. INSTALL ANCHORS AND COMPENSATORS AS PER DRAWINGS.
5. EXACT ARRANGEMENT OF PIPING AT ALL COILS TO BE FIELD DETERMINED.
6. WATER CONNECTIONS TO ALL COILS SHALL BE RIGHT HAND OR LEFT HAND AS REQUIRED. SEE DWGS FOR SAME.
7. PROVIDE AUTOMATIC AIR VENTS AT ALL HIGH POINTS IN HEATING/CHILLER PIPING SYSTEM AS PER SPECIFICATION.
8. PROVIDE DRAINS AT ALL LOW POINTS IN THE HEATING SYSTEM TO ALLOW COMPLETE DRAINAGE OF THE HEATING/CHILLER PIPING SYSTEM.
9. INSULATE ALL PIPING AS PER THE SPECIFICATION.
10. ALL VALVES SHALL BE THE SAME SIZE AS THE LINES IN WHICH THEY ARE INSTALLED.
11. COORDINATE THE PAINTING OF EXPOSED MECHANICAL PIPING/SERVICES IN FINISHED AREAS WITH THE GENERAL CONTRACTOR.

5-DBM/CDD-5: 540135 VERSION 1