



- NOTES**
- THIS IS A DEDICATED TELEPHONE BACK TO LAND LINE ROOM ON MAIN LEVEL.
  - PROVIDE 3 (THREE) 25mm CONDUITS UP THE SAW CUT ACROSS THE FLOOR AND INTO THE BASE OF THE TABLE. COORDINATE LOCATION OF THE BASE ON SITE.  
CONDUITS AS FOLLOWS:  
- 1 (ONE) CONDUIT C/W 2C #12 + BOND FOR POWER (CIRCUIT LNF-15)  
- 1 (ONE) CONDUIT C/W 2 (TWO) CAT6 DATA CABLES. CABLES TO CONNECT TO PATCH PANEL IN TRANSPORT CANADA RACK IN ROOM 221.  
- 1 (ONE) EMPTY CONDUIT TO MULTI-MEDIA OUTLET ON WALL.
  - 
  - DATA RACKS TO BE SUPPLIED AND INSTALLED BY SHARED SERVICES. PATCH PANELS AND ALL TERMINATIONS BY SHARED SERVICES.
  - DATA OUTLET FOR DEDICATED FIDS SYSTEM. THIS OUTLET WILL IS FOR FIDS NETWORK ONLY. FIDS SWITCH IS LOCATED IN DATA RACK IN ROOM 221.

**LEVEL 2 – POWER & SYSTEMS** 1  
SCALE : 1:125  
0m 1 2 3 4 5 6 7 8 9 10m

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

PROVINCE OF NEWBrunswick and Labrador  
PERMIT HOLDER CLASS "A"  
This Permit Allows  
WSP CANADA INC.  
Member in Responsible Charge  
CRAIG MACINTYRE, P.Eng. No. 0600  
To practice Professional Engineering in Newfoundland and Labrador.  
Permit No. as issued by PEOB, 10075  
which is valid for the year 2017.

PROFESSIONAL ENGINEER  
CRAIG MACINTYRE  
SINCE 1988  
MAR 30 2017  
NEWBRUNSWICK & LABRADOR

prime consultant:  
**ARCHITECTURE 49**



revisions	date
F	ISSUED FOR TENDER MAR 30 2017
E	ISSUED FOR 99% REVIEW FEB 10 2017
D	ISSUED FOR 66% REVIEW NOV 4 2016
C	ISSUED FOR 33% REVIEW AUG 5 2016
B	DESIGN DEVELOPMENT MAY 27 2016
A	DESIGN DEVELOPMENT APR 26 2016

project  
**WABUSH ATB RENOVATIONS**  
**WABUSH AIRPORT WABUSH, NL**

drawing  
**LEVEL 2 – POWER & SYSTEMS**

designed	C.MACINTYRE	conçu
date	MAY 2016	
drawn	M.KAMPHUIS	dessiné
date	MAY 2016	
approved	C.MACINTYRE	approuvé
date	MAY 2016	
Tender	2017/05/10	Soumission
PWGSC Project Manager	Administrateur de projets TPSCC	
project number	R.076412.001	no. du projet
drawing no.	E9	no. du dessin

