

## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 DEFINITIONS

- .1 For additional acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.
- .2 AEL: ratio between total test period less any system downtime accumulated within that period and test period.
- .3 Downtime: results whenever EMCS is unable to fulfill required functions due to malfunction of equipment defined under responsibility of EMCS contractor. Downtime is measured by duration, in time, between time that Contractor is notified of failure and time system is restored to proper operating condition. Downtime not to include following:
  - .1 Outage of main power supply in excess of back-up power sources, provided that:
    - .1 Automatic initiation of back-up was accomplished.
    - .2 Automatic shut-down and re-start of components was as specified.
  - .2 Failure of communications link, provided that:
    - .1 Controller automatically and correctly operated in stand-alone mode.
    - .2 Failure was not due to failure of any specified EMCS equipment.
  - .3 Functional failure resulting from individual sensor inputs or output devices, provided that:
    - .1 System recorded said fault.
    - .2 Equipment defaulted to fail-safe mode.
    - .3 AEL of total of all input sensors and output devices is at least 99% during test period.

### 1.3 DESIGN REQUIREMENTS

- .1 Confirm with PWGSC Representative that Design Criteria and Design Intents are still applicable.
- .2 Commissioning personnel to be fully aware of and qualified to interpret Design Criteria and Design Intents.

### 1.4 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Final Report: submit report to PWGSC Representative.
    - .1 Include measurements, final settings and certified test results.
-

- 
- .2 Bear signature of commissioning technician and supervisor
  - .3 Report format to be approved by PWGSC Representative before commissioning is started.
  - .4 Revise "as-built" documentation, commissioning reports to reflect changes, adjustments and modifications to EMCS as set during commissioning and submit to PWGSC Representative in accordance with Section 01 78 00 - Closeout Submittals.
  - .5 Recommend additional changes and/or modifications deemed advisable in order to improve performance, environmental conditions or energy consumption.

#### 1.5 CLOSEOUT SUBMITTALS

- .1 Provide documentation, O&M Manuals, electronic copy of finalized EMCS control hardware, and training of O&M personnel for review of PWGSC Representative before interim acceptance in accordance with Section 01 78 00 - Closeout Submittals.

#### 1.6 COMMISSIONING

- .1 Do commissioning in accordance with Section 01 91 13 - General Commissioning (CX) Requirements.
- .2 Carry out commissioning under direction of PWGSC Representative and in presence of PWGSC Representative.
- .3 Inform, and obtain approval from, PWGSC Representative in writing at least 14 days prior to commissioning or each test. Indicate:
  - .1 Location and part of system to be tested or commissioned.
  - .2 Testing/commissioning procedures, anticipated results.
  - .3 Names of testing/commissioning personnel.
- .4 Correct deficiencies, re-test in presence of PWGSC Representative until satisfactory performance is obtained.
- .5 Acceptance of tests will not relieve Contractor from responsibility for ensuring that complete systems meet every requirement of Contract.
- .6 Load system with project software.
- .7 Perform tests as required.

#### 1.7 COMPLETION OF COMMISSIONING

- .1 Commissioning to be considered as satisfactorily completed when objectives of commissioning have been achieved and reviewed by PWGSC Representative.
-

## 1.8 ISSUANCE OF FINAL CERTIFICATE OF COMPLETION

- .1 Final Certificate of Completion will not be issued until receipt of written approval indicating successful completion of specified commissioning activities including receipt of commissioning documentation.

## PART 2 - PRODUCTS

### 2.1 EQUIPMENT

- .1 Provide sufficient instrumentation to verify and commission the installed system. Provide two-way radios.
- .2 Instrumentation accuracy tolerances: higher order of magnitude than equipment or system being tested.
- .3 Independent testing laboratory to certify test equipment as accurate to within approved tolerances no more than 2 months prior to tests.
- .4 Locations to be approved, readily accessible and readable.
- .5 Application: to conform to normal industry standards.

## PART 3 - EXECUTION

### 3.1 PROCEDURES

- .1 Test each system independently and then in unison with other related systems.
  - .2 Commission each system using procedures prescribed by the Commissioning Manager.
  - .3 Commission integrated systems using procedures prescribed by Commissioning Manager.
  - .4 Debug system software.
  - .5 Optimize operation and performance of systems by fine-tuning PID values and modifying CDLs as required.
  - .6 Test full scale emergency evacuation and life safety procedures including operation and integrity of smoke management systems under normal and emergency power conditions as applicable.
-

---

### 3.2 FIELD QUALITY CONTROL

- .1 Pre-Installation Testing.
    - .1 General: consists of field tests of equipment just prior to installation.
    - .2 Testing may be on site or at Contractor's premises as approved by PWGSC Representative.
    - .3 Configure major components to be tested in same architecture as designed system. Include BECC equipment and 2 sets of Building Controllers including MCUs, LCUs, and TCUs.
    - .4 Equip each Building Controller with sensor and controlled device of each type (AI, AO, DI, DO).
    - .5 Additional instruments to include:
      - .1 DP transmitters.
      - .2 Supply duct SP transmitters.
      - .3 DP switches used for dirty filter indication and fan status.
    - .6 In addition to test equipment, provide inclined manometer, digital micro-manometer, milli-amp meter, source of air pressure infinitely adjustable between 0 and 500 Pa, to hold steady at any setting and with direct output to milli-amp meter at source.
    - .7 After setting, test zero and span in 10% increments through entire range while both increasing and decreasing pressure.
    - .8 PWGSC Representative to mark instruments tracking within 0.5% in both directions as "approved for installation".
    - .9 Transmitters above 0.5% error will be rejected.
    - .10 DP switches to open and close within 2% of setpoint.
  - .2 Completion Testing.
    - .1 General: test after installation of each part of system and after completion of mechanical and electrical hook-ups, to verify correct installation and functioning.
    - .2 Include following activities:
      - .1 Test and calibrate field hardware including stand-alone capability of each controller.
      - .2 Verify each A-to-D convertor.
      - .3 Test and calibrate each AI using calibrated digital instruments.
      - .4 Test each DI to ensure proper settings and switching contacts.
      - .5 Test each DO to ensure proper operation and lag time.
      - .6 Test each AO to ensure proper operation of controlled devices. Verify tight closure and signals.
      - .7 Test operating software.
      - .8 Test application software and provide samples of logs and commands.
      - .9 Verify each CDL including energy optimization programs.
      - .10 Debug software.
      - .11 Blowout flow measuring and static pressure stations with high pressure air at 700 kPa.
      - .12 Provide point verification list in table format including point identifier, point identifier expansion, point type and address, low and high limits
-

---

and engineering units. Include space on commissioning technician and PWGSC Representative. This document will be used in final startup testing.

- .3 Final Startup Testing: Upon satisfactory completion of tests, perform point-by-point test of entire system under direction of PWGSC Representative and provide:
    - .1 2 technical personnel capable of re-calibrating field hardware and modifying software.
    - .2 Detailed daily schedule showing items to be tested and personnel available.
    - .3 PWGSC Representative's acceptance signature to be on executive and applications programs.
    - .4 Commissioning to commence during final startup testing.
    - .5 O&M personnel to assist in commissioning procedures as part of training.
    - .6 Commissioning to be supervised by qualified supervisory personnel and PWGSC Representative.
    - .7 Commission systems considered as life safety systems before affected parts of the facility are occupied.
    - .8 Operate systems as long as necessary to commission entire project.
    - .9 Monitor progress and keep detailed records of activities and results.
  - .4 Final Operational Testing: to demonstrate that EMCS functions in accordance with contract requirements.
    - .1 Prior to beginning of 30 day test demonstrate that operating parameters (setpoints, alarm limits, operating control software, sequences of operation, trends, graphics and CDLs) have been implemented to ensure proper operation and operator notification in event of off-normal operation.
      - .1 Repetitive alarm conditions to be resolved to minimize reporting of nuisance conditions.
      - .2 Test to last at least 30 consecutive 24 hour days.
      - .3 Tests to include:
        - .1 Demonstration of correct operation of monitored and controlled points.
        - .2 Operation and capabilities of sequences, reports, special control algorithms, diagnostics, software.
      - .4 System will be accepted when:
        - .1 EMCS equipment operates to meet overall performance requirements. Downtime as defined in this Section must not exceed allowable time calculated for this site.
        - .2 Requirements of Contract have been met.
    - .5 In event of failure to attain specified AEL during test period, extend test period on day-to-day basis until specified AEL is attained for test period.
    - .6 Correct defects when they occur and before resuming tests.
  - .5 Commissioning Manager to verify reported results.
-

### 3.3 ADJUSTING

- .1 Final adjusting: upon completion of commissioning as reviewed by Commissioning Manager and PWGSC Representative, set and lock devices in final position and permanently mark settings.

### 3.4 DEMONSTRATION

- .1 Demonstrate to Commissioning Manager and PWGSC Representative operation of systems including sequence of operations in regular and emergency modes, under normal and emergency conditions, start-up, shut-down interlocks and lock-outs in accordance with Section 01 79 00 - Demonstration and Training.

END

---

## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 DEFINITIONS

- .1 CDL - Control Description Logic.
- .2 For additional acronyms and definitions refer to Section 25 5 01 - EMCS: General Requirements.

### 1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures, supplemented and modified by requirements of this Section.
- .2 Submit training proposal complete with hour-by-hour schedule including brief overview of content of each segment to PWGSC Representative 10 days prior to anticipated date of beginning of training.
  - .1 List name of trainer, and type of visual and audio aids to be used.
  - .2 Show coordinated interface with other EMCS mechanical and electrical training programs.
- .3 Submit reports within one week after completion of training program confirming that training has been satisfactorily completed.

### 1.4 QUALITY ASSURANCE

- .1 Provide competent instructors thoroughly familiar with aspects of EMCS installed in facility.
- .2 PWGSC Representative reserves right to approve instructors.

### 1.5 INSTRUCTIONS

- .1 Provide instruction to designated personnel in adjustment, operation, maintenance and pertinent safety requirements of EMCS installed.
  - .2 Training to be project-specific.
-

#### 1.6 TIME FOR INSTRUCTION

- .1 Number of days of instruction to be as specified in this section (1 day = 8 hours including two 15 minute breaks and excluding lunch time).

#### 1.7 TRAINING MATERIALS

- .1 Provide equipment, visual and audio aids, and materials for classroom training.
- .2 Supply manual for each trainee, describing in detail data included in each training program.
  - .1 Review contents of manual in detail to explain aspects of operation and maintenance (O&M).

#### 1.8 TRAINING PROGRAM

- .1 To be in two phases over 6 month period.
  - .2 Phase 1: One-day program to begin before 30 day test period at time mutually agreeable to Contractor, Departmental Representative, and Commissioning Manager.
    - .1 Train O&M personnel in functional operations and procedures to be employed for system operation.
    - .2 Supplement with on-the-job training during 30 day test period.
    - .3 Include overview of system architecture, communications, operation of computer and peripherals, report generation.
    - .4 Include detailed training on operator interface functions for control of mechanical systems, CDL's for each system, and elementary preventive maintenance.
  - .3 Phase 2: One day program to begin 8 weeks after acceptance for operators, equipment maintenance personnel and programmers.
    - .1 Provide multiple instructors on pre-arranged schedule. Include at least following:
      - .1 Operator training: provide operating personnel, maintenance personnel and programmers with condensed version of Phase 1 training.
      - .2 Equipment maintenance training: provide personnel with 1 day training within 5 day period in maintenance of EMCS equipment, including general equipment layout, trouble shooting and preventive maintenance of EMCS components, maintenance and calibration of sensors and controls.
      - .3 Programmers: provide personnel with 1 day training within 5 day period in following subjects in approximate percentages of total course shown: Software and architecture: 10% Application programs: 15% Controller programing: 50% Trouble shooting and debugging: 10% Colour graphic generation: 15%
-



1.9            ADDITIONAL TRAINING

- .1        List courses offered by name, duration and approximate cost per person per week. Note courses recommended for training supervisory personnel.

1.10           MONITORING OF TRAINING

- .1        Departmental Representative to monitor training program and may modify schedule and content.

PART 2 - PRODUCTS

2.1        NOT USED

- .1        Not Used.

PART 3 - EXECUTION

3.1        NOT USED

- .1        Not Used.

---

END

---

## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/The Instrumentation, Systems and Automation Society (ISA).
    - .1 ANSI/ISA 5.5-1985, Graphic Symbols for Process Displays.
  - .2 American National Standards Institute (ANSI)/ Institute of Electrical and Electronics Engineers (IEEE).
    - .1 ANSI/IEEE 260.1-2004, American National Standard Letter Symbols Units of Measurement (SI Units, Customary Inch-Pound Units, and Certain Other Units).
  - .3 American National Standards Institute / American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
    - .1 ANSI/ASHRAE 135-2012, BACNET - Data Communication Protocol for Building Automation and Control Network.
  - .4 Canadian Standards Association (CSA International).
    - .1 CAN/CSA-Z234.1-00(R2006), Canadian Metric Practice Guide.
  - .5 Consumer Electronics Association (CEA).
    - .1 CEA-709.1-B-2002, Control Network Protocol Specification.
  - .6 Department of Justice Canada (Jus).
    - .1 Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
    - .2 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
  - .7 Electrical and Electronic Manufacturers Association (EEMAC).
    - .1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
  - .8 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
    - .1 Material Safety Data Sheets (MSDS).
  - .9 Transport Canada (TC).
    - .1 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.
-

---

1.3 ACRONYMS AND ABBREVIATIONS

- .1 Acronyms and abbreviations used in EMCS:
    - .1 AEL - Average Effectiveness Level.
    - .2 AI - Analog Input.
    - .3 AIT - Agreement on International Trade.
    - .4 AO - Analog Output.
    - .5 BACnet - Building Automation and Control Network.
    - .6 BC(s) - Building Controller(s).
    - .7 BECC - Building Environmental Control Center.
    - .8 CAD - Computer Aided Design.
    - .9 CDL - Control Description Logic.
    - .10 CDS - Control Design Schematic.
    - .11 COSV - Change of State or Value.
    - .12 CPU - Central Processing Unit.
    - .13 DI - Digital Input.
    - .14 DO - Digital Output.
    - .15 DP - Differential Pressure.
    - .16 ECU - Equipment Control Unit.
    - .17 EMCS - Energy Monitoring and Control System.
    - .18 HVAC - Heating, Ventilation, Air Conditioning.
    - .19 IDE - Interface Device Equipment.
    - .20 I/O - Input/Output.
    - .21 ISA - Industry Standard Architecture.
    - .22 LAN - Local Area Network.
    - .23 LCU - Local Control Unit.
    - .24 MCU - Master Control Unit.
    - .25 NAFTA - North American Free Trade Agreement.
    - .26 NC - Normally Closed.
    - .27 NO - Normally Open.
    - .28 OS - Operating System.
    - .29 O&M - Operation and Maintenance.
    - .30 OWS - Operator Work Station.
    - .31 PC - Personal Computer.
    - .32 PCI - Peripheral Control Interface.
    - .33 PCMCIA - Personal Computer Micro-Card Interface Adapter.
    - .34 PID - Proportional, Integral and Derivative.
    - .35 RAM - Random Access Memory.
    - .36 SP - Static Pressure.
    - .37 ROM - Read Only Memory.
    - .38 TCU - Terminal Control Unit.
    - .39 USB - Universal Serial Bus.
    - .40 UPS - Uninterruptible Power Supply.
    - .41 VAV - Variable Air Volume.
    - .42 B-BC - BACnet Building Controller.
    - .43 B-AAC - BACnet Advances Application Controller.
-

- .44 B-ASC - BACnet Application Specific Controller.
- .45 B-BMD - BACnet Broadcast Management Device

#### 1.4 DEFINITIONS

- .1 Point: may be logical or physical.
  - .1 Logical points: values calculated by system such as setpoints, totals, counts, derived corrections and may include, but not limited to result of and statements in CDL's.
  - .2 Physical points: inputs or outputs which have hardware wired to controllers which are measuring physical properties, or providing status conditions of contacts or relays which provide interaction with related equipment(stop, start) and valve or damper actuators.
- .2 Point Name: composed of two parts, point identifier and point Expansion.
  - .1 Point identifier: comprised of three descriptors, "area" descriptor, "system" descriptor and "point" descriptor, for which database to provide 25 character field for each point identifier. "System" is system that point is located on.
    - .1 Area descriptor: building or part of building where point is located.
    - .2 System descriptor: system that point is located on.
    - .3 Point descriptor: physical or logical point description. For point identifier "area", "system" and "point" will be short forms or acronyms. Database must provide 25 character field for each point identifier.
  - .2 Point expansion : comprised of three fields, one for each descriptor. Expanded form of short form or acronym used in "area", "system" and "point" descriptors is placed into appropriate point expansion field. Database must provide 32 character field for each point expansion.
- .3 Point Object Type: points fall into following object types:
  - .1 AI (analog input).
  - .2 AO (analog output).
  - .3 DI (digital input).
  - .4 DO (digital output).
  - .5 Pulse inputs.
- .4 Symbols and engineering unit abbreviations utilized in displays: to ANSI/ISA S5.5.
  - .1 Printouts: to ANSI/IEEE 260.1.
  - .2 Refer also to Section 25 05 54 - EMCS: Identification.

#### 1.5 SYSTEM DESCRIPTION

- .1 Refer to control schematics for system architecture.

- .2 Expansion of existing EMCS system: Contractor to ensure expansion is compatible with existing Alerton EMCS system.
  - .3 Work covered by sections referred to above consists of fully operational EMCS, including, but not limited to, following:
    - .1 Building Controller.
    - .2 Control devices as listed in I/O point summary tables.
    - .3 OWS.
    - .4 Data communications equipment necessary to effect EMCS data transmission system.
    - .5 Field control devices.
    - .6 Software/Hardware complete with full documentation.
    - .7 Complete operating and maintenance manuals.
    - .8 Training of personnel.
    - .9 Acceptance tests, technical support during commissioning, full documentation.
    - .10 Wiring interface co-ordination of equipment supplied by others.
    - .11 Miscellaneous work as specified in these sections and as indicated.
  - .4 Design Requirements:
    - .1 Design and provide conduit and wiring linking elements of system.
    - .2 Supply sufficient programmable controllers of types to meet project requirements. Quantity and points contents as reviewed by PWGSC Representative prior to installation.
    - .3 Location of controllers as reviewed by PWGSC Representative prior to installation. Note that existing controllers located in the Mechanical Room will be reused.
    - .4 Provide utility power to EMCS and emergency power to EMCS as indicated.
    - .5 Metric references: in accordance with CAN/CSA Z234.1.
  - .5 Language Operating Requirements:
    - .1 Provide English operator selectable access codes.
    - .2 Use non-linguistic symbols for displays on graphic terminals wherever possible. Other information to be in English.
    - .3 Operating system executive: provide primary hardware-to-software interface specified as part of hardware purchase with associated documentation to be in English.
    - .4 System manager software: include in English system definition point database, additions, deletions or modifications, control loop statements, use of high level programming languages, report generator utility and other OS utilities used for maintaining optimal operating efficiency.
    - .5 Include, in English:
      - .1 Input and output commands and messages from operator-initiated functions and field related changes and alarms as defined in CDL's
-

- or assigned limits (i.e. commands relating to day-to-day operating functions and not related to system modifications, additions, or logic re-definitions).
- .2 Graphic "display" functions, point commands to turn systems on or off, manually override automatic control of specified hardware points. To be in English at specified OWS and to be able to operate one terminal in English.
- .3 Reporting function such as trend log, trend graphics, alarm report logs, energy report logs, maintenance generated logs.

#### 1.6 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit for review:
  - .1 Equipment list and systems manufacturers within 10 days after award of contract.
  - .2 Complete control schematics with corresponding sequences of operation.
- .3 Quality Control:
  - .1 Provide equipment and material from manufacturer's regular production, CSA certified, manufactured to standard quoted plus additional specified requirements.
  - .2 Where CSA certified equipment is not available submit such equipment to inspection authorities for special inspection and approval before delivery to site.
  - .3 Submit proof of compliance to specified standards with shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures. Label or listing of specified organization is acceptable evidence.
  - .4 In lieu of such evidence, submit certificate from testing organization, approved by PWGSC Representative, certifying that item was tested in accordance with their test methods and that item conforms to their standard/code.
  - .5 For materials whose compliance with organizational standards/codes/specifications is not regulated by organization using its own listing or label as proof of compliance, furnish certificate stating that material complies with applicable referenced standard or specification.
  - .6 Permits and fees: in accordance with general conditions of contract.
  - .7 Submit certificate of acceptance from authority having jurisdiction to PWGSC Representative.

#### 1.7 QUALITY ASSURANCE

- .1 Have local office within 300 km of project staffed by trained personnel capable of

providing instruction, routine maintenance and emergency service on systems.

- .2 Provide record of successful previous installations submitting tender showing experience with similar installations utilizing computer-based systems.
- .3 Have access to local supplies of essential parts and provide 7 year guarantee of availability of spare parts after obsolescence.
- .4 Ensure qualified supervisory personnel continuously direct and monitor Work and attend site meetings.

#### 1.8 WASTE MANAGEMENT AND DISPOSAL

- .1 Waste management and disposal to be in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

### PART 2 - PRODUCTS

#### 2.1 EQUIPMENT

- .1 Control Network Protocol and Data Communication Protocol: to CEA 709.1 ASHRAE STD 135.
- .2 Complete list of equipment and materials to be used on project and forming part of bid tender documents by adding manufacturer's name, model number and details of materials, and submit for approval.

#### 2.2 ADAPTORS

- .1 Provide adaptors between metric and imperial components as required.

### PART 3 - EXECUTION

#### 3.1 MANUFACTURERS' RECOMMENDATIONS

---

- .1 Installation: to manufacturers' recommendations.

### 3.2 PAINTING

- .1 Painting: in accordance with Section 09 91 23 - Painting, supplemented as follows:
  - .1 Clean and touch up marred or scratched surfaces of factory finished equipment to match original finish.
  - .2 Restore to new condition, finished surfaces too extensively damaged to be primed and touched up to make good.
  - .3 Paint unfinished equipment installed indoors.

### 3.3 FIELD QUALITY CONTROL

- .1 Verification requirements include:
  - .1 Materials and resources.
  - .2 Storage and collection of recyclables.
  - .3 Construction waste management.
  - .4 Resource reuse.
  - .5 Recycled content.
  - .6 Local/regional materials.
  - .7 Certified Wood.
  - .8 Low-emitting materials.

END

---



## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
  - .1 CSA C22.1-09, The Canadian Electrical Code, Part I (21<sup>st</sup> Edition), Safety Standard for Electrical Installations.

### 1.3 DEFINITIONS

- .1 For acronyms and definitions refer to Section 25 05 01 – EMCS: General Requirements.

### 1.4 SYSTEM DESCRIPTION

- .1 Language Operating Requirements: provide identification for control items in English.

### 1.5 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures, supplemented and modified by requirements of this Section.
- .2 Submit to PWGSC Representative for approval samples of nameplates, identification tags and list of proposed wording.

## PART 2 – PRODUCTS

### 2.1 NAMEPLATES FOR PANELS

- .1 Identify by 3 mm thick melamine, matt white finish, black core, square corners, lettering accurately aligned and engraved into core.
  - .2 Sizes: as required.
  - .3 Lettering: minimum 7 mm high, black.
  - .4 Inscriptions: machine engraved to identify function.
-

## 2.2 NAMEPLATES FOR FIELD DEVICES

- .1 Identify by plastic encased cards attached by chain or plastic tie.
- .2 Sizes: 50 x 100 mm minimum.
- .3 Lettering: minimum 5 mm high produced from laser printer in black.
- .4 Data to include: point name and point address.
- .5 Companion cabinet: identify interior components using plastic enclosed cards with point name and point address.

## 2.3 NAMEPLATES FOR ROOM SENSORS

- .1 Identify by stick-on labels using point identifier.
- .2 Location: as directed by PWGSC Representative.
- .3 Letter size: to suit, clearly legible.

## 2.4 WARNING SIGNS

- .1 Equipment including motors, starters under remote automatic control: supply and install orange coloured signs warning of automatic starting under control of EMCS.
- .2 Sign to read: "Caution: This equipment is under automatic remote control of EMCS".

## 2.5 WIRING

- .1 Supply and install numbered tape markings on wiring at panels, junction boxes, splitters, cabinets and outlet boxes.
- .2 Colour coding: to CSA C22.1. Use colour coded wiring in communications cables, matched throughout system.
- .3 Power wiring: identify circuit breaker panel/circuit breaker number inside each EMCS panel.

## 2.6 CONDUIT

- .1 Colour code all EMCS conduit.
-

- .2 Pre-paint box inside and outside plus covers and fittings.
- .3 Colour to be red and white.

### PART 3 - EXECUTION

#### 3.1 NAMEPLATES AND LABELS

- .1 Ensure that manufacturer's nameplates, CSA labels and identification nameplates are visible and legible at all times.
- .2 Electrical and Controls Equipment Identification
  - .1 Electrically fed equipment supplied by Division 21-28 (excluding that noted in .2 and .3, below) shall be identified as per Division 26 identification requirements.
  - .2 Intermediate and end control devices including sensor, controllers, monitoring devices etc. shall be identified with laminated plastic plates or white polyolefin tags as noted for system nameplates above. The plates shall be fastened securely with pop rivets or screws. Where rivets or screws are not feasible, provide heavy duty plastic tie wraps. As a minimum, control device identification shall correspond to descriptors provided in the approved shop drawings with respect to panel designation or DDC point name.
  - .3 Control devices located concealed by ceilings shall also be provided with a second identical plate installed on the underside of the ceiling grid or access door opening frame, as close as possible to the location of the device.

END

---

## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 REFERENCES

- .1 Canada Standards Association (CSA International).
  - .1 CSA Z204-94(R1999), Guidelines for Managing Indoor Air Quality in Office Buildings.

### 1.3 DEFINITIONS

- .1 BC(s) - Building Controller(s).
- .2 OWS - Operator Work Station.
- .3 For additional acronyms and definitions refer to Section 25 5 01 - EMCS: General Requirements.

### 1.4 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Submit detailed preventative maintenance schedule for system components to PWGSC Representative.
  - .3 Submit detailed inspection reports to Departmental Representative.
  - .4 Submit dated, maintenance task lists to PWGSC Representative and include the following sensor and output point detail, as proof of system verification:
    - .1 Point name and location.
    - .2 Device type and range.
    - .3 Measured value.
    - .4 System displayed value.
    - .5 Calibration detail
    - .6 Indication if adjustment required,
    - .7 Other action taken or recommended.
  - .5 Submit network analysis report showing results with detailed recommendations to correct problems found.
  - .6 Records and logs: in accordance with Section 01 78 00 - Closeout Submittals.
-

- .1 Maintain records and logs of each maintenance task on site.
- .2 Organize cumulative records for each major component and for entire EMCS chronologically.
- .3 Submit records to Departmental Representative, after inspection indicating that planned and systematic maintenance have been accomplished.
- .7 Revise and submit to PWGSC Representative in accordance with Section 01 78 00 - Closeout Submittals "As-built drawings" documentation and commissioning reports to reflect changes, adjustments and modifications to EMCS made during warranty period.

---

#### 1.5 MAINTENANCE SERVICE DURING WARRANTY PERIOD

- .1 Provide services, materials, and equipment to maintain EMCS for specified warranty period. Provide detailed preventative maintenance schedule for system components as described in Submittal article.
  - .2 Emergency Service Calls:
    - .1 Initiate service calls when EMCS is not functioning correctly.
    - .2 Qualified control personnel to be available during warranty period to provide service to "CRITICAL" components whenever required at no extra cost.
    - .3 Furnish Departmental Representative with telephone number where service personnel may be reached at any time.
    - .4 Service personnel to be on site ready to service EMCS within 48 hours after receiving request for service.
    - .5 Perform Work continuously until EMCS restored to reliable operating condition.
  - .3 Operation: foregoing and other servicing to provide proper sequencing of equipment and satisfactory operation of EMCS based on original design conditions and as recommended by manufacturer.
  - .4 Work requests: record each service call request, when received separately on approved form and include:
    - .1 Serial number identifying component involved.
    - .2 Location, date and time call received.
    - .3 Nature of trouble.
    - .4 Names of personnel assigned.
    - .5 Instructions of work to be done.
    - .6 Amount and nature of materials used.
    - .7 Time and date work started.
    - .8 Time and date of completion.
-

- .5 Provide system modifications in writing.
  - .1 No system modification, including operating parameters and control settings, to be made without prior written approval of PWGSC Representative.

#### 1.6 SERVICE CONTRACTS

- .1 Provide in-depth technical expertise and assistance to Departmental Representative and Commissioning Manager in preparation and implementation of service contracts and in-house preventive maintenance procedures.
- .2 Service Contracts to include:
  - .1 Annual verification of field points for operation and calibration.
  - .2 4 visits per year.
  - .3 4 responses to emergency calls during day, per year.
  - .4 Complete inventory of installed system.

#### PART 2 - PRODUCTS

##### 2.1 NOT USED

- .1 Not Used.
-

### PART 3 - EXECUTION

#### 3.1 FIELD QUALITY CONTROL

- .1 Perform as minimum (3) three minor inspections and one major inspection (more often if required by manufacturer) per year during warranty period. Provide detailed written report to Departmental Representative as described in Submittal article.
  - .2 Perform inspections during regular working hours, 0800 to 1630 h, Monday through Friday, excluding statutory holidays.
  - .3 Following inspections are minimum requirements and should not be interpreted to mean satisfactory performance:
    - .1 Perform calibrations using test equipment having traceable, certifiable accuracy at minimum 50% greater than accuracy of system displaying or logging value.
    - .2 Check and calibrate each field input/output device in accordance with CSA Z204.
    - .3 Provide dated, maintenance task lists, as described in Submittal article, as proof of execution of complete system verification.
  - .4 Minor inspections to include, but not limited to:
    - .1 Perform visual, operational checks to BC's, peripheral equipment, interface equipment and other panels.
    - .2 Check equipment cooling fans as required.
    - .3 Visually check for mechanical faults, air leaks and proper pressure settings on pneumatic components.
    - .4 Review system performance with Departmental Representative to discuss suggested or required changes.
  - .5 Major inspections to include, but not limited to:
    - .1 Minor inspection.
    - .2 Clean OWS(s) peripheral equipment, BC(s), interface and other panels, by micro-processor interior and exterior surfaces.
    - .3 Check signal, voltage and system isolation of BC(s), peripherals, interface and other panels.
    - .4 Verify calibration/accuracy of each input and output device and recalibrate or replace as required.
    - .5 Provide mechanical adjustments, and necessary maintenance on printers.
    - .6 Run system software diagnostics as required.
    - .7 Install software and firmware enhancements to ensure components are operating at most current revision for maximum capability and reliability.
      - .1 Perform network analysis and provide report as described in Submittal article.
-

- .6 Rectify deficiencies revealed by maintenance inspections and environmental checks.
- .7 Continue system debugging and optimization.
- .8 Testing/verification of occupancy and seasonal-sensitive systems to take place during four (4) consecutive seasons, after facility has been accepted, taken over and fully occupied.
  - .1 Test weather-sensitive systems twice: first at near winter design conditions and secondly under near summer design conditions.

END

---



## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
    - .1 CSA T530-99(R2004), Commercial Building Standard for Telecommunications Pathways and Spaces (Adopted ANSI/TIA/EIA-569-A with modifications).
    - .2 CSA T568.1-4-05, Commercial Building Telecommunications Cabling Standard - Part 1: General Requirements - Addendum 4 - Recognition of Category 6 and 850 nm Laser-Optimized 50/125 um Multimode Optical Fiber Cabling.
  - .2 Institute of Electrical and Electronics Engineers (IEEE)/Standard for Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements.
    - .1 IEEE 802.3-2008, IEEE Standard for Information technology--Telecommunications and information exchange between systems—Local and metropolitan area networks--Specific requirements Part 3: Carrier Sense Multiple Access with Collision Detection (CSMA/CD) Access Method and Physical Layer Specifications - Section Three .
  - .3 Telecommunications Industries Association (TIA)/Electronic Industries Alliance (EIA)
    - .1 TIA/EIA-568-B SET - March 2008, Commercial Building Telecommunications Cabling Standards Parts 1, 2, 3 Complete
    - .2 TIA/EIA-569-A-December 2001, Commercial Building Standard for Telecommunications Pathways and Spaces.
  - .4 Treasury Board Information Technology Standard (TBITS).
    - .1 TBITS 6.9-2000, Profile for the Telecommunications Wiring System in Government Owned and Leased Buildings – Technical Specifications.
-

---

### 1.3 DEFINITIONS

- .1 Acronyms and definitions: refer to Section 25 05 01 - EMCS - General Requirements.

### 1.4 SYSTEM DESCRIPTION

- .1 Data communication network to link Operator Workstations and Master Control Units (MCU) in accordance with CSA 568.1-4, CSA T530, TIA/EIA-569-A and TBITS 6.9.
  - .1 Provide reliable and secure connectivity of adequate performance between different sections (segments) of network.
  - .2 Allow for future expansion of network, with selection of networking technology and communication protocols.
- .2 Data communication network to include, but not limited to:
  - .1 EMCS-LAN.
  - .2 Modems.
  - .3 Network interface cards.
  - .4 Network management hardware and software.
  - .5 Network components necessary for complete network.

### 1.5 DESIGN REQUIREMENTS

- .1 EMCS Local Area Network (EMCS-LAN).
    - .1 High speed, high performance, local area network over which MCUs and OWSs communicate with each other directly on peer to peer basis in accordance with IEEE 802.3/Ethernet Standard.
    - .2 EMCS-LAN to: BACnet.
    - .3 Each EMCS-LAN to be capable of supporting at least 50 devices.
    - .4 Support of combination of MCUs and OWSs directly connected to EMCS-LAN.
    - .5 High speed data transfer rates for alarm reporting, quick report generation from multiple controllers, upload/download information between network devices. Bit rate to be 10 Megabits per second minimum.
  - .2 ECMS-LAN: (Cont'd)
    - .6 Detection and accommodation of single or multiple failures of either OWSs, MCUs or network media. Operational equipment to continue to perform designated functions effectively in event of single or multiple failures.
    - .7 Commonly available, multiple sourced, networking components and protocols to allow system to co-exist with other networking applications including office automation.
  - .3 Dynamic Data Access:
    - .1 LAN to provide capabilities for OWSs, either network resident or connected remotely, to access point status and application report data or execute control functions for other devices via LAN.
    - .2 Access to data to be based upon logical identification of building equipment.
-

- .4 Network Medium:
  - .1 Network medium: shielded twisted cable, or fibre optic cable compatible with network protocol to be used within buildings.

## PART 2 - PRODUCTS

### 2.1 NOT USED

- .1 Not Used.

## PART 3 - EXECUTION

### 3.1 NOT USED

- .1 Not Used.

END

---

## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements. Sections
- .2 Section 25 05 01 - EMCS: General Requirements.

### 1.2 SUMMARY

- .1 Section Includes:
  - .1 Hardware and software requirements for an Operator Work Station (OWS) in a Building Energy Monitoring and Control System (EMCS), including primary, secondary, portable and remote OWSs.

### 1.3 DEFINITIONS

- .1 Acronyms and definitions: refer to Section 25 05 01 - EMCS: General Requirements.
- .2 Portable OWS: used as remote dial-up OWS with same capabilities as primary OWS including graphic display.
- .3 Remote Auxiliary OWS: performs identical user interface functions as primary OWS.

### 1.4 OWS SYSTEM DESCRIPTION

- .1 Consists of commercially available personal computer in current production, with sufficient memory and processor capacity to perform functions specified.
- .2 Primary OWS to include:
  - .1 Report printer.
  - .2 Colour graphics printer.

### 1.5 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00 - Submittal Procedures.

### 1.6 ENVIRONMENTAL CONDITIONS

- .1 OWS to operate in conditions of 10 degrees C Conditions to 32 degrees C and 20% to 90% non-condensing RH.
-

## PART 2 - PRODUCTS

### 2.1 OWS HARDWARE

- .1 PC system to include:
  - .1 Processor: Pentium IV micro-processor, operating at minimum clock speed of 2 Gigahertz, capable of supporting software necessary to perform functions specified in this section. System backplane bus (100 Megahertz) to support PCI and ISA boards.
  - .2 Internal clock.
    - .1 Uninterruptible clock: accuracy of plus or minus 5 seconds/month, capable of deriving year / month / day / hour / minute / second.
    - .2 Rechargeable batteries: to provide minimum 48 h clock operation in event of power failure.
    - .3 Asynchronous interfaces for connection to listed peripheral devices including LAN and remote devices.
- .2 Power supply unit to accept 120 V 60 Hz source and include line surge and low voltage protection for processor and its peripherals.
- .3 Include UPS to provide 5 minutes minimum operation of PC, CRT and communication and peripheral devices; applies to fixed (non-portable) OWS and peripherals.

### 2.2 OWS PC COMPONENTS

- .1 Primary OWS: IBM PC compatible with following Components as minimum:
  - .1 IDE Disk drive controller to support 4 drives.
    - .1 1 20 GB hard disk drive, 12 ms.
    - .2 1 48X/24X/48X CD-RW drive.
  - .2 512 MB RAM minimum.
  - .3 Enhanced 101 key keyboard.
  - .4 PS2 mouse.
  - .5 Colour monitor: 17". Flat panel display TFT, resolution 1280 X 1040, dot pitch 0.26 mm, colour support 24 bit,
  - .6 Video card with 32 MB video RAM.
  - .7 2 Parallel Ports to support printers.
  - .8 2 USB ports or 2 serial ports.
  - .9 Internal Modem - 56 k.
  - .10 PCI Ethernet LAN Adapter to connect to local Ethernet LAN network.
  - .11 200 W minimum power supply.

### 2.3 PRINTERS

- .1 Report printer: Include following features:
    - .1 Laser printer.
    - .2 Accommodate 8.5" X 11" and 8.5" X 14" paper.
    - .3 Minimum 1200 by 1200 dpi resolution.
    - .4 Minimum 16 MB RAM, expandable to minimum 72 MB RAM.
-

- .5 Minimum 18 pages per minute print speed.

## 2.4 OPERATING SYSTEM (OS) OR EXECUTIVE

- .1 OS to support complement of hardware terminals and software programs specified.
- .2 OS to be true multi-tasking operating environment.
  - .1 MS DOS or PC DOS based software platforms not permitted.
- .3 OWS software to operate in "Windows" based operating environment: Windows 2000, XP or Unix "X" Windows based system.

## 2.5 OWS CONTROL SOFTWARE

- .1 Provide two licensed copies of control system application software. Control system application software is to be full B-OWS operator workstation.
  - .2 OWS is not to form part of real-time control functions either directly or indirectly or as part of communication link. Real-time control functions to reside in MCUs, LCUs, and TCUs with peer to peer communication occurring at MCU to MCU device level.
  - .3 Time Synchronization Module.
    - .1 System to provide Time Synchronization of real-time clocks in controllers.
    - .2 System to perform this feature on regular scheduled basis and on operator request.
  - .4 User Display Interface Module.
    - .1 OWS software to support "Point Names" as defined in Section 25 05 01 - EMCS: General Requirements.
    - .2 Upon operator's request in either text, graphic or table mode, system to present condition of single point, system, area, or connected points on system to OWS. Display analog values digitally to 1 place of decimal with negative sign as required. Update displayed analog values and status when new values received. Flag points in alarm by blinking, reverse video, different colour, bracketed or other means to differentiate from points not in alarm. For systems supporting COSV, refresh rate of screen data not to exceed 5 seconds from time of field change and system is to execute supervisory background scan every 20 seconds to verify point data value. For other systems refresh rate not to exceed 5 seconds for points displayed. Initial display of new system graphic display (with up to 30 active points), including presentation of associated dynamic data not to exceed 8 seconds.
  - .5 General Event Log Module: to record system activities occurring at OWS or elsewhere in system including:
    - .1 Operator Log-in from user interface device.
    - .2 Communication messages: errors, failures and recovery.
    - .3 Event notifications and alarms by category.
    - .4 Record of operator initiated commands.
-

- .6 General Event Log:
    - .1 Hold minimum of 4 months information and be readily accessible to operator.
    - .2 Able to be archived as necessary to prevent loss of information.
  
  - .7 Operator Control Software Module: to support entry of information into system from keyboard and mouse, disk, or from another network device. Display of information to user; dynamic displays, textual displays, and graphic displays to display logging and trending of system information and following tasks:
    - .1 Automatic logging of digital alarms and change of status messages.
    - .2 Automatic logging of analog alarms.
    - .3 System changes: alarm limits, set-points, alarm lockouts.
    - .4 Display specific point values, states as selected.
    - .5 Provide reports as requested and on scheduled basis when required.
    - .6 Display graphics as requested, and on alarm receptions (user's option).
    - .7 Display list of points within system.
    - .8 Display list of systems within building.
    - .9 Direct output of information to selected peripheral device.
    - .10 On-line changes:
      - .1 Alarm limits.
      - .2 Setpoints.
      - .3 Deadbands.
      - .4 Control and change of state changes.
      - .5 Time, day, month, year.
      - .6 Control loop configuration changes for controller-based CDLs.
      - .7 Control loop tuning changes.
      - .8 Schedule changes.
      - .9 Changes, additions, or deletions, of points, graphics, for installed and future systems.
    - .11 According to assigned user privileges (password definition) following functions are to be supported:
      - .1 Permit operator to terminate automatic (logic based) control and set value of field point to operator selected value. These values or settings to remain in effect until returned to automatic (logic based) control by operator.
      - .2 Requests for status, analog values, graphic displays, logs and controls to be through user interface screens.
    - .12 Software and tools utilized to generate, modify and configure building controllers to be installed and operational on the OWS.
  
  - .8 Dial-up host Module for off-site OWSs.
    - .1 Operators at dial-up OWS to be able to perform control functions, report functions, data base generation and modification functions as described for OWSs connected via LAN. Provide routines to automatically answer calls and either file or display information sent from remote panels.
    - .2 Operator to be able to access remote buildings by selection of facility by its logical name. Dial-up module to maintain user-definable cross-reference of buildings and associated telephone numbers without manual dialing.
    - .3 Local OWS may serve as dial-up host for remotely connecting OWSs, remote controllers or networks. Alarms and data file transfers handled via dial-up
-

transactions must not interfere with local LAN activity. LAN activity not to prevent work-station from handling incoming calls.

- .9 Message Handling Module - and Error Messages: to provide message handling for following conditions:
  - .1 Message and alarm buffering to prevent loss of information.
  - .2 Error detection correction and retransmission to guarantee data integrity.
  - .3 Informative messages to operator for data error occurrences, errors in keyboard entry, failure of equipment to respond to requests or commands and failure of communications between EMCS devices.
- .10 Access Control Module.
  - .1 Minimum 5 levels of password access protection to limit control, display, or data base manipulation capabilities. Following is preferred format of progression of password levels:
    - .1 Guest: no password data access and display only.
    - .2 Operator Level: full operational commands including automatic override.
    - .3 Technician: data base modifications.
    - .4 Programmer: data base generation.
    - .5 Highest Level : system administration - password assignment addition, modification.
  - .2 User-definable, automatic log-off timers from 1 to 60 min. to prevent operators leaving devices on-line inadvertently. Default setting = 3 minutes.
- .11 Trend Data Module: includes historical data collection utility, trend data utility, control loop plot utility. Each utility to permit operator to add trend point, delete trend point, set scan rate.
  - .1 Historical data collection utility: collect concurrently operator selected real or calculated point values at operator selectable rate 30-480 minutes. Samples to include for each time interval (time-stamped), minimum present value, maximum present value, and average present value for point selected. Rate to be individually selectable for each point. Data collection to be continuous operation, stored in temporary storage until removed from historical data list by operator. Temporary storage to have at least 6 month capacity.
  - .2 Trend data utility: continuously collect point object data variables for variables from building controllers as selected by operator, including at minimum; present value of following point object types - DI, DO, AI, AO set points value, calculated values. Trend data utility to have capacity to trend concurrently points at operator-selectable rate of 05 seconds to 3600 seconds, individually selectable for selected value, or use of COSV detection. Collected trend data to be stored on minimum 96 h basis in temporary storage until removed from trend data list by operator. Option to archive data before overwriting to be available.
  - .3 Control loop plot utility: for AO Points provide for concurrent plotting of Measured value input - present value, present value of output, and AO setpoint. Operator selectable sampling interval to be selectable between 1 second to 20 seconds. Plotting utility to scroll to left as plot reaches right side of display window. Systems not supporting control loop plot as separate function must provide predefined groups



- 
- of values. Each group to include values for one control loop display.
  - .4 Trend data Module to include display of historical or trend data to OWS screen in X Y plot presentation. Plot utility to display minimum of 6 historical points or 6 trend points concurrently or 1 Control Loop Plot. For display output of real time trend data, display to automatically index to left when window becomes full. Provide plotting capabilities to display collected data based on range of selected value for (Y) component against time/date stamp of collected data for (X) component.
  - .5 Provide separate reports for each trend utility. Provide operator feature to specify report type, by point name and for output device. Reports to include time, day, month, year, report title, and operator's initials. Implement reports using report module. Ensure trend data is exportable to third party spreadsheet or database applications for PCs.
  - .12 Report Module: reports for energy management programs, function totalization, analog/pulse totalization and event totalization features available at MCU level. Refer also to Section 25 30 01 - EMCS: Building Controllers.
    - .1 Reports to include time, day, month, year, report title, operator's initials.
    - .2 Software to provide capability to:
      - .1 Generate and format reports for graphical and numerical display from real time and stored data.
      - .2 Print and store reports as selected by operator.
      - .3 Select and assign points used in such reports.
      - .4 Sort output by area, system, as minimum.
    - .3 Periodic/automatic report:
      - .1 Generate specified report(s) automatically including options of start time and date, interval between reports (hourly, daily, weekly, monthly), output device. Software to permit modifying periodic/automatic reporting profile at any time.
      - .2 Reports to include:
        - .1 Power demand and duty cycle summary: see application program for same.
        - .2 Disabled "Locked-out" point summary: include point name, whether disabled by system or by operator.
        - .3 Run time summary: summary of accumulated running time of selected equipment. Include point name, run time to date, alarm limit setting. Run time to accumulate until reset individually by operator.
        - .4 Summary of run time alarms: include point name, run time to date, alarm limit.
        - .5 Summary of start/stop schedules: include start/stop times and days, point name.
        - .6 Motor status summary.
    - .4 Report types:
      - .1 Dynamic reports: system to printout or display of point object data value requested by operator. System to indicate status at time of request, when displayed, updated at operator selected time interval. Provide option for operator selection of report type, by point name, and/or output device. Ensure reports are available for following point value combinations:
-

- 
- .2 Points in accessible from this OWS total connected for this location), multiple "areas".
    - .3 Area (points and systems in Area).
    - .4 Area, system (points in system).
    - .5 System (points by system type).
    - .6 System point (points by system and point object type).
    - .7 Area point (points by system and point object type).
    - .8 Point (points by point object type).
  - .5 Summary report: printout or display of point object data value selected by operator. Report header to indicate status at time of request. Ensure reports are available on same basis as dynamic reports. Provide option as to report type, point name, output device.
  - .6 Include preformatted reports as listed in Event/Alarm Module.
- .13 Graphics Display Module: graphics software utility to permit user to create, modify, delete, file, and recall graphics required by Section 25 90 01 - EMCS: Site Requirements, Applications and Systems Sequences of Operation.
- .1 Provide capacity for 100% expansion of system graphics. Graphic interface to provide user with multiple layered diagrams for site, building in plan view, floor furniture plan view and building systems, overlaid with dynamic data appropriately placed and permitting direct operator interaction. Graphic interface to permit operator to start and stop equipment, change set points, modify alarm limits, override system functions and points from graphic system displays by use of mouse or similar pointing device.
  - .2 Display specific system graphics: provide for manual and/or automatic activation (on occurrence of an alarm). Include capability to call up and cancel display of graphic picture.
  - .3 Library of pre-engineered screens and symbols depicting standard air handling components (fans, coils, filters, dampers), complete mechanical system components (boilers, pumps), electrical symbols.
  - .4 Graphic development, creation, modification package to use mouse and drawing utility to permit user to:
    - .1 Modify portion of graphic picture/schematic background.
    - .2 Delete graphic picture.
    - .3 Call up and cancel display of graphic picture.
    - .4 Define symbols.
    - .5 Position and size symbols.
    - .6 Define background screens.
    - .7 Define connecting lines, curves.
    - .8 Locate, orient, size descriptive text.
    - .9 Define, display colours of elements.
    - .10 Establish co-relation between symbols or text and associated system points or other graphic displays.
  - .5 User to be able to build graphic displays showing on-line point data from multiple MCU panels. Graphic displays to represent logical grouping of system points or calculated data based upon building function, mechanical system, building layout, other logical grouping of points which aids operator in analysis of facility operation. Data to be refreshed on screen as "changed data" without redrawing of entire screen or row on screen.
  - .6 Dynamic data (temperature, humidity, flow, status) to be shown in actual
-

- 
- schematic locations, to be automatically updated to show current values without operator intervention.
- .7 Windowing environment to allow user to view several graphics simultaneously to permit analysis of building operation, system performance, display of graphic associated with alarm to be viewed without interrupting work in progress. If interface is unable to display several different types of display at same time, provide at minimum 2 OWSs.
  - .8 Utilize graphics package to generate system schematic diagrams as required in Section 25 90 01 - EMCS: Site requirements, Applications and System Sequences of Operation, and as directed by PWGSC Representative. In addition provide graphics for schematic depicted on mechanical plan flow diagrams, point lists and system graphics. Provide graphic for floor depicting room sensors and control devices located in their actual location. Diagram to be single line schematic of ductwork as well as associated heating coil or radiation valve. PWGSC Representative to provide CAD floor layouts. Provide display of TCU - VAVs in table form, include following values as minimum; space temp, setpoint, mode, actual flow, min flow setpoint, max flow setpoint, cooling signal value, and heating signal value. Organize table by rooms and floor groupings.
  - .9 Provide complete directory of system graphics, including other pertinent system information. Utilize mouse or pointing device to "point and click" to activate selected graphic.
  - .10 Provide unique sequence of operation graphic or pop-up window for each graphic that is depicted on OWS. Provide access to sequence of operation graphic by link button on each system graphic. Provide translation of sequence of operation, a concise explanation of systems operation, from control descriptive logic into plain English language.
- .14 Event/Alarm Module: displays in window alarms as received and stored in General Event Log.
- .1 Classify alarms as "critical", "cautionary", "maintenance". Alarms and alarm classifications to be designated by personnel requiring password level.
  - .2 Presentation of alarms to include features identified under applicable report definitions of Report Module paragraph.
  - .3 Alarm reports.
    - .1 Summary of points in critical, cautionary or maintenance alarm. Include at least point name, alarm type, current value, limit exceeded.
    - .2 Analog alarm limit summary: include point name, alarm limits, deviation limits.
    - .3 Summary of alarm messages: include associated point name, alarm description.
  - .4 Software to notify operator of each occurrence of alarm conditions. Each point to have its own secondary alarm message.
  - .5 EMCS to notify operator of occurrence of alarms originating at field device within following time periods of detection:
    - .1 Critical - 5 seconds.
    - .2 Cautionary - 10 seconds.
    - .3 Maintenance - 10 seconds.
  - .6 Display alarm messages in English.
  - .7 Primary alarm message to include as minimum: point identifier, alarm
-

- 
- classification, time of occurrence, type of alarm. Provide for initial message to be automatically presented to operator whenever associated alarm is reported.  
Assignment of secondary messages to point to be operator-editable function.  
Provide secondary messages giving further information (telephone lists, maintenance functions) on per point basis.
- .8 System reaction to alarms: provide alarm annunciation by dedicated window (activated to foreground on receipt of new alarm or event) of OWS with visual and audible hardware indication. Acknowledgement of alarm to change visual indicator from flashing to steady state and to silence audible device.  
Acknowledgment of alarm to be time, date and operator stamped and stored in General Event Log. Steady state visual indicator to remain until alarm condition is corrected but must not impede reporting of new alarm conditions. Notification of alarm not to impede notification of subsequent alarms or function of controllers/CDL. Do not allow random occurrence of alarms to cause loss of alarm or over-burden system. Do not allow acknowledgment of one alarm as acknowledgement of other alarms.
- .9 Controller network alarms: system supervision of controllers and communications lines to provide following alarms as minimum:
- .1 Controller not responding – where possible delineate between controller and communication line failure.
  - .2 Controller responding - return to normal.
  - .3 Controller communications bad - high error rate or loss of communication.
  - .4 Controller communications normal - return to normal.
- .10 Digital alarm status to be interrogated every 2 seconds as minimum or be direct interrupting non-polling type (COV). Annunciate each non-expected status with alarm message.
- .15 Archiving and Restoration Module.
- .1 Primary OWS to include services to store back-up copies of controller databases. Perform complete backup of OWS software and data files at time of system installation and at time of final acceptance. Provide backup copies before and after Controller's revisions or major modifications.
  - .2 Provide continuous integrity supervision of controller data bases. When controller encounters database integrity problems with its data base, system to notify operator of need to download copy data base to restore proper operation.
  - .3 Ensure data base back-up and downloading occurs over LAN without specialized operator technical knowledge. Provide operator with ability to manually download entire controller data base, or parts thereof as required.
- .16 CDL Generator and Modifier Module.
- .1 CDL Generator module to permit generation and modification of CDLs.
  - .2 Provide standard reference modules for text based systems module that will permit modification to suit site specific applications. Module to include cut, paste, search and compare utilities to permit easy CDL modification and verification.
  - .3 Provide full library of symbols used by manufacturer for system product installed accessible to operators for systems using graphical environment for creation of CDLs Module to include graphic tools required to generate and create new object code for downloading to building controllers.
-

- .4 Module to permit testing of code before downloading to building controllers.

## 2.6 WORKSTATION APPLICATION EDITORS

- .1 Support editing of all system applications. Provide editors for each application at the PC workstation. The applications shall be downloaded and executed at one or more of the controller panels.
- .1 Controller: provide a full-screen editor for each type of application that shall allow the operator to view and change the configuration, name, control parameters, and set points for all controllers.
- .2 Scheduling: an editor for the scheduling application shall be provided at each workstation. Provide a method of selecting the desired schedule and month. This shall consist of a monthly calendar for each schedule. Exception schedules and holidays shall be shown clearly on the calendar. Provide a method for allowing several related objects to follow a schedule. The start and stop times for each object shall be adjustable from this master schedule.
- .3 Custom Application Programming: provide the tools to create, modify, and debug custom application programming. The operator shall be able to create, edit, and download custom programs at the same time that all other system applications are operating. The system shall be fully operable while custom routines are edited, compiled, and downloaded. The programming language shall have the following features:
- .4 The language shall be English language oriented, be based on the syntax of BASIC, FORTRAN, C, or PASCAL, and allow for free-form programming (i.e., not column-oriented or "fill in the blanks").
- .5 A full-screen character editor/programming environment shall be provided. The editor shall be cursor/mouse-driven and allow the user to insert, add, modify, and delete custom programming code. It also shall incorporate word processing features such as cut/paste and find/replace.
- .6 The programming language shall allow independently executing program modules to be developed. Each module shall be able to independently enable and disable other modules.
- .7 The editor/programming environment shall have a debugging/simulation capability that allows the user to step through the program and observe any intermediate values and/or results. The debugger also shall provide error messages for syntax and execution errors.
- .8 The programming language shall support conditional statements (IF/THEN/ELSE/ELSE-IF) using compound Boolean (AND, OR, and NOT) and/or relations (EQUAL, LESS THAN, GREATER THAN, NOT EQUAL) comparisons. The programming language shall support floating point arithmetic using the following operators: +, -, /, x, square root, and x-to-the-y power. The following mathematical functions also shall be provided: natural log, log, trigonometric functions (sine, cosine, etc.) absolute value, and minimum/maximum value from a list of values.
- .9 The programming language shall have predefined variables that represent time of day, day of the week, month of the year, and the date. Other predefined variables shall provide elapsed time in seconds, minutes, hours, and days. These elapsed time variables shall be able to be reset by the language so that interval-timing functions can be stopped and started within a program. Values from all of the above variables shall be readable by the language so that they can be used in a

- program for such purposes as IF/THEN comparisons, calculations, etc.
- .10 The language shall be able to read the values of the variables and use them in programming statement logic, comparisons, and calculations.
- .11 The programs shall support online changes with the ability to read real time values without exiting the program. Sample programs and syntax help functions shall be resident in the program.

## 2.7 ADDITIONAL UTILITY SOFTWARE

- .1 Supply and install on primary OWS, following CAD software products by Autodesk Inc. and include:
  - .1 Include special drivers, fonts, to ensure complete and proper functioning of software packages specified. Deliver system complete with full set of User Manuals.
  - .2 Enter soft copy submissions, including "Record" drawings specified in Section 01 33 00 - Submittal Procedures in OWS.
  - .3 Enter soft copy of Architectural, Electrical, Mechanical systems plans and "Record" drawings in OWS. Plans and drawings to be provided by PWGSC Representative.

## PART 3 - EXECUTION

### 3.1 INSTALLATION REQUIREMENTS

- .1 Power as required from local 120 V power branch circuit panels for OWSs and peripheral equipment supplied by Division 26.
  - .1 Install tamper locks on breakers of circuit panels.
  - .2 Refer to UPS requirements stated under OWS Hardware in PART 2.

END

---

## PART 1 - GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers, Inc. (ASHRAE).
  - .1 ASHRAE 2013, Applications Handbook, SI Edition.
- .2 Canadian Standards Association (CSA International).
  - .1 CSA C22.2 No.205-M1983 (R2004), Signal Equipment.
- .3 Institute of Electrical and Electronics Engineers (IEEE).
  - .1 IEEE C37.90.1-02, Surge Withstand Capabilities (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus.

### 1.3 DEFINITIONS

- .1 Acronyms and definitions: refer to Section 25 05 01 - EMCS: General Requirements.

### 1.4 SYSTEM DESCRIPTION

- .1 General: Network of controllers comprising of Description MCU's (B-BC), LCU's (B-AAC), ECU's or TCU's (B-ASC) to be provided as indicated in System Architecture Diagram to support building systems and associated sequence(s) of operations as detailed in these specifications. Every device in the system which executes control logic and directly controls HVAC equipment must conform to a standard BACnet Device profile as specified in ANSI/ASHRAE 135-2012, BACnet Annex L. Unless otherwise specified, hardwired actuators and sensors may be used in lieu of BACnet Smart Actuators and Smart Sensors.
    - .1 Provide sufficient controllers to meet intents and requirements of this section.
    - .2 Building Controllers (BCs). Each BC shall conform to BACnet Building Controller (B-BC) device profile as specified in ANSI/ASHRAE 135-2012, BACnet Annex L and shall be listed as a certified B-BC in the BACnet Testing Laboratories (BTL) Product Listing.
    - .3 Advanced Application Controllers (AACs). Each AAC shall conform to BACnet Advanced Application Controller (B-AAC) device profile as specified in ANSI/ASHRAE 135-2012, BACnet Annex L and shall be listed as a certified B-AAC in the BACnet Testing Laboratories (BTL) Product Listing.
    - .4 Application Specific Controllers (ASCs). Each ASC shall conform to BACnet Application Specific Controller (B-ASC) device profile as specified in ANSI/ASHRAE 135-2012, BACnet Annex L and shall be listed as a certified B-ASC in the BACnet Testing Laboratories (BTL)Product Listing.
-

- .5 Smart Actuators (SAs). Each SA shall conform to BACnet Smart Actuator (B-SA) device profile as specified in ANSI/ASHRAE 135-2012, BACnet Annex L and shall be listed as a certified B-SA in the BACnet Testing Laboratories (BTL) Product Listing.
- .6 Smart Sensors (SSs). Each SS shall conform to BACnet Smart Sensor (B-SS) device profile as specified in ANSI/ASHRAE 135-2012, BACnet Annex L and shall be listed as a certified B-SS in the BACnet Testing Laboratories (BTL) Product Listing.
- .7 BACnet Communication:
  - .1 Each BC shall reside on or be connected to a BACnet network using ISO 8802-3 (Ethernet) Data Link/Physical layer protocol and BACnet/IP addressing.
  - .2 BACnet routing shall be performed by BCs or other BACnet device routers as necessary to connect BCs to networks of AACs and ASCs.
  - .3 Each AAC shall reside on a BACnet network using ISO 8802-3 (Ethernet) Data Link/Physical layer protocol with BACnet/IP addressing, or it shall reside on a BACnet network using the ARCNET or MS/TP Data Link/Physical layer protocol.
  - .4 Each ASC shall reside on a BACnet network using the ARCNET or MS/TP Data Link/Physical layer protocol.
  - .5 Each SA shall reside on a BACnet network using the ARCNET or MS/TP Data Link/Physical layer protocol.
  - .6 Each SS shall reside on a BACnet network using ISO 8802-3 (Ethernet) Data Link/Physical layer protocol with BACnet/IP addressing, or it shall reside on a BACnet network using ARCNET or MS/TP Data Link/Physical layer protocol.
- .2 Controllers: stand-alone intelligent Control Units.
  - .1 Incorporate programmable microprocessor, non-volatile program memory, RAM, power supplies, as required to perform specified functions.
  - .2 Incorporate communication interface ports for communication to LANs to exchange information with other Controllers.
  - .3 Capable of interfacing with operator interface device.
  - .4 Execute its logic and control using primary inputs and outputs connected directly to its onboard input/output field terminations or slave devices, and without need to interact with other controller. Secondary input used for reset such as outdoor air temperature may be located in other Controller(s).
    - .1 Secondary input used for reset such as outdoor air temperature may be located in other Controller(s).

## 1.5 DESIGN REQUIREMENTS

- .1 To include:
  - .1 Scanning of AI and DI connected inputs for detection of change of value and processing detection of alarm conditions.
  - .2 Perform On-Off digital control of connected points, including resulting required states generated through programmable logic output.
  - .3 Perform Analog control using programmable logic, (including PID) with adjustable dead bands and deviation alarms.
  - .4 Control of systems as described in sequence of operations.



- 
- .5 Execution of optimization routines as listed in this section.
  - .2 Total spare capacity for MCUs and LCUs: at least 25% of each point type distributed throughout the MCUs and LCUs.
  - .3 Field Termination and Interface Devices:
    - .1 To: CSA C22.2 No. 205.
    - .2 Electronically interface sensors and control devices to processor unit.
    - .3 Include, but not be limited to, following:
      - .1 Programmed firmware or logic circuits to meet functional and technical requirements.
      - .2 Power supplies for operation of logics devices and associated field equipment.
      - .3 Lockable wall cabinet.
    - .4 Required communications equipment and wiring (if remote units).
    - .5 Leave controlled system in "fail-safe" mode in event of loss of communication with, or failure of, processor unit.
    - .6 Input Output interface to accept as minimum AI, AO, DI, DO functions as specified.
    - .7 Wiring terminations: use conveniently located screw type or spade lug terminals.
  - .4 AI interface equipment to:
    - .1 Convert analog signals to digital format with 10 bit analog-to-digital resolution.
    - .2 Provide for following input signal types and ranges:
      - .1 4 - 20 mA;
      - .2 0 - 10 V DC;
      - .3 100/1000 ohm RTD input;
    - .3 Meet IEEE C37.90.1 surge withstand capability.
    - .4 Have common mode signal rejection greater than 60 dB to 60 Hz.
    - .5 Where required, dropping resistors to be certified precision devices which complement accuracy of sensor and transmitter range specified.
  - .5 AO interface equipment:
    - .1 Convert digital data from controller processor to acceptable analog output signals using 8 bit digital-to-analog resolution.
    - .2 Provide for following output signal types and ranges:
      - .1 4 - 20 mA.
      - .2 0 - 10 V DC.
    - .3 Meet IEEE C37.90.1 surge withstand capability.
  - .6 DI interface equipment:
    - .1 Able to reliably detect contact change of sensed field contact and transmit condition to controller.
    - .2 Meet IEEE C37.90.1 surge withstand capability.
    - .3 Accept pulsed inputs up to 2 kHz.
  - .7 DO interface equipment:
    - .1 Respond to controller processor output, switch respective outputs. Each DO hardware to be capable of switching up to 0.5 amps at 24 V AC.
-

- .2 Switch up to 5 amps at 220 V AC using optional interface relay.
- .3 Controllers and associated hardware and software: operate in conditions of 0 degrees C to 44 degrees C and 20% to 90% non-condensing RH.
- .4 Controllers (MCU, LCU): mount in wall mounted cabinet with hinged, keyed-alike locked door.
  - .1 Provide for conduit entrance from top, bottom or sides of panel.
  - .2 ECUs and TCUs to be mounted in equipment enclosures or separate enclosures.
- .5 Cabinets to provide protection from water dripping from above, while allowing sufficient airflow to prevent internal overheating.
- .6 Provide surge and low voltage protection for interconnecting wiring connections.

#### 1.6 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .1 Submit product data sheets for each product item proposed for this project.

### PART 2 - PRODUCTS

#### 2.1 MASTER CONTROL UNIT (MCU)

- .1 Include high speed communication LAN Port for Peer to Peer communications with OWS(s) and other MCU level devices.
  - .1 MCU must support BACnet/IP.
  - .2 MCU must support field bus protocol BACnet MS/TP.
- .2 MCU local I/O capacity as follows:
  - .1 MCU I/O points as allocated in I/O Summary Table referenced in MD13800.
  - .2 LCUs may be added to support system functions.
- .3 Central Processing Unit (CPU).
  - .1 Processor to consist of minimum 16 bit microprocessor capable of supporting software to meet specified requirements.
  - .2 CPU idle time to be more than 30% when system configured to maximum input and output with worst case program use.
  - .3 Minimum addressable memory to be at manufacturer's discretion but to support at least performance and technical specifications to include but not limited to:
    - .1 Non-volatile EEPROM to contain operating system, executive, application, sub-routine, other configurations definition software. Tape media not acceptable.
    - .2 Battery backed (72 hour minimum capacity) RAM (to reduce the need to reload operating data in event of power failure) to contain CDLs, application parameters, operating data or software that is required to be modifiable from operational standpoint such as schedules, set points, alarm limits, PID constants and CDL and hence modifiable on-line through operator panel or remote operator's interface. RAM to be downline loadable from OWS.
- .4 Include uninterruptible clock accurate to plus or minus 5 secs/month, capable of

deriving year/month/day/hour/minute/second, with rechargeable batteries for minimum 72 hour operation in event of power failure.

- .4 MCU to conform to BACnet (B-BC) profile.
- .5 Local Operator Terminal (OT):
  - .1 Mount access/display panel in MCU or in suitable enclosure beside MCU.
  - .2 Support operator's terminal for local command entry, instantaneous and historical data display, programs, additions and modifications.
  - .3 Display simultaneously minimum of 16 point identifiers to allow operator to view single screen dynamic displays depicting entire mechanical systems. Point identifiers to be in English.
  - .4 Functions to include, but not be limited to, following:
    - .1 Start and stop points.
    - .2 Modify setpoints.
    - .3 Modify PID loop parameters.
    - .4 Override PID control.
    - .5 Change time/date.
    - .6 Add/modify/start/stop weekly scheduling.
    - .7 Add/modify setpoint weekly scheduling.
    - .8 Enter temporary override schedules.
    - .9 Define holiday schedules.
    - .10 View analog limits.
    - .11 Enter/modify analog warning limits.
    - .12 Enter/modify analog alarm limits.
    - .13 Enter/modify analog differentials.
  - .5 Provide access to real and calculated points in controller to which it is connected or to other controller in network.  
This capability not to be restricted to subset of predefined "global points" but to provide totally open exchange of data between OT and other controller in network.
  - .6 Operator access to OTs: same as OWS user password and password changes to automatically be downloaded to controllers on network.
  - .7 Provide prompting to eliminate need for user to remember command format or point names. Prompting to be consistent with user's password clearance and types of points displayed to eliminate possibility of operator error.
  - .8 Identity of real or calculated points to be consistent with network devices. Use same point identifier as at OWS's for access of points at OT to eliminate cross-reference or look-up tables.

## 2.2 LOCAL CONTROL UNIT (LCU)

- .1 Provide multiple control functions for typical built-up and package HVAC systems, hydronic systems and electrical systems.
- .2 Minimum of 16 I/O points of which minimum be 4 AOs, 4 AIs, 4 DIs, 4 DOs.
- .3 Points integral to one Building System to be resident on only one controller.

- .4 Microprocessor capable of supporting necessary software and hardware to meet specified requirements as listed in previous MCU article with following additions:
  - .1 Include minimum 2 interface ports for connection of local computer terminal.
  - .2 Design so that shorts, opens or grounds on input or output will not interfere with other input or output signals.
  - .3 Physically separate line voltage (70V and over) circuits from DC logic circuits to permit maintenance on either circuit with minimum hazards to technician and equipment.
  - .4 Include power supplies for operation of LCU and associated field equipment.
  - .5 In event of loss of communications with, or failure of, MCU, LCU to continue to perform control. Controllers that use defaults or fail to open or close positions not acceptable.
  - .6 Provide conveniently located screw type or spade lug terminals for field wiring.
  - .7 LCU to conform to BACnet (B-AAC) profile.

## 2.3 SOFTWARE

- .1 General:
  - .1 Include as minimum: operating system executive, communications, application programs, operator interface, and systems sequence of operation - CDL's.
  - .2 Include "firmware" or instructions which are programmed into ROM, EPROM, EEPROM or other non-volatile memory.
  - .3 Include initial programming of Controllers, for entire system.
- .2 Program and data storage.
  - .1 Store executive programs and site configuration data in ROM, EEPROM or other non-volatile memory.
  - .2 Maintain CDL and operating data including setpoints, operating constants, alarm limits in battery-backed RAM or EEPROM for display and modification by operator.
- .3 Programming languages.
  - .1 Program Control Description Logic software (CDL) using English like or graphical, high level, general control language.
  - .2 Structure software in modular fashion to permit simple restructuring of program modules if future software additions or modifications are required. GO TO constructs not allowed unless approved by PWGSC Representative.
- .4 Operator Terminal interface.
  - .1 Operating and control functions include:
    - .1 Multi-level password access protection to allow user/manager to limit workstation control.
    - .2 Alarm management: processing and messages.
    - .3 Operator commands.
    - .4 Reports.
    - .5 Displays.
    - .6 Point identification.

- 
- .5 Pseudo or calculated points.
    - .1 Software to provide access to value or status in controller or other networked controller in order to define and calculate pseudo point. When current pseudo point value is derived, normal alarm checks must be performed or value used to totalize.
    - .2 Inputs and outputs for process: include data from controllers to permit development of network-wide control strategies. Processes also to permit operator to use results of one process as input to number of other processes (e.g. cascading).
  - .6 Control Description Logic (CDL):
    - .1 Capable of generating on-line project-specific CDLs which are software based, programmed into RAM or EEPROM and backed up to OWS. PWGSC must have access to these algorithms for modification or to be able to create new ones and to integrate these into CDLs on BC(s) from OWS.
    - .2 Write CDL in high level language that allows algorithms and interlocking programs to be written simply and clearly. Use parameters entered into system (e.g. setpoints) to determine operation of algorithm. Operator to be able to alter operating parameters on-line from OWS and BC(s) to tune control loops.
    - .3 Perform changes to CDL on-line.
    - .4 Control logic to have access to values or status of points available to controller including global or common values, allowing cascading or inter-locking control.
    - .5 Energy optimization routines including enthalpy control, supply temperature reset, to be LCU or MCU resident functions and form part of CDL.
    - .6 MCU to be able to perform following pre-tested control algorithms:
      - .1 Two position control.
      - .2 Proportional Integral and Derivative (PID) control.
    - .7 Control software to provide ability to define time between successive starts for each piece of equipment to reduce cycling of motors.
    - .8 Provide protection against excessive electrical-demand situations during start-up periods by automatically introducing time delays between successive start commands to heavy electrical loads.
  - .7 Event and Alarm management: use management by exception concept for Alarm Reporting. This is system wide requirement. This approach will insure that only principal alarms are reported to OWS. Events which occur as direct result of primary event to be suppressed by system and only events which fail to occur to be reported. Such event sequence to be identified in I/O Summary and sequence of operation. Examples of above are, operational temperature alarms limits which are exceeded when main air handler is stopped, or General Fire condition shuts air handlers down, only Fire alarm status shall be reported. Exception is, when air handler which is supposed to stop or start fails to do so under event condition.
  - .8 Energy management programs: include specific summarizing reports, with date stamp indicating sensor details which activated and or terminated feature.
    - .1 MCU in coordination with subordinate LCU, TCU, ECU to provide for the following energy management routines:
      - .1 Time of day scheduling.
      - .2 Calendar based scheduling.
-

- .3 Holiday scheduling.
- .4 Temporary schedule overrides.
- .5 Optimal start stop.
- .6 Night setback control.
- .7 Enthalpy (economizer) switchover.
- .8 Peak demand limiting.
- .9 Temperature compensated load rolling.
- .10 Fan speed/flow rate control.
- .2 Programs to be executed automatically without need for operator intervention and be flexible enough to allow customization.
- .3 Apply programs to equipment and systems as specified.
- .9 Function/Event Totalization: features to provide predefined reports which show daily, weekly, and monthly accumulating totals and which include high rate (time stamped) and low rate (time stamped) and accumulation to date for month.
  - .1 MCUs to accumulate and store automatically run-time for binary input and output points.
  - .2 MCU to automatically sample, calculate and store consumption totals on daily, weekly or monthly basis for user-selected analog or binary pulse input-type points.
  - .3 MCU to automatically count events (number of times pump is cycled off and on) daily, weekly or monthly basis.
  - .4 Totalization routine to have sampling resolution of 1 min or less for analog inputs.
  - .5 Totalization to provide calculations and storage of accumulations up to 99,999.9 units (eg. kWh, litres, tonnes, etc.).
  - .6 Store event totalization records with minimum of 9,999,999 events before reset.
  - .7 User to be able to define warning limit and generate user-specified messages when limit reached.

## 2.4 LEVELS OF ADDRESS

- .1 Upon operator's request, EMCS to present status of any single 'point', 'system' or point group, entire 'area', or entire network on printer or OWS as selected by operator.
  - .1 Display analog values digitally to 1 place of decimals with negative sign as required.
  - .2 Update displayed analog values and status when new values received.
  - .3 Flag points in alarm by blinking, reverse video, different colour, bracketed or other means to differentiate from points not in alarm.
  - .4 Updates to be change-of-value (COV)-driven or if polled not exceeding 2 second intervals.

## 2.5 POINT NAME SUPPORT

- .1 Controllers (MCU, LCU) to support PWGSC point naming convention as defined in Section 25 05 01 - EMCS: General Requirements.

PART 3 - EXECUTION

3.1 LOCATION

- .1 Location of Controllers to be approved by PWGSC Representative.

3.2 INSTALLATION

- .1 Install Controllers in secure locking enclosures.
- .2 Provide necessary power from local 120 V branch circuit panel for equipment.
- .3 Install tamper locks on breakers of circuit breaker panel.
- .4 Coordinate airflow adjustments with air balancer.

END

---

## PART 1 – GENERAL

### 1.1 RELATED SECTIONS

- .1 Division 01 - General Requirements.

### 1.2 REFERENCES

- .1 American Society for Testing and Materials (ASTM International).
  - .1 ASTM B148-97(2009), Standard Specification for Aluminum-Bronze Sand Castings.
- .2 Institute of Electrical and Electronics Engineers (IEEE)
  - .1 IEEE C57.13-2008, IEEE Trial-Use Standard of Performance and Test Requirements for Instrument Transformers of a Nominal System Voltage of 115 kV and Above.
- .3 National Electrical Manufacturer's Association (NEMA).
  - .1 NEMA 250-2008, Enclosures for Electrical Equipment (1000 Volts Maximum).
- .4 Air Movement and Control Association, Inc. (AMCA).
  - .1 AMCA Standard 500-D-07, Laboratory Method of Testing Dampers For Rating.
- .5 Canadian Standards Association (CSA International).
  - .1 CSA C22.1-09, Canadian Electrical Code, Part 1 (21st Edition), Safety Standard for Electrical Installations.

### 1.3 DEFINITIONS

- .1 Acronyms and Definitions: refer to Section 25 05 01 - EMCS: General Requirements.

### 1.4 SUBMITTALS

- .1 Submit shop drawings and manufacturer's installation instructions in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Manufacturer's Instructions:
  - .1 Submit manufacturer's installation instructions for specified equipment and devices.

## PART 2 - PRODUCTS

### 2.1 GENERAL

- .1 Control devices of each category to be of same type and manufacturer.
  - .2 External trim materials to be corrosion resistant.
  - .3 Operating conditions: 0 - 32 degrees C with 10 - 90% RH (non-condensing) unless otherwise specified.
-



- .4 Terminations: use standard conduit box with slot screwdriver compression connector block unless otherwise specified.
- .5 Transmitters and sensors to be unaffected by external transmitters including walkie talkies.
- .6 Account for hysteresis, relaxation time, maximum and minimum limits in applications of sensors and controls.
- .7 Outdoor installations: use weatherproof construction in NEMA 4 enclosures.
- .8 Devices installed in user occupied space not exceed Noise Criteria (NC) of 35. Noise generated by any device must not be detectable above space ambient conditions.
- .9 Range: including temperature, humidity, pressure, as indicated on drawings.

## 2.2 TEMPERATURE SENSORS

- .1 General: except for room sensors to be resistance or thermocouple type to following requirements:
    - .1 Thermocouples: limit to temperature range of 200 degrees C and over.
    - .2 RTD's: 100 or 1000 ohm at 0 degrees C (plus or minus 0.2 ohms) platinum element with strain minimizing construction, 3 integral anchored leadwires. Coefficient of resistivity: 0.00385 ohms/ohm degrees C.
    - .3 Sensing element: hermetically sealed.
    - .4 Stem and tip construction: copper or type 304 stainless steel.
    - .5 Time constant response: less than 3 seconds to temperature change of 10 degrees C.
    - .6 Immersion wells: NPS 3/4, stainless steel spring loaded construction, with heat transfer compound compatible with sensor. Insertion length 100, 150 mm as indicated.
  - .2 Room temperature sensors and display wall modules.
    - .1 Room temperature sensors.
      - .1 Wall mounting, in slotted type covers having brushed aluminum, brushed stainless steel finish, with guard as indicated.
      - .2 Element 10-50 mm long RTD with ceramic tube or equivalent protection or thermistor, 10,000 ohm, accuracy of plus or minus 0.2 degrees C.
    - .2 Provide duplex receptacle as required.
  - .3 Duct temperature sensors:
    - .1 General purpose duct type: suitable for insertion into ducts at various orientations, insertion length 460 mm.
    - .2 Averaging duct type: incorporates numerous sensors inside assembly which are averaged to provide one reading. Minimum insertion length 600 mm. Bend probe at field installation time to 100 mm radius at point along probe without degradation of performance.
    - .3 Low voltage mechanical wire to be yellow in colour.
-

- .4 Outdoor air temperature sensors:
  - .1 Outside air type: complete with probe length 100 - 150 mm long, non-corroding shield to minimize solar and wind effects, threaded fitting for mating to 13 mm conduit, weatherproof construction in NEMA 4 enclosure.

## 2.3 TEMPERATURE TRANSMITTERS

- .1 Requirements:
  - .1 Input circuit: to accept 3-lead, 100 or 1000 ohm at 0 degrees C, platinum resistance detector type sensors.
  - .2 Power supply: 24 V DC into load of 575 ohms. Power supply effect less than 0.01 degrees C per volt change.
  - .3 Output signal: 4 - 20 mA into 500 ohm maximum load.
  - .4 Input and output short circuit and open circuit protection.
  - .5 Output variation: less than 0.2% of full scale for supply voltage variation of plus or minus 10%.
  - .6 Combined non-linearity, repeatability, hysteresis effects: not to exceed plus or minus 0.5% of full scale output.
  - .7 Maximum current to 100 or 1000 ohm RTD sensor: not to exceed 25 mA.
  - .8 Integral zero and span adjustments.
  - .9 Temperature effects: not to exceed plus or minus 1.0% of full scale/50 degrees C.
  - .10 Long term output drift: not to exceed 0.25% of full scale/ 6 months.
  - .11 Transmitter ranges: select narrowest range to suit application.

## 2.4 HUMIDITY SENSORS

- .1 Room and Duct Requirements:
    - .1 Range: 5 - 90% RH minimum.
    - .2 Operating temperature range: 0 - 60 degrees C.
    - .3 Absolute accuracy:
      - .1 Duct sensors: plus or minus 3%.
      - .2 Room sensors: plus or minus 2%.
    - .4 Sheath: stainless steel with integral shroud for specified operation in air streams of up to 10 m/s.
    - .5 Maximum sensor non-linearity: plus or minus 2% RH with defined curves.
    - .6 Room sensors: wall mounted as indicated.
    - .7 Duct mounted sensors: locate so that sensing element is in air flow in duct.
  - .2 Outdoor Humidity Requirements:
    - .1 Range: 0 - 100% RH minimum.
    - .2 Operating temperature range: -40 – 50 degrees C.
    - .3 Absolute accuracy: plus or minus 2%.
    - .4 Temperature coefficient: plus or minus 0.03%RH/ degrees C over 0 to 50 degrees C.
    - .5 Must be unaffected by condensation or 100% saturation.
    - .6 No routine maintenance or calibration is required.
-

---

## 2.5 HUMIDITY TRANSMITTERS

- .1 Requirements:
  - .1 Input signal: from RH sensor.
  - .2 Output signal: 4 - 20 mA onto 500 ohm maximum load.
  - .3 Input and output short circuit and open circuit protection.
  - .4 Output variations: not to exceed 0.2% of full scale output for supply voltage variations of plus or minus 10%.
  - .5 Output linearity error: plus or minus 1.0% maximum of full scale output.
  - .6 Integral zero and span adjustment.
  - .7 Temperature effect: plus or minus 1.0% full scale/6 months.
  - .8 Long term output drift: not to exceed 0.25% of full scale output/6 months.

## 2.6 PRESSURE TRANSDUCERS

- .1 Requirements:
  - .1 Combined sensor and transmitter measuring pressure.
  - .1 Internal materials: suitable for continuous contact with industrial standard instrument air, compressed air, water, steam, as applicable.
  - .2 Output signal: 4 - 20 mA into 500 ohm maximum load.
  - .3 Output variations: less than 0.2% full scale for supply voltage variations of plus or minus 10%.
  - .4 Combined non-linearity, repeatability, and hysteresis effects: not to exceed plus or minus 0.5% of full scale output over entire range.
  - .5 Temperature effects: not to exceed plus or minus 1.5% full scale/ 50 degrees C.
  - .6 Over-pressure input protection to at least twice rated input pressure.
  - .7 Output short circuit and open circuit protection.
  - .8 Accuracy: plus or minus 1% of Full Scale.

## 2.7 DIFFERENTIAL PRESSURE TRANSMITTERS

- .1 Requirements:
  - .1 Internal materials: suitable for continuous contact with industrial standard instrument air, compressed air, water, steam, as applicable.
  - .2 Output signal: 4 - 20 mA into 500 ohm maximum load.
  - .3 Output variations: less than 0.2% full scale for supply voltage variations of plus or minus 10%.
  - .4 Combined non-linearity, repeatability, and hysteresis effects: not to exceed plus or minus 0.5% of full scale output over entire range.
  - .5 Integral zero and span adjustment.
  - .6 Temperature effects: not to exceed plus or minus 1.5% full scale/50 degrees C.
  - .7 Over-pressure input protection to at least twice rated input pressure.
  - .8 Output short circuit and open circuit protection.
  - .9 Unit to have 12.5 mm N.P.T. conduit connection. Enclosure to be integral part of unit.

## 2.8 STATIC PRESSURE SENSORS

- .1 Requirements:
    - .1 Multipoint element with self-averaging manifold.
-

- .1 Maximum pressure loss: 160 Pa at 10 m/s. (Air stream manifold).
- .2 Accuracy: plus or minus 1% of actual duct static pressure.

## 2.9 STATIC PRESSURE TRANSMITTERS

- .1 Requirements:
  - .1 Output signal: 4 - 20mA linear into 500 ohm maximum load.
  - .2 Calibrated span: not to exceed 150% of duct static pressure at maximum flow.
  - .3 Accuracy: 0.4% of span.
  - .4 Repeatability: within 0.5% of output.
  - .5 Linearity: within 1.5% of span.
  - .6 Deadband or hysteresis: 0.1% of span.
  - .7 External exposed zero and span adjustment.
  - .8 Unit to have 12.5 mm N.P.T. conduit connection. Enclosure to be integral part of unit.

## 2.10 VELOCITY PRESSURE SENSORS

- .1 Requirements:
  - .1 Multipoint static and total pressure sensing element with self-averaging manifold with integral air equalizer and straightener section.
  - .2 Maximum pressure loss: 37 Pa at 1000 m/s.
  - .3 Accuracy: plus or minus 1% of actual duct velocity.

## 2.11 VELOCITY PRESSURE TRANSMITTERS

- .1 Requirements:
  - .1 Output signal: 4 - 20 mA linear into 500 ohm maximum load.
  - .2 Calibrated span: not to exceed 125% of duct velocity pressure at maximum flow.
  - .3 Accuracy: 0.4% of span.
  - .4 Repeatability: within 0.1% of output.
  - .5 Linearity: within 0.5% of span.
  - .6 Deadband or hysteresis: 0.1% of span.
  - .7 External exposed zero and span adjustment.
  - .8 Unit to have 12.5 mm N.P.T. conduit connection. Enclosure to be integral part of unit.

## 2.12 PRESSURE AND DIFFERENTIAL PRESSURE SWITCHES

- .1 Requirements:
  - .1 Internal materials: suitable for continuous contact with compressed air, water, steam, etc., as applicable.
  - .2 Adjustable setpoint and differential.
  - .3 Switch: snap action type, rated at 120V, 15 amps AC or 24 V DC.
  - .4 Switch assembly: to operate automatically and reset automatically when conditions return to normal. Over-pressure input protection to at least twice rated input pressure.
  - .5 Accuracy: within 2% repetitive switching.

- .1 Requirements:(Cont'd)
- .6 Provide switches with isolation valve and snubber, where code allows, between sensor and pressure source.
- .7 Switches on steam and high temperature hot water service: provide pigtail syphon.

## 2.13 TEMPERATURE SWITCHES

- .1 Requirements:
  - .1 Operate automatically. Reset automatically, except as follows:
    - .1 Low temperature detection: manual reset.
    - .2 High temperature detection: manual reset.
  - .2 Adjustable setpoint and differential.
  - .3 Accuracy: plus or minus 1 degrees C.
  - .4 Snap action rating: 120V, 15 amps or 24V DC as required. Switch to be DPST for hardwire and EMCS connections.
  - .5 Type as follows:
    - .1 Room: for wall mounting on standard electrical box with or without protective guard as indicated.
    - .2 Duct, general purpose: insertion length = 460 mm.
    - .3 Thermowell: stainless steel, with compression fitting for NPS ¾ thermowell. Immersion length: 100 mm.
    - .4 Low temperature detection: continuous element with 6000 mm insertion length, duct mounting, to detect coldest temperature in any 30 mm length.
    - .5 Strap-on: with helical screw stainless steel clamp.

## 2.14 AIR PRESSURE GAUGES

- .1 Diameter: 38 mm minimum.
- .2 Range: zero to two times operating pressure of measured pressure media or nearest standard range.

## 2.15 ELECTROMECHANICAL RELAYS

- .1 Requirements:
  - .1 Double voltage, DPDT, plug-in type with termination base.
  - .2 Coils: rated for 120V AC or 24V DC. Other voltage: provide transformer.
  - .3 Contacts: rated at 5 amps at 120 V AC.
  - .4 Relay to have visual status indication

## 2.16 SOLID STATE RELAYS

- .1 General:
  - .1 Relays to have LED Indicator
  - .2 Input and output Barrier Strips to accept 14 to 28 AWG wire.
  - .3 Operating temperature range to be -20 degrees C to 70 degrees C.
  - .4 Relays to be CSA Certified.
  - .5 Input/output Isolation Voltage to be 4000 VAC at 25 degrees C for 1 second maximum duration.

- .6 Operational frequency range, 45 to 65 HZ.
- .2 Input:
  - .1 Control voltage, 3 to 32 VDC.
  - .2 Drop out voltage, 1.2 VDC.
  - .3 Maximum input current to match AO (Analog Output) board.
- .3 Output.
  - .1 AC or DC Output Model to suit application.

#### 2.17 CURRENT TRANSDUCERS

- .1 Purpose: combined sensor/transducer, to measure line current and produce proportional signal in one of following ranges:
  - .1 4-20 mA DC.
  - .2 0-1 volt DC.
  - .3 0-10 volts DC.
  - .4 0-20 volts DC.
- .2 Frequency insensitive from 10 - 80 hz.
- .3 Accuracy to 0.5% full scale.
- .4 Zero and span adjustments. Field adjustable range to suit motor applications.
- .5 Adjustable mounting bracket to allow for secure/safe mounting inside MCC.

#### 2.18 CURRENT SENSING RELAYS

- .1 Requirements:
  - .1 Suitable to detect belt loss or motor failure.
  - .2 Trip point adjustment, output status LED.
  - .3 Split core for easy mounting.
  - .4 Induced sensor power.
  - .5 Relay contacts: capable of handling 0.5 amps at 30 VAC / DC. Output to be NO solid state.
  - .6 Suitable for single or 3 phase monitoring. For 3-Phase applications: provide for discrimination between phases.
  - .7 Adjustable latch level.

#### 2.19 ELECTRONIC CONTROL DAMPER ACTUATORS

- .1 Requirements:
  - .1 Direct mount proportional type as indicated.
  - .2 Spring return for "fail-safe" in Normally Open or Normally Closed position as indicated.
  - .3 Operator: size to control dampers against maximum pressure and dynamic closing/opening pressure, whichever is greater.
  - .4 Power requirements: 5 VA maximum at 24 V AC.
  - .5 Operating range: 0 - 10 V DC or 4 - 20 mA DC.

- .6 For VAV box applications floating control type actuators may be used.
- .7 Damper actuator to drive damper from full open to full closed in less than 120 seconds.

## 2.20 CONTROL VALVES

- .1 Body: globe style.
  - .1 Flow characteristic as indicated on control valve schedule: linear, equal percentage, quick opening.
  - .2 Flow factor (KV) as indicated on control valve schedule: CV in imperial units.
  - .3 Normally open, Normally closed, as indicated.
  - .4 Two or Three port, as indicated.
  - .5 Leakage rate ANSI class IV, 0.01% of full open valve capacity.
  - .6 Packing easily replaceable.
  - .7 Stem, stainless steel.
  - .8 Plug and seat, bronze.
  - .9 Disc, replaceable, material to suit application.
  - .10 NPS 2 and under:
    - .1 Screwed National Pipe Thread (NPT) tapered female connections.
    - .2 Valves to ANSI Class 250, valves to bear ANSI mark.
    - .3 Rangeability 50:1 minimum.
  - .11 NPS 2½ and larger:
    - .1 Flanged connections.
    - .2 Valves to ANSI Class 150, valves to bear ANSI mark.
    - .3 Rangeability 100:1 minimum.

## 2.21 ELECTRONIC / ELECTRIC VALVE ACTUATORS

- .1 Requirements:
  - .1 Construction: steel, cast iron, aluminum.
  - .2 Control signal: 0-10V DC or 4-20 mA DC.
  - .3 Positioning time: to suit application.
  - .4 Fail to normal position as indicated.
  - .5 Scale or dial indication of actual control valve position.
  - .6 Size actuator to meet requirements and performance of control valve specifications.
  - .7 For interior and perimeter terminal heating and cooling applications floating control actuators are acceptable.
  - .8 Minimum shut-off pressure: refer to control valve schedule.

## 2.22 PANELS

- .1 Wall mounted enamelled steel cabinets with hinged and key-locked front door.
- .2 Multiple panels as required to handle requirements with additional space to accommodate 25% additional capacity as required.
- .3 Panels to be lockable with same key.

## 2.23 WIRING

- .1 Low voltage mechanical wire to be yellow in colour.
- .2 In accordance with Section 26 27 26 – Wiring Devices.
- .3 For wiring under 70 volts use FT6 rated wiring where wiring is not run in conduit. Other cases use FT4 wiring.
- .4 Wiring must be continuous without joints.
- .5 Sizes:
  - .1 Field wiring to digital device: #18AWG or 20AWG stranded twisted pair.
  - .2 Analog input and output: shielded #18 minimum solid copper or #20 minimum stranded twisted pair.

## 2.24 THERMOSTATS

- .1 Reverse acting thermostats:
  - .1 Single, pole double throw.
  - .2 120 V, 8.0 Amps.
  - .3 Acceptable manufacturers: Johnson Controls, Andover, Honeywell, Siemens.

## 2.25 AIR PROVING SWITCH

- .1 Sail switch.
- .2 Operating Velocity (m/s): 0.4 m/s-22.9 m/s.
- .3 Switching: SPDT.
- .4 Contact Ratings (AFL): N.O. Contacts: 2.0 A @ 24 VAC, 120 VAC.
- .5 Maximum Ambient Temperature: 52°C
- .6 Approvals: UL Listed, CSA.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- .1 Install equipment, components so that manufacturers' and CSA labels are visible and legible after commissioning is complete.
  - .2 Install field control devices in accordance with manufacturers' recommended methods, procedures and instructions.
  - .3 Temperature transmitters, humidity transmitters, current-to-pneumatic transducers, controllers, relays: install in NEMA I enclosure or as required for specific applications.
-



Provide for electrolytic isolation in cases when dissimilar metals make contact.

- .4 Support field-mounted panels, transmitters and sensors on pipe stands or channel brackets.
- .5 Fire stopping: provide space for fire stopping in accordance with Section 07 84 00 - Firestopping. Maintain fire rating integrity.
- .6 Electrical:
  - .1 Complete installation in accordance with Section 26 05 00 - Common Work Results - Electrical.
  - .2 Modify existing starters to provide for EMCS as indicated in I/O Summaries and as indicated.
  - .3 Refer to control schematics on drawings.
  - .4 Terminate wires with screw terminal type connectors suitable for wire size, and number of terminations.
  - .5 Install communication wiring in conduit.
    - .1 Provide complete conduit system to link Building Controllers, field panels and OWS(s).
    - .2 Conduit sizes to suit wiring requirements and to allow for future expansion capabilities specified for systems.
    - .3 Maximum conduit fill not to exceed 40%.
    - .4 Design drawings do not show conduit layout.
  - .6 Do not run exposed conduits in normally occupied spaces unless otherwise indicated or unless impossible to do otherwise.

### 3.2 TEMPERATURE AND HUMIDITY SENSORS

- .1 Stabilize to ensure minimum field adjustments or calibrations.
- .2 Readily accessible and adaptable to each type of application to allow for quick easy replacement and servicing without special tools or skills.
- .3 Outdoor installation:
  - .1 Protect from solar radiation and wind effects by non-corroding shields.
  - .2 Install in NEMA 4 enclosures.
- .4 Duct installations:
  - .1 Do not mount in dead air space.
  - .2 Locate within sensor vibration and velocity limits.
  - .3 Securely mount extended surface sensor used to sense average temperature.
- .4 Duct installations: (Cont'd)
  - .4 Thermally isolate elements from brackets and supports to respond to air temperature only.
  - .5 Support sensor element separately from coils, filter racks.
- .5 Averaging duct type temperature sensors.
  - .1 Install averaging element horizontally across the ductwork starting 300 mm from top of ductwork. Each additional horizontal run to be no more than 300 mm from

- one above it. Continue until complete cross sectional area of ductwork is covered. Use multiple sensors where single sensor does not meet required coverage.
- .2 Wire multiple sensors in series for low temperature protection applications.
- .3 Wire multiple sensors separately for temperature measurement.
- .4 Use software averaging algorithm to derive overall average for control purposes.
- .6 Thermowells: install for piping installations.
  - .1 Locate well in elbow where pipe diameter is less than well insertion length.
  - .2 Thermowell to restrict flow by less than 30%.
  - .3 Use thermal conducting paste inside wells.

### 3.3 PANELS

- .1 Arrange for conduit and tubing entry from top, bottom or either side.
- .2 Wiring and tubing within panels: locate in trays or individually clipped to back of panel.
- .3 Identify wiring and conduit clearly.
- .4 Provide duplex receptacle.

### 3.4 MAGNEHELIC PRESSURE INDICATORS

- .1 Install adjacent to fan system static pressure sensor and duct system velocity.
- .2 Locations: as indicated.

### 3.5 PRESSURE AND DIFFERENTIAL PRESSURE SWITCHES AND SENSORS

- .1 Install isolation valve and snubber on sensors between sensor and pressure source where code allows.
  - .1 Protect sensing elements on steam and high temperature hot water service with pigtail syphon between valve and sensor.

### 3.6 IDENTIFICATION

- .1 Identify field devices in accordance with Section 25 05 54 - EMCS: Identification.

### 3.7 TESTING AND COMMISSIONING

- .1 Calibrate and test field devices for accuracy and performance in accordance with Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.

END