

MOTOR SCHEDULE												
EQUIPMENT TAG	DESCRIPTION	MOTOR				MOTOR STARTER				CONNECTION	DISCONNECT SWITCH	COMMENTS
		VOLTS	PHASE	HZ	AMPS/KW/HP	MANUAL	MAGNETIC FVNR	VFD	COMBINATION FVNR			
VAV-1	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	25KW	-	-	-	-	DIRECT	-	-
VAV-2	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	25KW	-	-	-	-	DIRECT	-	-
VAV-3	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-4	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	15KW	-	-	-	-	DIRECT	-	-
VAV-5	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	15KW	-	-	-	-	DIRECT	-	-
VAV-6	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	15KW	-	-	-	-	DIRECT	-	-
VAV-7	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	15KW	-	-	-	-	DIRECT	-	-
VAV-8	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-9	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	8KW	-	-	-	-	DIRECT	-	-
VAV-10	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	8KW	-	-	-	-	DIRECT	-	-
VAV-11	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-12	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-13	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-14	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-15	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-16	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	15KW	-	-	-	-	DIRECT	-	-
VAV-17	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-18	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-19	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-20	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-21	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-22	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-22	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-??	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-23	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-24	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	15KW	-	-	-	-	DIRECT	-	-
VAV-25	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-26	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	8KW	-	-	-	-	DIRECT	-	-
VAV-27	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-28	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-29	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-30	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
VAV-31	VARIABLE AIR VOLUME TERMINAL UNIT	208	3	60	5KW	-	-	-	-	DIRECT	-	-
EF-1	EXHAUST FAN	208	3	60	0.75KW	-	-	-	-	DIRECT	YES	-
EF-2	EXHAUST FAN	208	3	60	0.19KW	-	-	-	-	DIRECT	YES	-
EF-3	EXHAUST FAN	208	3	60	0.37KW	-	-	-	-	DIRECT	YES	-
EF-4	EXHAUST FAN	208	3	60	0.12KW	-	-	-	-	DIRECT	YES	-
H-1	RANGE HOOD	-	-	-	-	-	-	-	-	DIRECT	-	SUPPLIED WITH LED LIGHTS AND EQUIPPED WITH FOG SUPPRESSION.
AHU-1	AIR HANDLING UNIT	600	3	60	40.5A	-	-	-	-	DIRECT	-	-
AHU-2	AIR HANDLING UNIT	600	3	60	8.8A	-	-	-	-	DIRECT	-	-
AHU-3	AIR HANDLING UNIT	600	3	60	11.5A	-	-	-	-	DIRECT	-	-
AHU-4	AIR HANDLING UNIT	600	3	60	8.8A	-	-	-	-	DIRECT	-	-
AHU-5	AIR HANDLING UNIT	600	3	60	11.5A	-	-	-	-	DIRECT	-	-
CD-1	CONDENSING UNIT	600	3	60	57.0A	-	-	-	-	DIRECT	-	SERVES AHU-1
CD-2	CONDENSING UNIT	600	3	60	12.2A	-	-	-	-	DIRECT	-	SERVES AHU-2
CD-3	CONDENSING UNIT	600	3	60	25.6A	-	-	-	-	DIRECT	-	SERVES AHU-3
CD-4	CONDENSING UNIT	600	3	60	18.0A	-	-	-	-	DIRECT	-	SERVES AHU-4
CD-5	CONDENSING UNIT	600	3	60	20.0A	-	-	-	-	DIRECT	-	SERVES AHU-5
UH-1	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-2	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-3	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-4	UNIT HEATER	208	3	60	5.0KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-5	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-6	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-7	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-8	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT
UH-9	UNIT HEATER	208	3	60	7.5KW	-	-	-	-	DIRECT	-	COMPLETE WITH PROGRAMMABLE THERMOSTAT



prime consultant:
ARCHITECTURE 49



F	ISSUED FOR TENDER	MAR 30 2017
E	ISSUED FOR 99% REVIEW	FEB 10 2017
D	ISSUED FOR 66% REVIEW	NOV 4 2016
C	ISSUED FOR 33% REVIEW	AUG 5 2016
B	DESIGN DEVELOPMENT	MAY 27 2016
A	DESIGN DEVELOPMENT	MAR 26 2016

revisions: [table with 2 columns: description, date]

project: **WABUSH ATB RENOVATIONS**
WABUSH AIRPORT WABUSH, NL

drawing: **MOTOR SCHEDULE**

designed: C.MACINTYRE
date: MAY 2016
drawn: M.KAMPHUIS
date: MAY 2016
approved: C.MACINTYRE
date: MAY 2016
Tender: [Signature] 2017/05/10
PWSC Project Manager / Administrateur de projets TPSCC
project number: **R.076412.001**
drawing no.: **E15**