



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1300 - 635 8 Ave SW**  
**Calgary, AB T2P3M3**  
**Bid Fax: (403) 292-4475**

**AMENDMENT / MODIFICATION**

**001**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**Suite 1300**  
**635 - 8 Ave SW**  
**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Asset Storage Building Elk Island National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-17-5080/A		<b>Date:</b> June 7, 2017
<b>GETS Reference No. - No de reference de SEAG</b> PW-17-00779765		<b>Amendment No. - N° de la modif.</b> 001
<b>Solicitation Closes:</b>		
<b>at - á</b> 02:00 PM	<b>on - le</b> June 9, 2017	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/>	<b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>		
Jen Maheu		
<b>Telephone No. - No de téléphone</b>		<b>Fax No. - No de FAX:</b>
(403) 292-8502		(403) 292-4475
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>		
See Herein - Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b> _____	
<b>Facsimile No. - N° de télécopieur:</b> _____	
<b>Signature</b>	<b>Date</b>

## Amendment 01

This amendment is being raised to distribute answers to bidder questions from the optional site visit on May 31, 2017 and questions submitted by email.

### Site Visit Attendees

Company Name	Representative's Name
Flex-co Construction Corp.	Lyle Mickalyk
Taurus Contractors Ltd.	Bert Jonas

### A) SITE VISIT QUESTIONS

**Q1** How many bay doors will Parks Canada be seeking for this building?

**A1** Parks Canada would requires four bay doors for the Asset equipment storage building. Doors to be centered along the front side of the building equally spaced.

**Q2** Is there any specific spacing between trusses that is not permitted?

**A2** The Contractor must abide by drawings stamped and approved by the successful bidders engineer prior to any construction.

**Q3** Will the Contractor have regular access to the work area within the gated compound?

**A3** Parks Canada will provide an entry code to the Contractor for the compound gate so that they may have regular access to the work area.

**Q4** Will the Contractor be allowed to perform concrete mixing on-site?

**A4** The mixing of concrete on-site is permissible, so long as the mix is monitored by the Parks Canada Departmental Representative for quality and consistency.

**Q5** In section 5.1 of the Statement of Work, an 'Annex A' is referenced, yet does not exist within the existing tender package.

**A5** Replace "Annex A" with "Section 8 - Environmental Procedures". The Contractor will refer to and abide by Parks Canada environmental best practices included in Section 8 ("Environmental Procedures") of the Statement of Work as found within the Tender Package.

### B) EMAILED QUESTIONS

**Q6** Item 3.7... Building will require four insulated overhead doors 16' wide by 14' high complete with automatic electric openers. Please confirm if there is an electrical scope of work required for this building?

**A6** There is no electrical scope of work, we are asking for the openers only to be installed on the doors and the electrical will be completed in a future phase.

**Q7** Item 3.7....All overhead doors on the building to be installed on the sidewall on the front side only.

Please confirm what elevations/elevation the doors are being located on? Are they all in the same wall?

**A7** The overhead doors will all be located on the front wall with equal spacing from the ends of the building.

**All other terms and conditions remain unchanged.**