



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving - PWGSC / Réception des soumissions  
- TPSGC**

**11 Laurier St./11 rue Laurier**

**Place du Portage, Phase III**

**Core 0B2 / Noyau 0B2**

**Gatineau, Québec K1A 0S5**

**Bid Fax: (819) 997-9776**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

This document contains a security requirement.

Ce document contient une condition de sécurité.

**Vendor/Firm Name and Address**

**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

11 Laurier St./11 Rue Laurier

3C2, Place du Portage

Phase III

Gatineau, Québec K1A 0S5

<b>Title - Sujet</b> WEST MEMORIAL BUILDING	
<b>Solicitation No. - N° de l'invitation</b> EH900-173240/A	<b>Amendment No. - N° modif.</b> 010
<b>Client Reference No. - N° de référence du client</b> 20173240	<b>Date</b> 2017-06-12
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-362-72725	
<b>File No. - N° de dossier</b> fg363.EH900-173240	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-22</b>	<b>Time Zone</b> Fuseau horaire Eastern Daylight Saving Time EDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Boivin, Emmanuelle	<b>Buyer Id - Id de l'acheteur</b> fg363
<b>Telephone No. - N° de téléphone</b> (819) 420-5352 ( )	<b>FAX No. - N° de FAX</b> (819) 956-8335
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> National Memorial Building Wellington Street, Ottawa, Ontario	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This amendment 010 is raised to:

1. Issue questions 31 to 40.
2. Issue Addendum #4

31	Please provide type and detail of door frame, pivot hinge and threshold to be restored as per Note #2 on sheet R11-01	Bid as per plans and specs. Information for existing entry doors can be found in the HMMP
32	Regarding article 1.4.3.1 in section 01 53 00, it states that we are to use Chain Link fencing for the storage area, but in the description, there's mention of Heavy Duty Welded Wire Fence. Please clarify which one is required	Bid as per plans and specs, section 01 53 00, 1.4.3
33	RFI 006: "We are to protect most of the baseboards on the ground floor as per the Heritage Action Plan, but per the Heritage Protection Plan and the Demolition Plans we are eliminating most of the partitions. Are we salvaging the baseboards? For example; Room #254. Heritage Action Plan shows the baseboards as covered terrazzo and we are to implement action "P" Retain and Protect. In the Heritage Protection Plans and Demolition Plans, we are eliminating all the walls in this room. What shall we do with the baseboards? Are we to protect only the baseboards on the walls that are staying? "	Bid as per plans and specs. Refer to sheet H16-03 for baseboard protection details and to sheet A16-01 and to spec section 024100 paragraph 3.3.6 for cutting terracotta block wall procedures.
34	RFI 011: Regarding article 3.1.1 in section 21 05 05 - there's a reference to Section 09 91 23-Interior Painting which is missing in the specs. Please provide this section.	Bid as per plans and specs. Article 3.1.1 does not apply to this project.
35	In Amendment 6, Question 22 regarding type of fence required. Response 22 "Bid as per plans and specs. Refer to Section 01 53 00, 1.4.3." does not clarify which type of fencing is required. Section 01 53 00, 1.4.3 refers to Chain Link fencing, but states something different(Welded Wire). Please clarify which type of fence is required, either chain link fencing <b>or</b> welded wire with square tube.	Bid as per plans and specs.  Refer to Section 01 53 00, 1.4.3.
36	The new plans show sloped insulation in the roof composition. An inverted roof system does not have sloped insulation; no supplier will approve this.  What is the existing roof assembly? We need to know what we are demolishing and whether there is pitch in the roof as	Bid as per plans and specs. Information for new inverted roof assembly can be found in 07 55 53.  Bid as per plans and specs. Sheet AD1 08 contains notes instructing the

	<p>in several old buildings; this is an hourly premium for our workers.</p> <p>Looking at A11 08 (roof plan) ; we do not see any mechanical penetrations such as roof vents &amp; roof anchors ; please provide details and quantity for these items and others mechanical/structural details if required.</p> <p>I was told to look at the plan details; there are no details corresponding to roof anchors or quantity thereof.</p> <p>Section 07 62 00 says to re-use existing copper sheets and replace damaged copper sheet metal, how much should we allow for replacement since we have not seen roof condition. No details were provided on the quantity to be replaced.</p>	<p>contractor to demolish the existing inverted roof assembly.</p> <p>Bid as per plans and specs. Refer to MD2 sheet series in the mechanical drawing set for plumbing to be demolished. Refer to Note 4 in general notes on the MD2 sheets. Refer to section 01 71 00 – Examination &amp; Preparation Bid as per plans and specs. Work specific to roof anchors is not in the scope of work, thus details have not been provided</p> <p>Bid as per plans and specs. Reuse sheet copper flashings in accordance with 07 62 00, 3.2.3</p>
37	Can you please clarify the tapered insulation layout. Our suppliers are not exactly sure which roof needs sloped insulation provided that some areas have sloped concrete toppings.	Bid as per plans and specs. Refer to Addendum 004. All roofs being replaced are inverted roofs and will not require insulation to be sloped
38	We are requesting an extension to the tender close in order to fully review and allow for all amendments issued to date.	Refer to Amendment 008
39	<p>If possible, I will need more information about Soft Padding.</p> <p>No problem. If possible, I will need technical data sheets or a list of suppliers for the materials in section 01 35 91 Part 2 Materials 2.1.4 for types 1, 2, 3 and 4. I am having a lot of difficulty finding sellers as they are unsure of the products requested. Also, if you have photos or samples of the products in question, would you be able to forward them to us?</p>	<p>Bid as per plans and specs.</p> <p>Specifications are not prescriptive, they are performance-based. Supplier lists or proprietary data sheets cannot be provided</p>
40	If that is the case I'd like to know as well if we are to allow for a complete replacement of the copper flashings or assume the copper is in good condition And reinstall them.	Bid as per plans and specs. Refer to Addendum 004. Assume new copper throughout

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**