

ADDENDUM No.: 004

Project Number: R.073422.209

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

SPECIFICATIONS

1. Index
Delete English and French versions;
Replace with attached new English and French versions.
2. Section 01 19 00 - 1.1.1
Delete 1.1.1 from English and French specifications.
3. Section 01 33 00 – Submittal Procedures
 - a. Delete French version
 - b. Replace with new attached French version
4. Section 01 35 91 – 1.1.8.1
Add: West Memorial Building Heritage Materials Testing Scope Results Report attached
5. Section 01 43 00 – Quality Assurance
 - a. Delete French version
 - b. Replace with new attached French version.
6. Section 02 41 00 – Demolition and Preparation for New Work
 - a. Delete French version
 - b. Replace with new attached French version.
7. 02 42 94 – Removal and Salvage of Heritage Doors
 - a. Delete 1.4.1 from English and French versions.
8. Section 02 42 96.01 – Removal and Salvage of Heritage Grilles
 - a. Delete 1.4.1 from English and French versions.
9. Section 02 42 97 – Removal and Salvage of Heritage Wood Elements
 - a. Delete 1.4.1 from English and French versions.
10. Section 23 07 13 – Duct Insulation
 - a. Add Section 23 07 13, English and French versions;
 - b. Insulate storm piping for first 5m from roof drain;
 - c. Existing rain water leader original to the building to be left in place if wall is not being demolished to remove other services. In areas where other services are being removed, rain water leaders to also be removed.
11. Section 07 62 00 – Sheet Metal Flashing and Trim
 - a. Delete 2.1.1 from English and French versions.
12. Section 21 13 13 – Wet Pipe Sprinkler Systems
 - a. Delete 1.5.1.1 from English and French versions.
13. Section 23 05 17 – Pipe Welding
 - a. Delete 1.4.1.1.4 from English and French versions.

14. Section 23 73 10 – 2.3.7.1
 - a. Delete 2.3.7.1 from English and French versions
 - b. Replace with Manufacturer shall provide a limited “parts only” warranty for a period of 12 months from the date of equipment start-up. Warranty shall cover material and workmanship that prove defective, within the specified warranty period, provided manufacturer’s written instructions for installations, operation and maintenance have been followed.

15. Section 26 05 30 – Electrical Seismic Control
 - a. Delete 2.1.1.1 from English and French versions.

16. Appendix
 - a. Add : Appendix-A “West Memorial Building, Heritage Materials Testing Results for Wood Paneling Dismantle”, English and French versions.

DRAWINGS

1. A16 02
 - a. Delete English and French versions
 - b. Replace with attached English and French Versions

End of Addendum