



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Tax Centre Relocation	
Solicitation No. - N° de l'invitation ET025-180168/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client CRA ET025-180168	Date 2017-06-13
GETS Reference No. - N° de référence de SEAG PW-\$PWU-909-11085	
File No. - N° de dossier PWU-7-40029 (909)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-21	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mayhew (RPC), Sylvia	Buyer Id - Id de l'acheteur pwu909
Telephone No. - N° de téléphone (780) 497-3645 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Department of Public Works and Government Services Canada on behalf of Canada Revenue Agency, See Herein.	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

3Solicitation No. - N° de l'invitation
ET025-180168/A
Client Ref. No. - N° de réf. du client
ET025-180168

Amd. No. - N° de la modif.
003
File No. - N° du dossier
PWU-7-40029

Buyer ID - Id de l'acheteur
pwu909
CCC No./N° CCC - FMS No./N° VME

This Amendment is raised to provide the following clarifications:

Q1. Do we have to provide and pay for the third party commissioning agent (Cx) or it is by the Owner? Please advise so we can price accordingly.

A1: No, commissioning to be completed by Contractor with Consultants and BGIS.

Q2. I have reviewed the specifications and would like to know if any window coverings/roller blinds will be required on this project?

A2. No

Q3. Could you please clarify is an asbestos survey for the area to be demolished available for this project?

A3. "An Asbestos Survey Report has been conducted for the affected areas of this project and can be made available to the successful bidder upon Contract Award. Please refer to drawings and specifications for identified remediation requirements."

Q4. Could you please provide more information on the "Acoustic Blanket" comment in the following...

C. PROVIDE NEW 610MM X1220MM (2'X4') VOLUMETRIC RECESSED LED TROFFER, 347V, 4000LM, 82CRI, 3500K. LIGHT FIXTURE SHALL BE COMPATIBLE WITH DIGITALLY ADDRESSABLE LIGHTING CONTROL SYSTEM. LIGHT FIXTURE SHALL BE RATED TO ALLOW ACOUSTIC BLANKET.

Does this mean that the contractor will be applying an acoustic blanket on the fixture above the ceiling?

A4. No Acoustic Blanket to be supplied in contract, Light fixture shall be "rated" to be compatible with Acoustic Blanket installation on fixture.

End of Amendment