



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Tax Centre Relocation	
<b>Solicitation No. - N° de l'invitation</b> ET025-180168/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> CRA ET025-180168	<b>Date</b> 2017-06-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-909-11085	
<b>File No. - N° de dossier</b> PWU-7-40029 (909)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-06-21</b>	<b>Time Zone</b> Fuseau horaire Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Mayhew (RPC), Sylvia	<b>Buyer Id - Id de l'acheteur</b> pwu909
<b>Telephone No. - N° de téléphone</b> (780) 497-3645 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Department of Public Works and Government Services Canada on behalf of Canada Revenue Agency, See Herein.	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
ET025-180168/A  
Client Ref. No. - N° de réf. du client  
ET025-180168

Amd. No. - N° de la modif.  
004  
File No. - N° du dossier  
PWU-7-40029

Buyer ID - Id de l'acheteur  
pwu909  
CCC No./N° CCC - FMS No./N° VME

---

This amendment is raised to provide the following clarifications and add Addendum 1 attached.

Q1. Specification section 01 14 00 – Work Restriction, paragraph 1.7.5.1.5 indicated *“Engage for security escort for personnel without reliability status, and for personnel performing work afterhours.”* Do we have to include the security escort cost in our price proposal? Are you going to allow us to use the personnel who doesn’t have PWGS Reliability Status Clearance for this project? Are you going to allow us to use General Contractor or Subcontractor who doesn’t have DOS clearance certificate? Please advise.

A2. No “escort cost” in price proposal required. Refer to Addendum 1 attached

Q2. I noticed that most of the openings require an STC rating of 45, is this correct? To achieve this rating they’ll be specialty doors and frames that come as a complete assembly and are allot more money than normal doors and frames. The spec does not have a section for these “acoustic assemblies”. Please clarify.

A2. The pressed steel frames are not required to be acoustically rated frames. Per the door hardware schedule and specifications, some openings are required to have acoustical seals and thresholds. Additionally, per the door schedule, some doors (without the frame) are required to have a minimum STC rating of 45.

End of Amendment

CRA Winnipeg Tax Centre Fit-Up  
66 Stapon Road, Winnipeg, Manitoba  
PWGSC Project No. R.078618

**ADDENDUM NO.1, June 15, 2017**

This addendum shall be read in conjunction with the drawings and specifications dated April 24, 2017 prepared for the above project. Where inconsistent with the drawings and specifications, this Addendum shall govern. The same conditions of the Contract and General Requirements shall apply to the Addendum as to the original drawings and specifications.

**TOTAL PAGES OF THIS ADDENDUM: 1, ATTACHED DOCUMENTS: None**

**ISSUED FOR CONSTRUCTION SPECIFICATIONS**

**Item No. 1:** Refer Specification Section 01 14 00 WORK RESTRICTIONS.

*Replace Part 1.7 SECURITY CLEARANCE REQUIREMENTS in its entirety with:*

**“ 1.7 SECURITY ESCORT:**

- .1 Personnel will be checked daily at start of work shift and provided with a pass that must be worn at all times. Each pass must be returned at end of work shift and personnel checked out.
- .2 Personnel employed on this project must be escorted when executing work in nonpublic areas.
- .3 Work performed afterhours requires security escort. ”

**Item No. 2:** Refer Specification Section 08 11 00 METAL DOORS AND FRAMES.

*DELETE FROM SECTION 2.7 FRAMES FABRICATION GENERAL “2.7.2 :Manufacture doors to minimum STC rating of 45, measured in accordance with ASTM E90.”*

*ADD TO SECTION 2.10 DOOR FABRICATION GENERAL “2.10.10 : Where indicated on Door Schedule, manufacture doors to minimum STC rating of 45, measured in accordance with ASTM E90.”*

**Item No. 3:** Refer Door Schedule on Sheet A4.5.

*Replace General Note #3 in its entirety with:*

**“ 3. ALL FRAMES TO BE PRESSED STEEL. INSULTATE INTERIOR FRAME COMPONENTS WITH POLYURETHANE INSULATION. “**

**END OF ADDENDUM**