



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving - PWGSC / Réception des soumissions  
- TPSGC**  
11 Laurier St. / 11, rue Laurier  
Place du Portage, Phase III  
Core 0B2 / Noyau 0B2  
Gatineau, Québec K1A 0S5  
Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Electrical & Electronics Products Division  
11 Laurier St./11, rue Laurier  
7B3, Place du Portage, Phase III  
Gatineau, Québec K1A 0S5

<b>Title - Sujet</b> Security Panel Replacement	
<b>Solicitation No. - N° de l'invitation</b> 21120-170603/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> 21120-170603	<b>Date</b> 2017-06-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$HN-465-72727	
<b>File No. - N° de dossier</b> hn465.21120-170603	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-06-27</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Nadeau, Alexandra	<b>Buyer Id - Id de l'acheteur</b> hn465
<b>Telephone No. - N° de téléphone</b> (819) 420-2859 ( )	<b>FAX No. - N° de FAX</b> (819) 953-4944
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This amendment 006 is being raised to address questions submitted by potential bidders.

---

1. Questions and Answers, All questions appear in their original format and language. The T.A's response appears in ***BOLD AND ITALIC***.

Q1) Within the STR (Issue 1.2 – May 16, 2017) – Specification ES/SPEC-0103 (UPS) is provided, but the only mention I see regarding UPS units is within Section 4.2.3 and it states to connect to “existing UPS supplied Power”, can you please confirm that no new UPS units are required and the contractor can utilize existing UPS units?

**A1) Utilize existing**

Q2) All Sites – For all hardware installation within each Living Unit, can a properly sized junction box be installed within each Utility Room to house the electronics?

**A2) Yes**

Q3) Amendment #001 – Provided pictures have been provided as a visualization of the existing installed hardware, can you confirm that the old hardware is to be removed and replaced with new hardware? Can the contractor re-purpose the existing junction boxes for the new hardware and I/O collection?

**A3) It is understood that this is in reference to WCHL; this is new equipment and can be retained if feasible with integration plans. Existing junction boxes may be repurposed if not.**

Q4) WCHL – It is noted that four (4) card readers are to be installed and integrated into the new Security Panel System, can you please confirm that the contractor is just required to accept a relay out from each of these four (4) doors to display on the new Control Station Monitors and that the Card Access Card Database is not required to be integrated into the new Security Panel System?

**A4) Card readers are existing, no new readers need to be installed. Confirmed on rest of question.**

Q5) Sask Pen (Riverbend) – During the site visit it was noted that the existing alarm panel system is routed through existing Fire Alarm conduit and Junction boxes, can this conduit be re-used or is the contractor required to supply and install all new conduit for the Security Alarm Panel Installation?

**A5) Conduit can be reused**

Q6) All Sites – For all fiber Optic cabling installed, can the DA please provide the minimum number of strands required per fiber optic run?

**A6) Minimum requirement to accommodate system plus 50% spare capacity**

Q7) All Sites – Is the contractor to assume that a conduit path from each building to the Main Building is in place and can be reused for the new Security Alarm Panel Installation?

**A7) Assume existing conduit is available, shortfalls discovered during installation can be accommodated via task authorization.**

Q8a) Sask Pen, SMI & Bowden – Each of these sites are equipped with a full MCCP (PIDS and FAAS), does the DA want all door alarms integrated into the existing PIDS ad FAAS for alarm monitoring?

**A8a) YES**

Q8b) If yes, can the DA confirm if the maps are to be bingo style or a graphical style?

**A8b) Bingo**

Q9) SMI (Rockwood) – For each of the housing units, is the contractor to bring fiber optic cabling to each of the houses or can the contractor determine means of collecting the alarm contacts by other means utilizing **new** cabling?

**A9) Fibre**

Solicitation No. - N° de l'invitation  
21120-170603/A  
Client Ref. No. - N° de réf. du client  
21120-170603

Amd. No. - N° de la modif.  
006  
File No. - N° du dossier  
HN465. 21120-170603

Buyer ID - Id de l'acheteur  
HN465  
CCC No./N° CCC - FMS No./N° VME

---

Q10) Sask Pen (Riverbend) - For each of the housing units, is the contractor to bring fiber optic cabling to each of the houses or can the contractor determine means of collecting the alarm contacts by other means utilizing **new** cabling?

**A10) Fibre**

Q11) Bowden (Annex) - For each of the housing units, is the contractor to bring fiber optic cabling to each of the houses or can the contractor determine means of collecting the alarm contacts by other means utilizing **new** cabling?

**A11) Fibre**

Q12) WCHL - For each of the housing units, is the contractor to bring fiber optic cabling to each of the houses or can the contractor determine means of collecting the alarm contacts by other means utilizing **new** cabling?

**A12) Fibre**

**ALL REMAINING TERMS AND CONDITIONS ARE UNCHANGED**