



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Hope Island, ON Demolition Proje	
Solicitation No. - N° de l'invitation EQ754-180161/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client EQ754-180161	Date 2017-06-14
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-7-40008 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-20	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Dhanna, Sheila	Buyer Id - Id de l'acheteur pwl003
Telephone No. - N° de téléphone (416) 512-5855 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Hope Island, Ontario Light Station	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur

EQ754-180161/A

4

PWL003

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

Project No.- No. du projet

R.078904.001

PROJECT TITLE

HOPE ISLAND (PENETANGUISHENE),
ON DEMOLITION PROJECT

The plans and specifications are amended as follows:

SPECIFICATIONS

1. Section 01 41 00 – REGULATORY REQUIREMENTS:
 1. Article 3.1.1 – IF SUSPECTED SPECIES-AT-RISK ARE ENCOUNTERED, STOP WORK AND CONTACT THE DEPARTMENTAL REPRESENTATIVE IMMEDIATELY has been added.
 2. Article 3.1.2 – IF NESTING BIRDS ARE ENCOUNTERED, STOP WORK AND CONTACT DEPARTMENTAL REPRESENTATIVE IMMEDIATELY. DO NOT DISTURB THE NEST UNTIL THE BIRDS HAVE PERMANENTLY LEFT THE NEST AS PER THE MIGRATORY BIRDS ACT has been added.
 3. Article 3.1.3 – A SPECIES-AT-RISK EVALUATION AND RELOCATION MAY BE UNDERTAKEN DURING THE PROJECT. CONTRACTOR IS TO STOP WORK AND/OR PROVIDE ASSISTANCE WHERE APPLICABLE ONCE DIRECTED TO BY THE DEPARTMENTAL REPRESENTATIVE TO FACILITATE THIS has been added.

QUESTIONS AND ANSWERS

1. Please clarify intended schedule and award date. Bidder need to understand whether this will be conducted in summer months or fall/winter conditions.

Answer: Please refer to Bid and Acceptance BA 04 and BA06.

It is PSPC intent to award this project as soon as possible, if a compliant bid has been received. As indicated in previous Addenda there is an in-water work restriction from September 15th to July 15th. All in-water work for this Project will need to be performed outside of this restriction window. It is anticipated that all work will be completed so as to not cause delays due to inclement weather.

2. Is it permissible to have the crew stay on the island during the project?

Answer: Yes Contractor is permitted. No assistance will be provided to the Contractor in this regard.

3. In regards to the above mentioned tender, specifically in regards to the lead paint, I have the following question:

Would you allow the lead paint to remain on the substrate and take a composite sample of the paint and substrate together in order to determine if the material is non-hazardous waste? Or are we to include costs for disposal of the lead paint and subsequent substrate as hazardous waste? If the latter is correct, we would need to find a barge that has an ECA (Environmental Compliance Approval) to haul hazardous waste across open water. Could you please confirm asap how we are to proceed?

Answer: Lead Paint can remain on substrate. A composite sample must be taken in order to determine if it is classified as hazardous waste. No material is to be removed from site before its classification has been determined. Suitable transport of the material to an approved disposal facility is required once its classification has been determined.

4. Will the winning contractor be allowed to Camp on the Site During the project, to insure 24 hours of site and equipment safety and security.

Answer: Yes Contractor is permitted. No assistance will be provided to the Contractor in this regard.

5. Will the winning contractor be required to utilize Transport Canada registered marine equipment and Transport Canada train and licenced captains and crews.

Answer: Yes.

6. Is the Contractor required to carry the client or their representatives to the island or back and forth to the island?

Answer: Yes. The Client and Departmental Representative will require transportation.

PART 1 - GENERAL

1.1 REFERENCES AND CODES

- .1 Perform Work in accordance with National Building Code of Canada (NBC)2015 including amendments up to tender closing date and other codes of provincial or local application provided that in case of conflict or discrepancy, more stringent requirements apply.
- .2 Meet or exceed requirements of:
 - .1 Contract documents.
 - .2 Specified standards, codes and referenced documents.

1.2 HAZARDOUS MATERIAL
DISCOVERY

- .1 Asbestos: demolition of spray or trowel-applied asbestos is hazardous to health. Stop work immediately when material resembling spray or trowel-applied asbestos is encountered during demolition work. Notify Departmental Representative.
- .2 PCB: Polychlorinated Biphenyl: stop work immediately when material resembling Polychlorinated Biphenyl is encountered during demolition work. Notify Departmental Representative.
- .3 Mould: stop work immediately when material resembling mould is encountered during demolition work. Notify Departmental Representative.

1.3 BUILDING SMOKING
ENVIRONMENT

- .1 Comply with smoking restrictions and municipal by - laws.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.

PART 3 - EXECUTION

3.1 SPECIES-AT-RISK

- .1 If suspected Species-At-Risk are encountered, stop work and contact the Departmental Representative immediately.
- .2 If nesting birds are encountered, stop work and contact Departmental Representative immediately. Do not disturb the nest until the birds have

permanently left the nest as per the Migratory
Birds Act.

- .3 A Species-At-Risk evaluation and relocation may be undertaken during the Project. Contractor is to stop work and/or provide assistance where applicable once directed to by the Departmental Representative to facilitate this.

END OF SECTION