



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Barn Roof Replacement	
Solicitation No. - N° de l'invitation EP922-180053/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EP922-180053	Date 2017-06-16
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11100	
File No. - N° de dossier PWU-7-40034 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-22	
Time Zone Fuseau horaire Mountain Daylight Saving Time MDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT No. 002

The following questions and answers are addressed to the specifications for clarification purposes only.

Question 1: Do you have more details on the specified Synthetic membrane?

Response: The Synthetic Membrane is referenced in Section 07 52 00, Clause 2.1.1n Synthetic Roofing Underlayment.

Question 2: Do you have a preferred product?

Response: Any commercially available product meeting the specification will be acceptable.

Question 3: Is a primer required for the Synthetic membrane?

Response: Membranes are to be applied according to manufacturer's recommendation, together with any supplementary instructions in the plans and specs.

Question 4: There are High/Low walls involved with the roofing. Is the metal cladding to be removed and sealed with the ice and water shield?

Response: The existing cladding on the short, vertical walls adjacent to the proposed roof repair needs to be removed in order to allow for new roof deck and flashing to be installed. After the roof deck and flashings are installed at the vertical walls, the existing vertical cladding needs to be re-installed. Adjustment to the vertical cladding panel length is not expected to be required for re-installation.

Question 5: Is there interest in a standing seam/hidden fastener system to reduce the amount of exposed penetrations?

Response: The roof system specified was chosen after consideration of alternative systems, including standing seam systems.

All other terms and conditions of the Invitation to Tender remain unchanged.