

The following additions, deletions & revisions form part of the drawings and specifications for the above referenced project:

SPECIFICATIONS

1. Reference Section 01 35 43 - Environmental Procedures:

.1 PART 3 – EXECUTION, add the following:

- “3.2 OIL DISPOSAL .1 The transformer shall be completely drained of oil. Once the oil has been removed, the transformer shall be disposed of as scrap metal. Removal of the oil shall be done at, or near the site.
- .2 Develop a plan to dispose of the non-PCB mineral oil. Although the oil does not contain PCBs, the oil shall not be placed in a non-secured landfill. The oil shall be disposed of using a licensed hazardous waste contractor.”

- END OF ELECTRICAL ADDENDUM NO. E-1 -

Goodkey, Weedmark & Associates Limited

Issued by: Richard Boivin, P.Eng., ing. /jvo



Distribution:

Rudy Pitton (PSPC)
Dave Harding (Cunliffe & Associates)
Ron Waghorn (Cunliffe & Associates)
Amy Girard (GWA – Electrical)
Eric Drouin (GWA – Electrical)
Roger Lavictoire (GWA – Electrical)