



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Rehabilitation of Buildings, York Factory National Historic Site		
Solicitation No.: / N° de l'invitation : 5P420-17-5149/A	Amendment No.: / N° de modification de l'invitation : 002	Date: June 21, 2017 Date : 21 juin 2017
GETS Reference No.: / N° de référence de SEAG : PW-17-00781563		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: June 27, 2017	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 27 juin 2017	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 002

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-17-5149/A:

A. QUESTIONS AND ANSWERS

Q1. Does the Stantec supply the stamped shop drawings or does the contractor have to have them drawn up?

A1. Stantec will not be providing shop drawings, the contractor has to draw them up.

Q2. Where is the power to run the electric winch coming from?

A2. The Field Unit will be using a generator for normal use.

All other terms and conditions remain the same.