

# Addendum/Addenda

Project Description / Description de projet 5378 - M2 Washrooms Renovation (phase 2) & 5379 – M59 Washrooms Renovation (phase 2)		
Solicitation No./ N° de sollicitation 17-22019	Project No./N° de projet 5378 / 5379	W.O. No./N° d'ordre de travail 765427
Departmental Representative / Représentant Ministériel Janik Leroux	Date June 20 <sup>th</sup> , 2017	
<b>Notice:</b> This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		<b>Note:</b> Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

**The following documents are part of the contractual documents and the bidders shall consider the described below services as part of their proposals:**

1. Addendum no. 3

**Clarifications:**

1. No office space is to be provided by NRC to the winning bidder.
2. The winning bidder will have to coordinate fire alarm bypasses through the NRC representative. NRC fire alarm system is by Chubb Edwards therefore, this is the service provider that must make the modifications on the system. Technicians of the electric company that will make modifications on the fire alarm system must have proper certification for fire alarm system related work.

End of Addendum 3