



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Washroom Replacements Elk Island National Park		
Solicitation No. - No. de l'invitation 5P420-17-5127/A		Date: June 22, 2017
GETS Reference No. - No de reference de SEAG PW-17-00781866		Amendment No. - N° de la modif. 002
Solicitation Closes:		
at - á 02:00 PM	on - le June 28, 2017	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jen Maheu		
Telephone No. - No de téléphone		Fax No. - No de FAX:
(403) 292-8502		(403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 02

This amendment is being raised to distribute questions and answers from the optional site visit and make changes to the tender package.

Site Visit Attendees

Company Name	Representative's Name
Allan Drummond Construction	Keith
"	JP
Brenex Building Corp	Robert Moore
Dee Jay Plumbing	Niki Schielke
Century	Ron Shaw
Willowridge Construction	Jordan R.
"	David Beck
Taurus Contractors	Bert Jonas
Flex-co Construction	Lyle Mickalyk

A) SITE VISIT QUESTIONS

Q1 What type of foundation slab is the existing buildings build on that will be demolished?

A1 Initial site investigations determine them to be grade beam slabs.

Q2 Will snow removal be done to access sites in the winter?

A2 Snow removal will be done by PCA staff to sites as required in the winter season.

Q3 Who is the contractor currently on site performing excavation work?

A3 The contractor completing the excavation work is MCL Group out of Acheson, Alberta.

Q4 What are the work hours?

A4 Monday to Friday 7:00am to 7:00pm until Oct 10 then additional days and hours can be requested.

B) TENDER PACKAGE

1. DRAWINGS

1.1 Drawing M7: Mechanical Schedules.

.1 Change KVG-1's "Description" in Plumbing Fixtures Schedule to "ValMatic Cam-Centric Rectangular Port Plug Valve 5800RN".

.2 Change KVG-1's "Accessories" in Plumbing Fixtures Schedule to "C/w Rotork IQT500 Actuator, adaption for valve to actuator. Actuator to be double sealed watertight enclosure, terminal box with two threaded cable entries, integral controls, valve position indicator to be located at the downstream of flow. Provide 120/1/60 on/off switch".

1.2 Drawing M3.B: Beach (#6080) – Plumbing Plans

.1 Modify Keynote 17: "By-pass valve access chamber/sump and valves arrangement as indicated. Prior to installation, contractor to check the dimensions, installation orientation of KGV-1 and its actuator, and coordinate with the two incoming sanitary lines, to ensure sufficient installation clearance in the sump pit is maintained. Refer to drawing 11/M06 for connection details"

2. Add the following document: *Building rehabilitation mitigations.pdf*

Solicitation No. - N° de l'invitation
5P420-17-5127/A

Amd. No. - N° de la modif.
002

Buyer - l'acheteur
Jen Maheu

Client Ref. No. - N° de réf. du client
515

File Name - Nom du dossier
Washroom Replacements - Elk Island National Park

All other terms and conditions remain unchanged.