



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

| | |
|---|---|
| Title - Sujet Wharf Construction - Caraquet,NB | |
| Solicitation No. - N° de l'invitation EC015-180071/A | Amendment No. - N° modif. 008 |
| Client Reference No. - N° de référence du client R.081895.001 | Date 2017-06-22 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWB-007-4124 | |
| File No. - N° de dossier PWB-7-40012 (007) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-06-29 | Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Ellis-Herring , Alison PWB | Buyer Id - Id de l'acheteur pwb007 |
| Telephone No. - N° de téléphone (506) 636-3908 () | FAX No. - N° de FAX (506) 636-4376 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
008

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. eight (8) is raised to include the following addendum no. 8.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 8

1. SPECIFICATIONS AND DRAWINGS – ELECTRICAL

| <u>ITEM</u> | <u>REFERENCE</u> | <u>DESCRIPTION</u> |
|-------------|------------------------------|---|
| 1. | DRAWINGS E21 & E23 | .1 ON DRAWING E21 DETAIL 1, ALL NOTES ON WIRING IN 103mm PVC CONDUITS ARE TO INCLUDE 1-103mm PVC SPARE CONDUIT AS PER ALL TRENCH DETAILS A-A TO H-H ON DRAWING E23. |
| 2. | SPEC SECTION 26 27 26.2 | .1 ALL SWITCHES, RECEPTACLES AND FISHERMAN'S OUTLETS ARE TO BE HUBBELL BRAND ONLY IN ORDER TO MATCH SWITCHES, RECEPTACLES AND FISHERMAN'S OUTLETS ON A RECENT MAJOR RENOVATION TO THE REMAINDER OF THE WHARF. THESE SPECIFIC RECEPTACLES ALSO MATCH THE RECEPTACLES AND FISHERMAN'S OUTLET PLUGS ON THE VESSELS THAT USE THE WHARF AND ALSO VESSELS FROM THE NEARBY SHIPPAGAN WHARF. .2 SPEC SECTION 26 27 26.2.3.3 - IN-USE WEATHERPROOF COVERPLATES FOR ALL 20A, 120V RECEPTACLES ARE TO BE CHANGED FROM HBL52CM21 AND HBL5830 TO LARGER METAL LOCKABLE COVERPLATES HUBBELL CAT. #MX5280SCN. |
| 3. | SPEC SECTION 26 05 31.2.3 | .1 THE APPROVED METAL FABRICATION SHOP SUB-CONTRACTED BY THE ELECTRICAL CONTRACTOR ON THE PROJECT SHALL REMOVE THE POWER CENTRES FROM THE WHARF WITH THEIR OWN PERSONNEL AND TRUCKS C/W HOISTS AND DELIVER THE POWER CENTRES TO THE METAL FABRICATION SHOP FOR UPGRADE AFTER WHICH THE METAL FABRICATION SHOP SHALL RETURN THE POWER CENTRES TO THE NEW CONCRETE FOUNDATION ON THE WHARF AND ENSURE THE POWER CENTRES ARE COMPLETELY LEVEL AND ALL DOORS AND WEATHERSTRIPPING FITS PROPERLY. THE ELECTRICAL SHALL NOT SUB-CONTRACT OUT ANY PORTION OF THIS WORK TO A THIRD PARTY. THE APPROVED METAL FABRICATOR SHALL ENSURE THAT THE POWER CENTRES ARE |

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
008

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

UPGRADED ON THE TRUE LEVEL FLOOR SURFACE IN
THE FABRICATION SHOP.

| <u>ITEM</u> | <u>REFERENCE</u> | <u>DESCRIPTION</u> |
|-------------|--------------------------|---|
| 4. | SPEC SECTION 26 50 00 | .1 THROUGHOUT THIS SECTION, THE ELECTRICAL CONTRACTOR SHALL SUPPLY, INSTALL, WIRE AND COMMISSION THE FIVE (5) LIGHT POLES C/W LUMINAIRE MOUNTING BRACKETS AND THE CARAQUET HARBOUR AUTHORITY SHALL SUPPLY THE 10 TYPE 'A' LIGHT FIXTURES ON SITE AND THE ELECTRICAL CONTRACTOR SHALL INSTALL, WIRE AND COMMISSION THE 10 TYPE 'A' LIGHT FIXTURES. .2 THE ELECTRICAL CONTRACTOR SHALL SUPPLY THE SHOP DRAWINGS ON THE POLES AND BRACKETS AND THE CARAQUET HARBOUR AUTHORITY SHALL SUPPLY THE SHOP DRAWINGS FOR THE TYPE 'A' LIGHT FIXTURES. .3 THE BIRD SPIKES ON THE LIGHT FIXTURES SHALL BE SUPPLIED BY THE HARBOUR AUTHORITY AND INSTALLED BY THE ELECTRICAL CONTRACTOR; AND THE ELECTRICAL CONTRACTOR SHALL SUPPLY AND INSTALL THE BIRD SPIKES ON THE MOUNTING ARMS. .4 THE ELECTRICAL CONTRACTOR WILL BE RESPONSIBLE FOR AIMING THE 10 LIGHT FIXTURES AT NIGHT-TIME UNDER THE DIRECTION OF THE ENGINEER. |
| 5. | DRAWING E4 NOTE 27 | .1 ELECTRONIC PAD LOCKING SYSTEM TO BE SUPPLIED, INSTALLED AND COMMISSIONED BY THE ELECTRICAL CONTRACTOR UNDER THIS CONTRACT. .2 ELECTRONIC PADLOCK SYSTEM TO BE PROVIDED FOR POWER CENTRES #15, AND #16 WITH EACH OF THE TWO (2) POWER CENTRES REQUIRING THREE (3) LOCKS EACH. MEDECO XT SYSTEM TO HAVE SIX (6) OUTDOOR PADLOCKS, NON-KEY RETAINING WITH 2.4mm SHACKLE CLEARANCE WITH CYLINDER (CAT. #5451F00 G). INDUSTRIAL KEY AND CHARGER BUNDLE TO INCLUDE CHARGER AND USB CABLE (CAT. #940239) AND PROGRAM DESKTOP MOUNT KIT (CAT. #940295). MOBILE PROGRAMMER COMPATIBLE WITH ANDROID PHONES (CAT. #EA-100125). INCLUDE TWO (2) YEAR ANNUAL SOFTWARE LICENSE, TRAINING AND COMMISSIONING. LOCAL AGENT IS CAPITAL SAFE & LOCK, FREDERICTON, NB (TEL: 1- |

Solicitation No. - N° de l'invitation
EC015-180071/A

Amd. No. - N° de la modif.
008

Buyer ID - Id de l'acheteur
PWB007

Client Ref. No. - N° de réf. du client
R.081895.001

File No. - N° du dossier
PWB-7-40012

CCC No./N° CCC - FMS No./N° VME

506-458-9811) OR EQUIVALENT SECURITY LOCK
SYSTEM AGENT.

| <u>ITEM</u> | <u>REFERENCE</u> | <u>DESCRIPTION</u> |
|-------------|--|---|
| 6. | SPEC SECTION 26 05 13.1.7.1 | .1 ALL ELECTRICAL EQUIPMENT NOT TO BE REUSED IS TO BE TURNED OVER TO THE HARBOUR AUTHORITY AT THE HARBOUR AUTHORITY MAINTENANCE GARAGE ON SITE. ALL REMOVED WIRE IS TO BE COILED WHEN REMOVED AND NOT CUT. .2 DELETE ITEM 26 05 13.1.7.4. |
| 7. | SPEC SECTION 26 05 00.1.6 | .1 INCLUDE IN TENDER PRICE ALL COSTS FOR NB POWER TO DE-ENERGIZE POWER SOURCE #4 WHEN ELECTRICAL WORK IS BEING COMPLETED TO POWER CENTRE #11. |
| 8. | DRAWINGS E4 & E8 | .1 IN POWER CENTRES PC12, PC13, PC14, PC15 AND PC16, ALL 20A, 1P, 120V CIRCUIT BREAKERS ARE GFI TYPE. |
| 9. | SPEC SECTION 26 05 31.2.3 DRAWINGS E15 TO E19 | .1 ITEM 18 AND 21 TO INCLUDE 25 X 25 X 3mm SQUARE TUBING WELDED TO THE INTERIOR OF THE DOOR AS DETAILED ON THE DRAWINGS. .2 ITEM 31 TO BE COORDINATED WITH THE SQUARE TUBING IN ITEM 1 ABOVE TO PROVIDE A METHOD TO INSTALL THE DOOR ALUMINUM FILTER WITHOUT BENDING THE FILTER. THE FILTER SHOULD BE INSTALLED FROM THE BOTTOM WITH A RETAINING CHANNEL. .3 ITEM 18 TO INCLUDE A 53mm ALUMINUM ANGLE 5mm THICK CONTINUOUSLY WELDED IN ALL INSIDE CORNERS OF THE ENCLOSURE TO STIFFEN THE ENCLOSURE. .4 THE ENCLOSURE WIDTH SHALL BE EXTENDED FROM 2200mm TO 2300mm IN ORDER TO ALLOW SPACE FOR THE DOOR LATCHES BETWEEN DOORS. THIS WILL REQUIRE THE CONCRETE PAD TO HAVE 25mm CHAMPFERS INSTEAD OF 75mm CHAMPFERS. |
| 10. | SPEC SECTION 26 27 26.2.2 | .1 EXHAUST FAN GUARDS ARE TO BE 316 GRADE STAINLESS STEEL OR COATED WITH ONE (1) COAT OF ZINC AND THREE (3) COATS OF MACRO EPOXY. .2 CANARM IS AN APPROVED MANUFACTURER OF THE EXHAUST FAN SYSTEM. |