



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Construction of Adult Handling Bldg	
Solicitation No. - N° de l'invitation F1700-176118/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1700-176118	Date 2017-06-23
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8082	
File No. - N° de dossier PWY-7-40056 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-07-04	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Inch Creek Hatchery - Dewdney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-176118/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
001
File No. - N° du dossier
pwy-7-40056

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

This Solicitation Amendment 001 is raised to incorporate responses to questions received.

All other terms and conditions remain unchanged.

Q1.) Request for Alternate Product: Wayne Dalton Rolling Service Doors

A1.) Wayne Dalton Rolling Service Doors:

- Contractor must ensure that the product meets all the design criteria per GEA dwg. 11-31-459, specifically wind load requirement.
- Wall opening height available is 3585 mm. Contractor to confirm that the door can be fitted in the available opening.
- Wall opening widths:
Nominal Door Size : 10'
As Designed Product dimensions
Wall opening 3500mm (+/- 11.5') 10'
Door clear opening 3050mm (+/- 10') 8'-9"

Nominal Door Size : 16'
As Designed Product dimensions
Wall opening 5400mm (+/- 17'- 8 1/2") 16'
Door clear opening 4880mm (+/- 16') 14'-8"

The contractor to confirm if the product dimensions can be modified to fit the doors in the available wall opening per GEA dwg. 11-31-443.

Q2.) Request for Alternate Product: Cornell Innovative Door Solutions

A2.) Cornell Innovative Door Solutions

- Contractor must ensure that the product meets all the design criteria per GEA dwg. 11-31-459, specifically wind load requirement.
- Wall opening height available is 3585 mm. Contractor to confirm that the door can be fitted in the available opening.
- Wall opening widths:

Nominal Door Size : 10'

As Designed Product dimensions

Wall opening 3500mm (+/- 11.5') 10'

Door clear opening 3050mm (+/- 10') 8'-10 1/2"

Nominal Door Size : 16'

As Designed Product dimensions

Wall opening 5400mm (+/- 17'- 8 1/2") Information not available Door clear opening
4880mm (+/- 16') Information not available

The contractor to confirm if the product dimensions can be modified to fit the doors in the available wall opening per GEA dwg.11-31-443.