



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Construction of Adult Handling Bldg	
Solicitation No. - N° de l'invitation F1700-176118/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1700-176118	Date 2017-06-23
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8082	
File No. - N° de dossier PWY-7-40056 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-07-04	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Inch Creek Hatchery - Dewdney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-176118/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
001
File No. - N° du dossier
pwy-7-40056

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 001 is raised to incorporate responses to questions received.

All other terms and conditions remain unchanged.

Q1.) Request for Alternate Product: Wayne Dalton Rolling Service Doors

A1.) Wayne Dalton Rolling Service Doors:

- Contractor must ensure that the product meets all the design criteria per GEA dwg. 11-31-459, specifically wind load requirement.
- Wall opening height available is 3585 mm. Contractor to confirm that the door can be fitted in the available opening.
- Wall opening widths:
Nominal Door Size : 10'
As Designed Product dimensions
Wall opening 3500mm (+/- 11.5') 10'
Door clear opening 3050mm (+/- 10') 8'-9"

Nominal Door Size : 16'
As Designed Product dimensions
Wall opening 5400mm (+/- 17'- 8 1/2") 16'
Door clear opening 4880mm (+/- 16') 14'-8"

The contractor to confirm if the product dimensions can be modified to fit the doors in the available wall opening per GEA dwg.11-31-443.

Q2.) Request for Alternate Product: Cornell Innovative Door Solutions

A2.) Cornell Innovative Door Solutions

- Contractor must ensure that the product meets all the design criteria per GEA dwg. 11-31-459, specifically wind load requirement.
- Wall opening height available is 3585 mm. Contractor to confirm that the door can be fitted in the available opening.
- Wall opening widths:

Nominal Door Size : 10'

As Designed Product dimensions

Wall opening 3500mm (+/- 11.5') 10'

Door clear opening 3050mm (+/- 10') 8'-10 1/2"

Nominal Door Size : 16'

As Designed Product dimensions

Wall opening 5400mm (+/- 17'- 8 1/2") Information not available Door clear opening

4880mm (+/- 16') Information not available

The contractor to confirm if the product dimensions can be modified to fit the doors in the available wall opening per GEA dwg.11-31-443.