



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

001

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Water and Wastewater Controls Replacement Prince Albert National Park		
Solicitation No. - No. de l'invitation 5P420-17-5122/A		Date: June 28, 2017
GETS Reference No. - No de reference de SEAG PW-17-00782424		Amendment No. - N° de la modif. 001
Solicitation Closes:		
at - à 02:00 PM	on - le July 5, 2017	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Jen Maheu		
Telephone No. - No de téléphone (403) 292-8502		Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 01

This amendment is being raised to distribute clarifications from the mandatory site visit on June 21, 2017.

A. SITE VISIT ATTENDEES

Company Name	Representative's Name
Flyer Electric	Kris Krueger
Triad Power	Garnet Connolly

B. CLARIFICATIONS

1. Coordination of system changeovers:
 - a. Some equipment and processes can be run manually.
 - b. The successful bidder will need to present a changeover plan and schedule followed by a meeting with the Park and Engineer.
 - c. This topic is covered in 1.4 of Section 01 11 00, Summary of Work.
2. A Parks Canada staff member drove the route of the fibre-optic underground run and provided an approximate distance figure of 1.5 km.
3. The underground trenching for the fibre-optic installation should be backfilled, tamped, and brought back to original surface condition. Trenching through asphalt areas should be patched with asphalt cold mix.
4. At the Water Tower, conduit should be installed alongside the ladder structure for running the coaxial cable to the antenna near the top of the railing at the tank elevation. The coax cable should not be installed alongside the other coax cables running from the communications building. The height of the water tower is 100 feet to the top.

All other terms and conditions remain unchanged.