

PROJECT TITLE

GRAVENHURST, ONTARIO  
BEAVER CREEK INSTITUTION - MEDIUM  
CORRECTIONAL SERVICE CANADA  
2000 BEAVER CREEK DRIVE

ROOF REPLACEMENT

AMENDMENT No.1, dated Wednesday, June 28, 2017

This Amendment shall form part of documents referred to in the  
"Bid and Acceptance Form"

The Plans and Specifications are amended as follows:

01 14 00 - WORK RESTRICTIONS

Sub Section 1.1 Clause .3:

Add .1 Building "D" and "J" to be completed as Phase 1 and Phase 2  
respectively.

Sub Section 1.2 Clause .5.2:

Add .1 Travel between work areas and staging and storage areas is the sole  
responsibility of contractor and at contractor's cost.

01 32 16 - CONSTRUCTION PROGRESS SCHEDULE - BAR CHART

Sub Section 1.7:

Add .3 Preconstruction meeting, Bi-weekly construction meeting, Certificate of  
Substantial Performance meeting and Certificate of Completion meeting all  
on site.

01 33 00 - SUBMITTAL PROCEDURES

Sub Section 1.2:

Revise Clause .4 "Allow 3 working days..." to read "Allow 7 working days..."

01 35 00 - Fire Safety Requirements for Roofing

Sub Section 1.2:

Revise Clause .3 "...Evacuation plan in place at the site. Departmental  
Representative will provide Building, Facility, Tenant's Emergency Procedures  
and Evacuation Plan. Deliver two copies..." to read "...Evacuation Plan in place  
at the site. Deliver two copies..."

## 01 51 00 - Temporary Utilities

### Sub Section 1.7:

Revise Clause .1 "...maximum supply of 120 volts 30 amps." to read  
"...maximum supply of 120 volts 15 amps, 1 Receptacle."

## 01 56 00 - Temporary Barriers and Enclosures

### Sub Section 1.12, Clause .1:

Add .1 Provide for protection of all interior finishes, fittings and interior equipment in areas of roof removable and installation. Extend interior protection beyond below roof areas to ensure and prevent water damage to interior finishes, fittings and equipment.

### Sub Section 1.12:

Revise Clause .3 "...installation schedule 3 days prior..." to read  
"...installation schedule 7 days prior..."

## 01 74 20 - Construction-Demolition Waste Management and Disposal

### Sub Section 1.1, clause .2 Sub-Clause .2:

Add .6 Insulation and Roof materials.

## 07 52 00 - Modified Bitumen Membrane Roofing

### Sub Section 1.4, clause .2:

Add .1 Building "D" and "J" to be completed as Phase 1 and Phase 2 respectively.

### Sub Section 1.4, clause .5:

Revise Sub-Clause .3 "...bidder has necessary resources and expertise..." to read "...bidder has necessary trade resources and expertise..."

### Sub Section 1.5, clause .1:

Revise Sub-Clause .1 "...experience and pre-approved by manufacture for installation..." to read "...experience and manufacture approved for installation..."

### Sub Section 1.9, clause .1:

Revise Sub-Clause .1 "...with Contractor's Warranty for Workmanship on a Canadian Roofing Contractor's Association (CRCA) approved form..." to read "...with Contractor's Warranty for Workmanship on an Ontario Industrial Roofing Contractors Association (OIRCA) approved form..."

07 52 00 - Modified Bitumen Membrane Roofing (Con't.)

Sub Section 1.9, clause .1:

Revise Sub-Clause .2 "...from 12 months to 24 months from date..." to  
read "...from 12 months to 36 months from date..."

Sub Section 3.15, clause .1:

Add .2 Contractor responsible at contractor' cost to inspect all  
work, reviewed and re-reviewed made good defective work by  
Electrical Safety Authority (ESA).

END