



Fisheries and Oceans  
Canada

Pêches et Océans  
Canada

Procurement Hub – Ottawa Office,  
Station 9W081, 9th Floor,  
200 Kent Street,  
Ottawa, Ontario K1A 0E6

June 28, 2017

**ADDENDUM NO. 1**

Subject: **ITT Invitation to Tender No. FP802-170091  
Design Build - Tower and Foundation Replacements**

Dear Sir/Madam:

Further to the above-mentioned Request for Proposal, this Addendum (#1) is to advise potential bidders of the question(s) received during this tender call to date. Both the question(s) and the response(s) are indicated in the attached Annex A

**Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.**

Yours truly,

(Original signed by)

**Beverly Shawana**  
Senior Contracting Officer,  
Financial & Materials Management Operations

**RECEIPT ACKNOWLEDGED**

Name of Company  
Signature \_\_\_\_\_

**Canada**

## Annex A

### Questions

- Q1. What is the approx. weight of the new towers?
- Q2. Can the existing towers be dismantled /cut to return to the CCG in Parry Sound?
- Q3. Can you please confirm the height of the new concrete foundation at LL 1420.7 Three Sisters?

### Answers

- A1. The tower is approximately 400 kg.
- A2. Yes. The dismantled/cut towers shall be returned to CCG in Parry Sound as indicated in Section 024116, 1.1.1.1
- A3. The height of the concrete shall be 0.5 m.