


ITEM	QUANT	DESCRIPTION
92		EP RELAY SWITCH
50		SUMMER WINTER THERMOSTAT
49		COOLING THERMOSTAT

STORK-WERKSPOR CANADA 47 MARIE-VICTORIN, V.I.C. TEL: (514) 859-8571 CANDIAC, QUE. TELE: 055-82387 J5R186 CABLE: "MARSHMONT"	
TITLE/TITRE A/C PLANTS S1, S2 ELECTRIC DIAGRAM (SPLIT SYSTEM)	
CUSTOMER/CLIENT 456-457 HULL/COQUE NAV AID 1100	
MARINE INDUSTRIE LTEE	
SCALE NTS ECHELLE NTS CONTRACT/CONTRAT MH 1047 A 6AA DATE DEC 9 REV 35	NO 1047-25 DATE DEC 9 REV 35



— BY STORK
 - - - BY SHIPYARD
 * * * * PNEUMATIC PIPING BY SHIPYARD



ITEM	QUANT	DESCRIPTION	REV
43A	2	1/2 FPT GATE VALVE	
85	2	HUMIDISTAT	PNEUMATIC
41	2	GAUGE VALVE 1/4 FPT	
44A	2	3/4 FLG GLOBE VALVE (BYPASS)	
44	4	3/4 FLG GATE VALVES	
43	3	1/2 FLG GATE VALVES	
42	1	PRESS. REDUCING VALVE	
40	1	BYPASS GAUGE 0-11 BAR	
39	1	BYPASS GAUGE 0-2 BAR	
37	1	3/4" STEAM CHECK VALVE	
36	2	1/2" TRAP	
35	2	1/8" REGULATOR	PNEUMATIC
34	2	3/4" SOLENOID VALVE	
33	2	3/4" STRAINER	
32	1	1/2" "	
31	2	HIGH LIMIT SWITCH	PNEUMATIC
30	2	EZE STEAM HUMIDIFIER	
30A	2	C/W STEAM CONTROL VALVE	PNEUMATIC
30B	2	SEPARATOR	
30C	2	COND. TRAP 3/4 FPT	

STEAM HUMIDIFIER
 TYPICAL HORIZONTAL INSTALLATION
 I-LEFT HAND MOUNTED (SHOWN)
 I-RIGHT HAND MOUNTED

NOTES:

- 1) (M) CONTROL AIR SUPPLY 20 PSI MAX (1.4 KG/CM²)
- 2) STL. FITTINGS ON STEAM SUPPLY TO BE AS FOLLOWS:
 - MINIMUM PRESSURE 150 PSIG (10.5 KG/CM²)
 - FITTINGS 1 1/4" & MORE TO BE FLANGED
 - FITTINGS UNDER 1 1/4" TO BE SOCKET WELL

STORK-WERKSPOR CANADA	
47 MARIE-VICTORIN CANDIAC QUE J5R 1B6	TEL: (514) 659-6671 TELEX: 055-62387 CABLE: "MARSHMONT"
TITLE/TITRE STEAM FLOW DIAGRAM FOR AC PLANTS s1 & s2	
CUSTOMER/CLIENT 950-451 HULL/COQUE NAV AID 1100	
MARINE INDUSTRIES LTEE	
SCALE Echelle NT5	CONTRACT/CONTRAT MH 1047-22
DN DES PCAS VER 1.0	DWG/DES 1047-22
NO DATE ISSUES	REV 2



94	1	PNEU. PRESS REDUCER	
92	1	PNEU. E.F. RELAY SWITCH	
91	2	PNEU. TEMP. CONTROLLER	
90	1	PNEU. DAMPER OPERATOR % LINKAGE	
85	1	HUMIDISTAT "PNEU"	
62	6	FAN RUBBER MOUNTS	
60	1	STEEL BASE	
59	1	SUCT./LIQ HT. EXCHANGER	
53	1	TXV.	
52	1	LIQ. SOL. VALVE	
44A	1	ST. GATE VALVE	3/4 FLG.
44	2	ST. GATE VALVE	3/4 FLG.
43A	?	ST GATE VALVE	1/2 FLG.
30A	1	STEAM CONTROL VALVE	
37	1	STEAM CHECK VALVE	
36	1	STEAM TRAP	
35	1	STEAM REGULATOR "PNEU."	
34	1	STEAM SOL. VAL % 120 COIL	
33	1	STEAM STRAINER	
32	1	STEAM STRAINER	
31	1	HIGH LIMIT SW. "PNEU"	
30	1	STEAM HUMIDIFIER "PNEU."	
29	1	TRANSITION	
27	1	FLEXIBLE CONN. "INLET"	
26	1	CENT. FAN C.C.W., UP-BLAST DISH.	
24	2	FILTERS	
23	1	AIR HANDLING UNIT R.H. CONN.	
22	1	FLEXIBLE CONN. "OUTLET"	

[illegible]