

Addendum/Addenda

Project Description / Description de projet 5378 - M2 Washrooms Renovation (phase 2) & 5379 – M59 Washrooms Renovation (phase 2)		
Solicitation No./ N° de sollicitation 17-22019	Project No./N° de projet 5378 / 5379	W.O. No./N° d'ordre de travail 765427
Departmental Representative / Représentant Ministériel Mark O'Connor	Date June 29 th , 2017	
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Note: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

The following documents are part of the contractual documents and the bidders shall consider the described below services as part of their proposals:

1. Addendum no. 5
2. Addendum no M1 from Goodkey Weedmark

Clarifications:

1. Bidders to refer to the attached mechanical addendum from Goodkey Weedmark.

End of Addendum 5

The following additions, deletions & revisions form part of the drawings and specifications for the above referenced project:

SPECIFICATIONS

1. Reference Section 23 82 36 – Finned Tube & Radiant Panels:

.1 Item 2.2.8, revise as follows:

“.8 Acceptable materials: TWA panels, Airtex (Engineered Air), Rittling, Sigma panels, **Rosemex.**

DRAWINGS

1. Reference Drawing M0.1:

.1 Remove exhaust fan (EF1) from fan schedule.

.2 EF2 to come c/w curb adapter to mount new fan on existing roof curb.

.3 Refer to detail 1/M.1, remove note “Roofing work to be included in bid price as cash allowance.”

- END OF MECHANICAL ADDENDUM NO. M-1 -

Goodkey, Weedmark & Associates Limited

Issued by: Scott Vallier /kr



Distribution:

Isabelle D'Amour-Tanguay (NRC)

Allan Smith (NRC)

Jeremy Van Dyke (Edward J. Cuhacci & Assoc. Arch. Inc.)

Ryan Leonard (GWA – Mechanical)

Richard Boivin (GWA – Electrical)

Amy Girard (GWA – Electrical)