



**Addendum / Addenda**

No./N<sup>o</sup>  
5

Project Description / Description de projet <b>WIN - Fire Alarm Replacement</b>		
Solicitation No./ No de sollicitation <b>17-22017</b>	Project No./N <sup>o</sup> de projet <b>WIN-A1-011387-01</b>	W.O. No./N <sup>o</sup> d'ordre de travail
Project Engineer / Ingénieur de projet <b>L. Lalonde (204)896-1209</b>		Date <b>June 28, 2017</b>
<b>Notice:</b> This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		<b>Nota:</b> Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

**ADDENDUM**

**Responses to RFIs Submitted by Contractor:**

*Q: Please have the following clarified.*

*Sprinkler switch replacement*

*In regards to the note on drawings regarding Sprinkler Switches for Flow, Tamper, Pressure to be replaced.*

*In building (WPG01) most of the tamper valves can just have the switch replace.*

*In building ( WPG01) all the valves in stair 1 will require the valve totally be replaced.*

*Please clarify if just switches need to be replaced where possible and where not possible replace valve as required.*

**A: Replacing only fire alarm modules under the scop of this project to match the new fire alarm system for monitoring of pressure, flow or tamper for a full ULC compliant system. No sprinkler work is considered under this project.**

*Q: Key Notes 1 on the drawings are requesting new sprinkler flow, tamper and pressure switches in the same locations as the existing devices. Is the intent to replace the existing Fire Alarm modules or is the Intent to replace the sprinkler system devices also?*

**A: Replacing only fire alarm modules under the scop of this project to match the new fire alarm system for monitoring of pressure, flow or tamper for a full ULC compliant system. No sprinkler work is considered under this project.**