



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Snowshed Column Rehabilitation, Trans-Canada Highway, Glacier National Park		
Solicitation No.: / N° de l'invitation : 5P420-17-5163/A	Amendment No.: / N° de modification de l'invitation : 002	Date: July 3, 2017 Date : 3 juillet 2017
GETS Reference No.: / N° de référence de SEAG : PW-17-00782066		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: July 5, 2017	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 5 juillet 2017	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 002

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-17-5163/A:

A. BID CLOSING DATE

Q1. Will we be allowed to move both lanes of traffic onto 1 side of the tunnel in order to complete certain critical tasks such as Concrete pours?

A1. Except for the purpose of initially establishing the traffic control set up, moving both lanes of traffic to one side of the tunnel will not be permitted.

Q2. Further to Specification 03 30 00 Cast-In-Place Concrete Part 2.1 Acceptable Concrete Repair Products: Item 4 States – Other Products accepted by the department Representative. Will SCC Ready Mix Concrete be acceptable?

A2. SCC Ready Mix Concrete may be acceptable, but will be subject to a detailed review of the mix design and performance. Review of a proposed mix will not be completed during the tender period

All other terms and conditions remain the same.