

PANEL: A1											
LOCATION: P1			VOLTAGE: 120/240VAC			AIC RATING: 10KA					
SUPPLY FROM: PANEL - NEW OVERHEAD			PHASES: 1			MAINS TYPE: CU					
ENCLOSURE: NEMA 4X			NUMBER OF WIRES: 3			MAINS RATING: 200 AMP					
MOUNTING: SURFACE						MCB RATING: 200 AMP					
CKT	CIRCUIT DESCRIPTION	TRIP	POLES	A	B	POLES	TRIP	CIRCUIT DESCRIPTION	CKT		
1	DUPLEX RECEPTACLE (POLE 1)	20A	1			1	15A	LIGHTING (POLE 1)	2		
3	DUPLEX RECEPTACLE (POLE 1)	20A	1			2	175 A	PANEL A2	4		
5	PANEL A3	60A	2						6		
7											8
9	SPARE	15A	1					SPARE	10		
11									12		

PANEL: A2											
LOCATION: P2			VOLTAGE: 120/240VAC			AIC RATING: 10KA					
SUPPLY FROM: PANEL - A1			PHASES: 1			MAINS TYPE: CU					
ENCLOSURE: NEMA 4X			NUMBER OF WIRES: 3			MAINS RATING: 200 AMP					
MOUNTING: SURFACE						MCB RATING: 200 AMP					
CKT	CIRCUIT DESCRIPTION	TRIP	POLES	A	B	POLES	TRIP	CIRCUIT DESCRIPTION	CKT		
1	DUPLEX RECEPTACLE (POLE 2)	20A	1			1	15A	LIGHTING (POLE 2)	2		
3	DUPLEX RECEPTACLE (POLE 2)	20A	1			1	15A	LIGHTING (POLE 3)	4		
5	WELDING PLUG	50A	2			1	15A	LIGHTING (POLE 4)	6		
7								1	15A	LIGHTING (POLE 5)	8
9	DUPLEX RECEPTACLE (POLE 3)	20A	1			1	20A	DUPLEX RECEPTACLE (POLE 5)	10		
11	DUPLEX RECEPTACLE (POLE 3)	20A	1			1	20A	DUPLEX RECEPTACLE (POLE 5)	12		
13	DUPLEX RECEPTACLE (POLE 4)	20A	1			1	15A	SPARE	14		
15	DUPLEX RECEPTACLE (POLE 4)	20A	1			1	15A	SPARE	16		
17									18		

PANEL: A3											
LOCATION: BAIT SHED			VOLTAGE: 120/240VAC			AIC RATING: 10KA					
SUPPLY FROM: PANEL - A1			PHASES: 1			MAINS TYPE: CU					
ENCLOSURE: NEMA 4X			NUMBER OF WIRES: 3			MAINS RATING: 100 AMP					
MOUNTING: SURFACE						MCB RATING: 60 AMP					
CKT	CIRCUIT DESCRIPTION	TRIP	POLES	A	B	POLES	TRIP	CIRCUIT DESCRIPTION	CKT		
1	DUPLEX RECEPTACLE (BAIT SHED)	15A	1			1	15A	SPARE	2		
3	SPARE	15A	1						4		
5									6		
7									8		
9									10		
11									12		

LUMINAIRE SCHEDULE					
TAG	DESCRIPTION	LAMPS	VOLTS	MOUNTING	MOUNTING HEIGHT
A	OUTDOOR POLE MOUNTED FIXTURE, TYPE 3 DISTRIBUTION, 4000K 16000 LUMENS, BLACK IN COLOR WITH BIRD SPIKE.	LED	120	POLE	-

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

EA Engineering
 Electrical Engineering | Project Management | Thermal Imaging
 PO BOX 594 CHARLOTTETOWN PEI C1A 7J1
 PHONE: 802 394-8881 craig@eaeng.ca
 WWW.EAENG.CA



1	ISSUED FOR TENDER	JUN 23 2017
revisions		date

project: **WHARF RECONSTRUCTION 408 MONTAGUE KINGS COUNTY, PEI**

drawing: **SCHEDULES**

designed: C.M. / conçu
 date: JUNE, 2017
 drawn: R.C. / dessiné
 date: JUNE, 2017
 approved: C.M. / approuvé
 date: JUNE, 2017
 Tender: *Craig Macclure* / Soumission
 PWGSC Project Manager / Administrateur de projets TPSGC

project number: **R.084160.001**

drawing no.: **E3 of 3**

