

June 30, 2017

SASKATOON RESEARCH AND DEVELOPMENT CENTRE
CONTRACT NO. 37 – HEATING LINE REPLACEMENT
CONTRACT #465-1-28-C37

Addendum #2

Questions and Answers

Q1 - What percentage / ratio of glycol mix would you like installed into the new lines?

A1 - Glycol ratio is 30% glycol.

Q2 - Please confirm you want the dimensions as stated in the tender, the existing main supply and return lines are both 2" in diameter.

A2 - The piping sizes are all in the blue prints that were provided after the mandatory site meeting.

Q3 - Is there an option to complete the work working a night shift? (This would allow for a shorter project turnover time, less overall cost and less collaboration between lab occupants would be necessary)

A3- Work can only be completed during the day.

Q4 - Please confirm that we can drain both the main lines and all ancillary lines to all radiator panels simultaneously.

A4 – Yes that will be acceptable.

Colby Collinge
Materiel Manager AAFC
Regina, Saskatchewan